

Asset Management Plan

2026–2036



Enquiries

Enquiries, submissions, or comments about this Asset Management Plan (AMP) can be directed to:

General Manager: Asset Management **OR** Engineering Manager (Networks)

PowerNet Limited,
PO Box 1642,
Invercargill, 9840

Phone: (03) 211 1899

Fax: (03) 211 1880

Email: amp@powernet.co.nz



This Asset Management Plan (AMP) is available for public disclosure and applies for the period 1 April 2026 to 31 March 2036.

© Electricity Invercargill Limited (EIL) 2026

Front cover image: Civic Theatre Invercargill. Photo credit: The Civic Theatre

Liability Disclaimer

The information and statements made in this AMP are prepared on assumptions, projections, and forecasts. It represents Electricity Invercargill's intentions and opinions at the date of issue (31 March 2026).

Due to global uncertainties, assumptions and forecasts in the AMP may prove to be wrong, events may occur that were not predicted, and Electricity Invercargill could decide to take different actions than planned. Electricity Invercargill may also change any information in this document at any time. EIL accepts no liability for any action, inaction, or failure to act based on this AMP.



View from Bluff Hill Lookout

Tēnā koe,

I am pleased to introduce the Electricity Invercargill Limited (EIL) 2026 Asset Management Plan (AMP). The 2026 AMP reflects an ongoing need to replace ageing assets plus developing responses to known and foreseen changes in our operating environment. These changes include: evolving regulatory requirements, the impact of renewable energy transition, the changes in customer needs and expectations, and an increase in adverse weather events. The EIL Board has considered these factors carefully in approving this AMP, which sets out how EIL will manage risk, investment and service performance in the coming decade.

Our largely underground network continues to deliver tangible benefits for customers by reducing exposure to adverse weather events. The resilience this provides remains a strategic advantage for Invercargill, preserving a high level of network reliability.

As the network ages, we have an evidence-based programme for ongoing asset replacement that is driven by asset condition assessments. The AMP includes a total forecast expenditure of \$158.5 million over the next 10 years, with around 44.2% of the capital investment being on asset replacements.

In this AMP, we have realigned priorities to reflect stakeholder feedback. We have drawn on updated analysis of customer surveys and stakeholder engagement to better inform service level targets, placing particular emphasis on: continuity of supply, responsiveness to faults and enquiries, and voltage quality. These targets guide investment choices and operational performance measures going forward.

Through PowerNet our network management service provider, we continue to seek network management improvements and efficiencies by further innovation. One example is how we use smart meter data and analytics. The insights this provides will be used to improve fault detection, enable proactive management of LV constraints and to support safe, efficient integration of rooftop solar and other distributed resources. Related to this, our plan also incorporates revised, electrification-driven demand scenarios to ensure our network is prepared for a range of future outcomes.

I am confident that this Asset Management Plan positions EIL to meet both current obligations and future challenges, preserving service quality for our customers while responsibly managing risk and investment.



Stephen Lewis

Chair of the Board of Directors
Electricity Invercargill Limited

CONTENTS

Abbreviations, Acronyms and Definitions	6
2026–2036 AMP Summary	9
1 Introduction	17
1.1 Our Supply Area and Customers	18
1.2 How we prepare and communicate our AMP	19
1.3 Assumptions	20
1.4 Potential Variation Factors	23
2 Our Business Environment.....	25
2.1 Our Purpose and Strategy	26
2.2 Our ownership, governance, and network management	27
2.3 Our Stakeholders and their Interests	28
2.4 External Business Influences.....	32
2.5 Commerce Commission Determination – Financial Impact.....	33
2.6 Planning Processes	33
2.7 Structure and Accountabilities	37
2.8 Incorporating customer requirements in our network planning	39
2.9 Quality of Service (Regulated Service Levels)	40
3 The Network and Asset Base	41
3.1 Bulk Supply Points and Embedded Generation.....	42
3.2 Sub-transmission Network.....	42
3.3 Zone Substations.....	45
3.4 Distribution Network.....	48
3.5 LV Network	54
3.6 Customer Connections	57
3.7 Assets for Control and Auxiliary Functions	57
3.8 Summary of EIL asset base.....	59
3.9 Load Characteristics	61
4 Risk Management	65
4.1 Risk Strategy and Policy.....	66
4.2 Risk Management Methods	66
4.3 Company related risks (general).....	70
4.4 Asset Management Risks	72
4.5 System Risks	83
4.6 Asset Criticality	85
4.7 Price Elasticity of Demand.....	85

CONTENTS

5	Service Levels	87
5.1	Customer Oriented Service Levels	88
5.2	Efficiency Levels	92
5.3	Service Level Justification	93
5.4	Service Level Target Setting	93
6	Asset Management Strategy	97
6.1	Lifecycle Stages	98
6.2	Lifecycle Support	101
6.3	Lifecycle Management and Growth	102
6.4	Fleet Plans	102
7	Capital Expenditure	103
7.1	Asset and Network Development Planning	104
7.2	Asset and Network Design	124
7.3	Asset Acquisition	133
7.4	Commissioning of Assets	139
7.5	Retiring and Disposal of Assets	140
7.6	Capital Expenditure Forecast	141
8	Operating Expenditure	145
8.1	The Operation and Maintenance Lifecycle Phase	146
8.2	Asset Maintenance	148
8.3	Asset Operation	155
8.4	Operational Expenditure Forecast	157
9	Execution Capacity	159
9.1	People, Culture and Leadership	161
9.2	Funding the Business	162
9.3	Information Management	163
10	Evaluation of Performance	169
10.1	Progress against Plan	170
10.2	Service Level Performance	171
10.3	AMMAT Performance	173
10.4	Gap Analysis and Planned Improvements	174
10.5	Benchmarking	174
	Annexures	185
	Annexure 1 – Policies, Standards and Procedures	186
	Annexure 2 – Customer Engagement Questionnaire	190
	Annexure 3 – Disclosure Schedules	198
	Annexure 4 – References	224
	Annexure 5 – AMP Disclosure Table	225
	Annexure 6 – Directors’ Approval	237

This AMP can be found at: www.eil.co.nz/disclosures/asset-management-plan

ABBREVIATIONS, ACRONYMS AND DEFINITIONS

ABC	Aerial Bundled Conductor	MAR	Maximum Allowable Revenue
ABP	Annual Business Plan	MBIE	Ministry of Business, Innovation and Employment
ABS	Air Break Switch	MD	Maximum Demand
ALARP	As Low as Reasonably Practicable	MDI	Maximum Demand Indicator
AMIS	Asset Management Information System	MV	Medium Voltage
AMP	Asset Management Plan	NEM	Network Equipment Movement
AWP	Annual Works Program	NER	Neutral Earthing Resistor
CAPEX	Capital Expenditure	O&M	Operations and Maintenance / Operate and Maintain
CBD	Central Business District	ODV	Optimised Deprival Valuation
CCTO	Council Controlled Trading Organisation	OHL	Overhead Line
CES	Customer Engagement Survey	OHUG	Overhead to Underground
CIMS	Coordinated Incident Management System	OJV	OtagoNet Joint Venture (where OJV is used it generally includes the Lakeland network (LNL) unless the context indicates otherwise)
DC	Direct Current	OPEX	Operating Expenditure
DG	Distributed Generation	PILC	Paper Insulated Lead Covered
DGA	Dissolved Gas Analysis	PNL	PowerNet Limited
DIN	Deutsches Institut für Normung (the German Institute for Standardization)	RCP	Regulatory Control Period
DPP	Default Price-Quality Path	RMU	Ring Main Unit
EDB	Electricity Distribution Business	ROI	Return on Investment
EEA	Electricity Engineers' Association	RTU	Remote Terminal Unit
EIL	Electricity Invercargill Limited	SAIDI	System Average Interruption Duration Index
ENA	Electricity Network Aotearoa	SAIFI	System Average Interruption Frequency Index
ESL	Electricity Southland Limited	SCADA	Supervisory Control and Data Acquisition
GIS	Geographic Information System	SLT	Senior Leadership Team
GPS	Global Positioning System	SOI	Statement of Intent
GXP	Grid Exit Point	SWHT	Southland Warm Homes Trust
HILP	High Impact Low Probability	TCOL	Tap Change on Load
Holdco	Invercargill City Holdings	TOU	Time of Use
HRC	High Rupture Capacity	TPCL	The Power Company Limited
HVBT	High Voltage Busbar Insulation Tape	TPM	Transmission Pricing Methodology
ICP	Interconnection Point	UILP	Utilities Industry Liability Programme
IED	Intelligent Electronic Device	VRR	Voltage Regulating Relay
IoT	Internet of Things	XLPE	Cross-Linked Polyethylene
KPI	Key Performance Indicator		
LSI	Lower South Island		
LV	Low Voltage		

ABBREVIATIONS, ACRONYMS AND DEFINITIONS

Customers means the entities connected to the local lines company, which can be households or businesses. Most customers do not have a direct relationship with their local lines company. Rather, they will engage with an electricity retailer to which they pay their bill.

Flexibility services refer to the ability to adjust power generation or consumption in response to real-time grid conditions. These services include:

- Demand-Side Response (DSR) – Customers reduce or shift their electricity use based on grid needs, often incentivized by financial rewards.
- Distributed Energy Resources (DERs) – Small-scale generation (e.g., solar, batteries, EVs) provides flexibility by injecting power into the grid when needed.
- Energy Storage – Batteries and other storage systems absorb excess electricity and release it during peak demand.
- Generation Flexibility – Power plants adjust their output dynamically to balance supply and demand.
- Network Reconfiguration – Grid operators optimize how electricity flows by switching between different network configurations.

EIL
Electricity Invercargill Ltd



Rugby Park Southland. Photo: Envious Photography



Burt Munro Challenge Rally Site. Photo: Great South



Murihiku Polyfest. Photo: Anjelina Nikora Wilson



2026–2036 AMP Summary



Southland A&P Show, Photo: Great South




Queens Park. Photo: Jeremy Pierce

Electricity Invercargill Limited (EIL) is the council-owned electricity distribution network that services Invercargill City and the Bluff township.

Our Asset Management Plan (AMP) describes our network and forecasts the capital and operational budget needed to continue to provide high reliability and to support demand growth. The plan also assesses past network performance and infrastructure asset management practices, identifying opportunities for improvements.

This summary provides key information from our 2026 review of our AMP and identifies steps EIL is taking to ensure our network is well placed to support changes in electricity usage and increased demand for electricity supply.



92%

Of line and cable length underground



17,774

Consumer Connections




250

GWh supplied per year



Where we fit in the electricity industry



Generation

Electricity is generated using a variety of resources – water, geothermal, gas, wind, coal, and solar.

Transmission

Transpower owns and operates the high voltage transmission system that transports electricity from generators to local distribution networks.

Distribution

High voltage electricity is stepped down at substations, then the **EIL** network distributes it safely to local residential and business consumers using our network of poles, lines, and underground cables. **PowerNet** manages our network for us.

Retail

The retailer measures how much power each customer uses, and sends each customer their power bill. Some of what is paid to retailers comes to us to cover the cost of investing in and maintaining a reliable network.

Customers

Our customers are the households and businesses in Invercargill City and Bluff, who use the electricity provided to power their home or business.

How we operate our network

EIL has a Network Management Agreement (NMA) with PowerNet. Through this agreement, PowerNet is responsible for the operational management of EIL’s electricity network and asset management activities. EIL retains ownership, governance and strategic accountability for the network and its investment programme. PowerNet reports to EIL’s General Manager on operational matters relating to the delivery of services.



PowerNet is an electricity network management company. It was established in 1994 to achieve scale benefits through integrated network management across the Southern region’s Electricity Distribution Businesses (EDBs).

PowerNet provides services to over 76,000 customers through more than 14,300 circuit kilometres and manages the fourth-largest suite of EDB assets in New Zealand. With its head office in Invercargill, the company has over 300 staff based at depots in Invercargill, Lumsden, Gore, Balclutha, Te Anau, Frankton and Stewart Island.

Asset management is at the core of PowerNet’s business capability. Its network management maturity and capability provide strong and structured asset management practices - from fleet plans for asset classes, to structured inspection and testing regimes for ground-mounted assets (poles, transformers, ring main units, air-break switches) and underground assets such as cables.

PowerNet has achieved ISO 55001 certification, which is the international standard for asset management. It has also developed and implemented the award-winning health and safety software, RiskMentor.





The Langlands. Photo: Andrei Robertson

Ensuring Invercargill has the electricity network it needs for the future

Electricity networks have an essential role to play in enabling and supporting businesses and households to reduce their use of fossil fuels and lower carbon emissions.

To ensure that we have the required network infrastructure to provide the capacity and reliability that our customers need, we plan to spend **\$158.5 million** over the next 10 years on developing and maintaining the EIL network.

Our 10-year capital and operating expenditure plan enables a programme of work to mature our asset management capability, support customer growth, and improve our service provision for customers.

\$93.1m

Planned network capital expenditure over the next 10 years

\$24.0m

Planned network operating expenditure over the next 10 years

\$41.4m

Network support services cost over the next 10 years


Investing to maintain leading network reliability

Most of our network is underground, which enables EIL to be one of the most reliable networks in New Zealand. However, because the network was converted to underground over a 50-year period from the 1960s, the cables are approaching the end of their useful life.

To continue to provide the high level of reliability that EIL customers are used to, we are committed to replacing end-of-life assets and extending the life of other assets where appropriate, such as the oil-filled cable programme.

Asset replacements and renewals are a dominant driver of our capital expenditure program. We estimate that our capital expenditure on asset renewal and replacement over the next 10 years will be approximately \$70.0 million.

Planned capital expenditure, 2026/27 to 2035/36





Esk Street. Photo: Stacy Williamson

Proudly supporting the rejuvenation of Invercargill City

After completing our multiyear involvement with the Invercargill CBD redevelopment, we continue with the phase of connecting customers. With few expected capacity constraints within the network, we are enabling economic growth in our region by meeting customer requests for new connections and supporting major developments. With the revitalisation of the CBD area, our new connections have included retailers and hospitality businesses.

Upcoming developments within our network area that will create a demand for new connections include the Te Puāwai residential housing development. This is set to be the biggest housing development for Invercargill in decades, creating more than 600 sections and including a commercial hub and retirement village.



Anderson Park Southland. Photo: Jeremy Pierce



Photo: Sebastian Katzlese

Monitoring EV Charging Patterns

On the EIL network, extra demand from electrification is expected primarily from space heating and transport electrification, as opposed to large industrial process heat conversions that are occurring in other parts of Southland. As a result, we do not foresee significant network constraints on our High Voltage (HV) or Medium Voltage (MV) networks, and this is reflected in a relatively low system growth capital expenditure. Our use of data analytics allows us to monitor for congestion on our LV networks.

Ownership of electric vehicles (EVs) is relatively low in Southland. EVs account for around 0.6% of the vehicle fleet in Southland, compared with 2.4% nationally. While we expect EV uptake to accelerate, the impact on electricity demand is highly uncertain and depends on when and where drivers choose to charge their vehicles. The relatively slower EV uptake in Southland means that we can observe how EV charging demand evolves in other regions.



Ongoing innovation to deliver better services for our customers

We are a partner in SmartCo, which has developed the Hiko Energy electronic tools that use data from our smart meters to improve network management and customer outcomes. The Hiko Energy tools provide us with a dashboard highlighting congested LV networks, giving us valuable information for our network planning and management. This year's AMP incorporates greater reliance on smart meter data and analytics to help us prioritise investments and to optimise the network.

We also use Hiko Energy tools for pre-emptive fault management. For example, we can identify potential neutral faults in LV networks. By identifying these faults promptly, we can improve the safety of our network and reduce the likelihood of damage to customers' electrical equipment.

The Hiko Energy tools also allow us to identify customers who have their own generation installed but are experiencing voltage issues. By identifying these issues, we can help our customers address the problem leading to safe and efficient solar integration.

Our major capital projects

investing for safety, efficiency and reliability

We have the following key network initiatives to replace end-of-life assets and improve the safety, reliability and efficiency of our network:


- **Improving safety at zone substations and on the distribution network** – Replacement of the near end-of-life 11 kV switchboard at the Racecourse Road substation, and the refurbishment of a power transformer at the Leven Street substation if condition assessment shows this is needed.
- **Ongoing replacements of Ring Main Unit (RMU)** – We expect to spend \$2.9 million in each of the next 3 years to replace end-of-life RMUs as they reach end of life and risk of failure increases. Our replacement programme prioritises those RMUs that present the highest level of risk.
- **Replacing Low Voltage tie port disconnectors** – We plan to spend \$1.4 million over the next 5 years to install disconnector switches at all LV tie points on the network. This means that when PowerNet needs to de-energise distribution substations to carry out maintenance on RMUs they will no longer need to manually connect live conductors together at tie points using cable taps. In addition to this safety benefit, this project is expected to reduce the switching time associated with a de-energisation by over 75% and reduce wear and tear from manual handling of cables.

Ongoing investment programmes include:

- Upgrading the network where needed to maintain voltage quality
- Improving the efficiency of our network by replacing assets with high losses and exchanging overloaded distribution transformers with units that have sufficient capacity
- Extending remote monitoring and control to distribution devices
- Various other safety, environmental, and other projects

Operating and maintaining our network

Our fleet plans are fundamental to our expenditure planning process. These plans describe how each asset will be managed over its entire lifecycle, enabling us to plan routine testing and maintenance, determine the resourcing and equipment needed to operate and maintain the assets, and to better estimate both operating and capital expenditure for the next 10 to 20 years.



Our resulting 10-year operating expenditure forecast includes:

\$15.7m

For routine and corrective maintenance and inspections


\$6.4m

For restoring services when there are outages and emergencies


\$1.9m

For operational support of asset replacement and renewal

Our operating expenditure plan



Our capital expenditure plan






Network reliability targets


We commission annual customer surveys and use the results to set target service levels. These surveys show that customers most highly value continuity and restoration. We also ensure that the target service levels adhere to the price-quality regulatory regime that is administered by the Commerce Commission.

We use two internationally accepted indices to measure performance for outage duration and outage frequency: SAIDI (System Average Interruption Duration Index) and SAIFI (System Average Interruption Frequency Index).


For health and safety purposes, we have implemented restrictions relating to Halo Ring Main Units (RMUs), which has increased our SAIDI minutes. Despite this, our SAIDI remains among the lowest in the country.



Average outage duration across the year (SAIDI) – actual and target



Average outage frequency across the year (SAIFI) – actual and target



1

Introduction

SECTION CONTENTS

1	Introduction	18
1.1	Our Supply Area and Customers	18
1.2	How we prepare and communicate our AMP	19
1.3	Assumptions	20
1.4	Potential Variation Factors	23

1 INTRODUCTION

Our Asset Management Plan (AMP) demonstrates the internal governance and asset management framework for EIL's network to achieve the services levels and strategy set out in Chapters 5 and 6. It is also intended to meet the requirements of Electricity Distribution Information Disclosure Determination as amended on 27 November 2024 for the ten-year planning period from 1 April 2026 to 31 March 2036.

The purpose of EIL's Asset Management Plan (AMP) is to:

- enable EIL to deliver a capable, reliable and safe electricity distribution network, with a secure and stable Regulated Asset Base and optimum sustainable returns to shareholders (section 2),
- document the nature, extent, age, utilisation, condition, performance and value of assets managed by EIL (section 3),
- describe how EIL identifies and manages risk (section 4),
- identify existing and proposed levels of service to be achieved over a five-year period, as well as any expected changes in services expectations and/or demand (section 5),
- document our asset management strategy to outline the life-cycle management needs (development, renewal, operations and maintenance and any disposal) over the five-year period (section 6),
- identify capital and operational budget needs and funding implications (sections 7 and 8) and the associated capacity and resourcing requirements (section 9), and
- assess the prevailing infrastructure asset management practice and identify further improvements (section 10).

The remainder of this section provides a description of the geographical area and customers that the EIL network serves, and then discusses how we prepare and communicate our AMP, the key assumptions that we have relied on, and possible variations from those assumptions.


1.1 Our Supply Area and Customers

EIL's service area includes two geographically separate areas.

- The part of Invercargill bounded by Racecourse Road to the east, the Waihopai Stream to the north and west (except for Invercargill Airport which is in EIL's area) and Elizabeth, Moulson and Brown Streets and Tramway Road to the south, as shown in Figure 1.
- The borough of Bluff extending as far west as the former Ocean Beach freezing works, as shown in Figure 2.

Bluff, which has less than 25km of distribution lines and less than 2000 ICPs connected, is not considered a sub-network and therefore values presented in this AMP for EIL are inclusive of the Bluff area network, except where explicitly stated otherwise. The topography is densely urban and built-up in both Invercargill and Bluff. Invercargill is a flat area (lying about 3m to 5m above sea level), whilst Bluff varies from flat to steep hills.

Figure 1: Invercargill Distribution Area



Electricity Invercargill Limited (EIL) owns the electricity lines network that conveys electricity to the majority of Invercargill and Bluff, supplying approximately 17,774 customers.

The Invercargill distribution area is predominantly residential but does include a medium-sized CBD, a heavy industrial area immediately west of the CBD and a light industrial area in the southeast.

Currently EIL's largest customer is Southport Limited, a large port in the Bluff distribution area which regularly peaks at about 1.6MW and consumes approximately 6.5GWh per year. Decarbonisation initiatives involving the change from coal boilers to electricity powered heating systems may change this. The Bluff distribution area also includes port associated heavy industries as well as residential and commercial customers.

Figure 2: Bluff Distribution Area



1.2 How we prepare and communicate our AMP

Through the NMA, EIL works with PowerNet's Asset Management team to prepare and finalise the AMP.

EIL also approves the Annual Works Programme (AWP) and the Annual Business Plan (ABP). The AWP details the capital and operation expenditure forecasts for the next ten years being produced as part of the development of the AMP. The ABP incorporates the first three years of the AMP along with any recent strategic, commercial, asset or operational issues. The ABP defines the priorities and actions for the year ahead. It informs the Statement of Intent (SOI), which is the interface between EIL and its shareholders Invercargill City Holdings Limited (ICHL).

Customer perceptions and expectations are compiled from surveys and customer consultations. These results are compared with the performance targets set in the previous year's AMP. Any improvements or changes deemed appropriate are incorporated into the AMP and AWP as necessary. The survey used for this document is the August 2025 survey.

Management and Operations Participation

Progress against the AWP is monitored and variations supervised as they arise with large capital projects. Progress and variations are addressed in formal monthly review meetings. Any changes are consolidated into the initial AWP revision.

The development of the AWP tends to be iterative with a level of trade-off reached between what is considered an optimal level of works against realistic expectations of the work force available. We use "smoothing" of the year-to-year works variation to keep a relatively constant and manageable work stream for both internal and external workforce resources, however longer-term variations need to be met by adjusting the resources available.

Governance Participation

Business cases required for large capital projects or other papers covering any non-business-as-usual projects are submitted in advance and will be included in the AWP. The EIL Board may require changes that reflect both asset management and commercial aspects and recognise the need to address any identified health and safety related issues.

Post Disclosure Communication

Once the first draft of the AMP has been approved, network engineers start producing project scopes for routine and non-routine projects that will be initiated future financial year. These scopes are passed to the relevant project managers to ensure that sufficient detail has been provided for each project in the AWP to proceed in line with the planner's expectation.

EIL monitors progress against the AMP through reporting on the outcomes of the following meetings:

- Monthly Major Project review meetings to assess progress on significant projects,
- Monthly Business Review meetings to assess business performance,
- Quarterly Management reviews to assess the effectiveness of the various management systems as well the integrated Business Management System, and
- Monthly Safety meetings per depot and a monthly Safety Leaders meeting.

This reporting contains information on safety performance, network performance and asset health for specific asset classes identified by the Board.

1.3 Assumptions

Although not published in the AMP, we develop demand forecast scenarios and publish the most likely scenario. We evaluate these scenarios against their likelihood of occurrence based on what we know of the external environment and our knowledge of the network asset health. In our planning we assume that the most likely scenario will eventuate. This minimises variation to performance targets over the short to medium term. Exceptions are, for example, building additional capacity early resulting in a slight overinvestment, where building additional capacity too late may have much greater consequences such as equipment damage or inability to supply customer load.

EIL estimates the asset life based on industry standards, current engineering knowledge and experience. Actual replacement is done based on condition, performance, remaining economic life and work efficiency. Generally, the expected asset life is conservative as borne out by the actual failure rates of equipment. Equipment housed indoors will often exceed the expected asset life, whereas in the harsh coastal environment assets tend to have a shorter life. The replacement and maintenance decision-making framework is constantly being refined to more accurately reflect the risk per individual asset. This is envisaged to be in line with the UK regulator's (OFGEM) disclosure requirements but adapted to also fit New Zealand's regulatory requirements. This will be a three-year process.

Recent changes to Temporary Traffic Management (TTM) requirements and updates to the Electricity (Hazards from Trees) Regulations have placed increasing cost pressure on both capital and operational activities. In some cases, TTM costs now account for more than half of total project expenditure. A 2024 Beca report, "Assessment of Costs of Carrying Out Works in the Road Corridor for Electricity Distribution Businesses" commissioned by the Electricity Networks Association (ENA), identified a 208% increase in TTM costs between 2019 and 2024, with a further 26% increase expected by 2026.

The introduction of the New Zealand Guide to Temporary Traffic Management (NZGTTM), replacing the former CoPTTM framework, is transitioning the industry to a more risk-based approach to traffic management. This change is expected to improve efficiency over time.

The Electricity (Hazards from Trees) Amendment Regulations 2024, effective from 17 October 2024, have also introduced new requirements such as extended growth limit zones and expanded notice zones, with further amendments expected to be formalised in late 2025. These evolving regulatory settings are expected to continue influencing work planning, delivery costs, and programme timing over the DPP4 period.

We estimate project costs and timeframes based on previous experience, market analysis and anticipated resourcing. Other than the disclosure schedules included in Appendix 3, all figures are expressed in 2026 dollars and assume an exchange rate of 1 NZ\$ to 0.60 US\$ (where applicable).

Table 1: Assumptions and Implications

Assumption	Discussion & Implications
General demand growth for existing customers tracks close to projected rates.	Prediction of demand growth based on “ground-up” analysis is uncertain, due to the many variables that affect potential growth. The way this is being addressed is through developing scenarios that take the variables into account and choosing the most likely outcome
New housing developments and smaller (<1MW) decarbonisation initiatives are additional to the general growth.	Actual demands may depart significantly from short term forecasts but becomes more predictable in the longer term. This is due to uncertainty in the timing of developments which in turn is due to market conditions and supply chain constraints. Static or declining growth rates in specific areas mean investments to accommodate previously projected growth are deferred and funds are reallocated. The higher growth rate scenario require adjustment in EIL’s resourcing and/or work scheduling to be able to respond to these opportunities.
Single large customer driven growth (such as supplies to data centres and electrode boilers) is likely to continue, albeit under a different funding mechanism. This may not occur on the EIL network but will affect the bulk supply to EIL. However, the aggregate of a large number of smaller decarbonisation initiatives will affect demand across the network.	Customers such as Open Country Dairy and Alliance are making huge investments to replace coal fired thermal processes with electricity-based processes, driven by GIDI funding. Southland is seen as an attractive environment within which to establish data centres. This is due to the colder climate, reducing cooling needs as well as the geographical location relative to Sydney which increases the viability of submarine fibre optic cable. The scenarios that were developed are for load increases of between 20MVA and 150MVA on Invercargill and North Makarewa GXP’s with a likely scenario of 100MVA in the area. This will take up the spare capacity at the GXP’s and on the subtransmission networks, decreasing the overall resilience of the network. Increased numbers of applications are leading to resource constraints for the analysis and implementation of supply options
Small-scale (household) distributed generation is expected to have little coincidence with network peak demand, and therefore will have little impact on network configuration within the ten-year planning horizon. This may however start to change as the increased tariffs envisaged in the DPP4 period start to take effect.	Increased injection of generation, especially during periods of low demand, could create voltage issues. Increased connection requests for distributed generation will require increased resourcing to analyse potential issues arising from connection (particularly safety and voltage) This assumption will need to be reviewed should battery storage become more economical compared to buying electricity from a retailer. This will allow usage to be shifted into peak times and reduce peak load on the LV network.
Electric Vehicle (EV) adoption rate is within the national forecast range. Customers respond well to price signals so that vehicle charging occurs mainly off-peak.	EV charging may have a large impact on networks. If customers do not respond well to price signals or if retailers do not send the right price signals, EV charging may exacerbate peak demand, causing localised constraints on the network and triggering upgrade investment. This effect will be greatest on the LV network where issues are more likely due to lower diversity. Given the cost of EVs, the effect is expected to initially be localised in more affluent areas. The ever-increasing range of EVs, reducing EV prices, a developing market for second hand EVs and fossil fuel taxes may change the vehicle distribution and make it more difficult to predict where issues may arise. Technology and/or pricing mechanisms that will give EDBs a level of control over the time of day when vehicles are being charged need to be developed.

Assumption	Discussion & Implications
Service life of assets tend towards industry accepted expected life for each specific asset type and operating environment	<p>Long term projected service life of asset fleets is based on expected service life for the asset type, operating environment, expected duty cycles and maintenance practices. Actual replacement and maintenance works are short term programmed and are driven by condition, criticality and safety for the specific asset.</p> <p>Actual failure rates are utilised to determine the useful life boundaries for each specific asset type. Investment may be deferred if condition analysis provides reasonable certainty of extended asset life.</p>
No material deviation from historical failure rates	Asset reliability deterioration compared to expected failure rates would require accelerated asset replacement (to maintain service levels to customer expectations)
Resourcing is sufficient for projected works programme	<p>Considerable effort has been made to ensure work volumes are deliverable by PowerNet staff and service providers.</p> <p>The local, national and international market demand for skilled resources creates difficulty in staff attraction and retention. Globally decarbonisation projects are increasing so this demand is becoming stronger.</p> <p>These and other unanticipated labour constraints may cause works to be delayed, and/or labour costs to rise.</p>
Little change in safety & work practice regulations	Increases in health & safety requirements will have corresponding increases in cost and duration of works
Inflation for electricity industry input costs track close to expected (CPI forecasts by Treasury are utilised where sector specific forecasts are unavailable)	Positive deviation from expected material, labour and overhead input costs will result in increased costs of works programmes. The projected treatment of network constraints may change, depending on the specific changes to each input cost factor.
Future technologies that may impact work methodologies are not priced into cost estimates	Cost savings may occur if technologies develop to a stage where implementation is feasible and economic.
Significant changes in national energy policy	Changes to central government energy policy may affect customer and/or industry behaviour in a way that changes the economic feasibility of EDB investment decisions.
No significant changes to the shift towards cost-reflective pricing	<p>There is an expectation for electricity distributors to progress towards more service-based and cost-reflective pricing.</p> <p>Challenges from external parties to pricing reform may affect revenue and cause currently proposed investments to be reconsidered.</p>
No significant changes to requirements regarding resource consenting, easements, land access (private, commercial, local, and national authorities)	Increased requirements are likely to result in increased costs, conversely decreased requirements may facilitate more development and reduce costs
No material changes to domestic and small customer expectations of service levels	Changes to domestic and small customer expectations will require adjustment to service levels and subsequent investments. The customer survey shows that these customers are happy with the current price/quality balance and few customers are willing to pay more for increased service levels.
No material changes to large customer expectations of service levels	Changes to large customer expectations will require adjustment to service levels and subsequent investments. Large customers using thermal storage devices are in some instances willing to accept a lower reliability of supply to these facilities.

Assumption	Discussion & Implications
No significant changes to local and/or national government development policies	Development policies have the potential to affect aggregate and local demand. Investment levels will be adjusted to suit.
Improving industry co-operation	Deterioration in industry co-operation may result in duplicated and uncoordinated efforts and higher costs. Potential areas of improvement are standardisation (this usually leads to decreasing production cost) and coordination of bulk supply upgrades.
Cost impact of equipment size step changes are assumed to remain minor with labour cost being a large proportion of works.	Historic trend expected to continue.
Step changes in underlying growth are possible, should significant investments in the region materialise. Population growth for sizing of equipment is based on the high projection.	Lower than planned population growth may result in some equipment, mainly transformers being oversized. Likely impact on total project cost is minor as the incremental cost of using a larger standard size transformer is minimal while energy losses are reduced. Higher population growth may initiate capacity improvement works earlier.
Abnormal price movements caused by major external events (war, terrorism, union action, natural disaster) affecting pricing of equipment or labour substantially are difficult to predict and not allowed for in estimates except for the effects of known events (Covid, Ukraine, Israel, US elections).	These major external events are unable to be predicted with any certainty and EIL must react accordingly to any changes.
Establishment of Distribution System Operator (DSO) services may enable additional load factor improvements to be achieved, mainly on the Transmission network. This could lead to a decrease in bulk supply costs.	Cost savings may occur if services develop to a stage where implementation is feasible and economic. Managing the maximum load may enable capacity increase projects to be deferred.

1.4 Potential Variation Factors

The information and statements made in this AMP are prepared on assumptions, projections, and forecasts. The AMP represents EIL’s intentions and opinions at the date of issue (31 March 2026).

Climate change, natural disasters and the increasing frequency and intensity of severe weather events introduce significant uncertainty into asset planning. Extreme storms and flooding can cause widespread damage to network infrastructure, resulting in unplanned outages and emergency repairs that exceed forecasted budgets. These events also disrupt supply chains and resource availability, creating delays that extend project delivery timelines beyond initial assumptions. In addition, shifting demand patterns during prolonged heatwaves or cold spells can stress network reliability, requiring accelerated reinforcement or resilience measures.

Due to the current global uncertainties caused by events such as the wars in the Ukraine and the middle East, and potential tariff “wars”, as well as the possibility of future pandemic outbreaks similar to Covid-19, assumptions and forecasts in the AMP may vary from what actually happens. Further events may occur that were not predicted, and EIL could decide to take different actions than planned. EIL may also change any information in this document at any time. EIL accepts no liability for any action, inaction, or failure to act based on this AMP.

The further impact of the war in the Ukraine and the impact of the conflict in the Middle East is still uncertain, but developments in these conflicts may affect fuel supply and cost. The Trump administration in the USA may also affect supply chains and equipment availability, however the impact of the administration’s policies is difficult to predict.

The following table describes specific factors that have the potential to cause significant variation between the forecasts in this AMP and the actual information that will be included in future disclosures.

Table 2: Variation Causes and Implications

Cause of Variation	Implications
Cost and time estimate inaccuracies	<p>The external international environment is volatile making accurate cost predictions difficult and may lead to higher than budgeted project cost.</p> <p>Supply chains into and within New Zealand are still under pressure, Project timing may vary, resulting in lower work efficiencies. These may trigger review of project approval if variations are sufficiently large.</p> <p>Transport cost and timing is becoming more variable as shipping companies shed uneconomic routes and destinations.</p>
Variation in inflation rates and exchange rates	Higher input costs than forecast, leading to lower work volumes being executed.
High staff turnover and/or inability to recruit required resources	Labour cost increases in order to attract and/or retain competent people. Potential deferment of parts of the investment programme, or outright cancellation of certain works if resources to execute the work cannot be found. This also applies to contractors.
Reactive work varying from that estimated	Deferment of capital or planned maintenance work, if those works are dependent on the asset being in-service. Deferment of capital or planned maintenance work may also arise from staff resourcing constraints due to staff utilised on reactive work. One of the key factors that may lead to the increase is climate change, i.e. more frequent storm and high precipitation events.
Equipment failure of especially large capital plant	<p>Increased replacement costs and additional costs to maintain supply to customers until replacement. (E.g., generators may have to be deployed)</p> <p>Increased failure rates on specific classes of assets triggers a review of equipment selection and work methodologies.</p>
New safety issues identified, and initiatives created	<p>Higher labour or material costs.</p> <p>Triggers reviews of work methodologies.</p>
Reprioritisation of projects as new work activities are identified	Require revision of the longer-term investment programme and funding requirements.
Obvious short term project options may not be the best long-term solutions.	Inefficient investment and potential fruitless expenditure.
Greater demand growth than anticipated levels, especially large new industry, or customers	<p>May cause capital investments to be accelerated, or advanced.</p> <p>May constrain staffing resources.</p>
Lower demand growth than anticipated, especially loss of existing industry or customers	May cause certain capital investments to be deferred or cancelled.
Changes in central government energy policies	<p>Reducing funding levels for decarbonisation projects will reduce network growth but will also free up resources for other projects. The opposite will be true should funding levels increase.</p> <p>Increasing the acceptable voltage range will reduce the need to upgrade conductors where there are voltage constraints.</p>

2

Our Business Environment

SECTION CONTENTS

2	Our Business Environment	26
2.1	Our Purpose and Strategy	26
2.2	Our ownership, governance, and network management	27
2.3	Our Stakeholders and their Interests	28
2.4	External Business Influences	32
2.5	Commerce Commission Determination – Financial Impact	33
2.6	Planning Processes	33
2.7	Structure and Accountabilities	37
2.8	Incorporating customer requirements in our network planning	39
2.9	Quality of Service (Regulated Service Levels)	40

2 OUR BUSINESS ENVIRONMENT

EIL has numerous stakeholders and incorporates stakeholder interests in asset management practices. When managing conflicting interests, safety is the top priority.

As well as elaborating on our approach to these issues, this section details our planning processes and related documents, the organisational structure and accountabilities, as well as how our planning takes account of customer requirements, and provides for quality of service.

2.1 Our Purpose and Strategy

The purpose of the EIL is:

- Delivering a capable, safe, reliable and efficient electricity distribution network;
- A secure and stable Regulated Asset Base; and
- Delivering optimum sustainable returns to the shareholder.

The capital and resources of the company will be allocated to those assets and activities which will enable it to achieve the company purpose in a manner best serving the interests of the shareholder as a whole.

EIL acknowledges its legislative and regulatory obligations to ensure customer satisfaction with pricing and reliability and manages the return to shareholders in that context.

Asset Management Objectives

EIL's asset management objectives are based on the following guiding principles:

- Deliver value from assets by applying risk-based, safety-by-design (ALARP), and whole-of-life cost decision-making aligned with organisational objectives and risk appetite.
- Manage asset lifecycle performance to maintain network condition, capacity, quality, and security of supply, with no material deterioration and timely replacement at risk-adjusted end of life.
- Optimise lifecycle cost and performance through standardisation, condition-based maintenance, refurbishment, and economically justified life-extension or alternative solutions.
- Enable current and future demand by supporting customer-driven growth and forecast network requirements through planned, timely investment.
- Assure sustainable outcomes through regulatory compliance, environmental stewardship, resilience to natural hazards, adoption of proven technologies, and continuous improvement in efficiency and customer value.

Health, Safety and Environmental Strategy Objectives

People and equipment can be put at risk if safety is not foremost in our thinking. EIL and PowerNet each have responsibilities as persons in control of a business or undertaking under the Health and safety at Work Act 2015. EIL and PowerNet consult, co-operate and coordinate to ensure that their respective duties are satisfied. The protection of people and the environment is considered in every decision we make, and in every action we take. EIL is committed to:

- Protect people, communities, and the environment by embedding health, safety, and environmental considerations into all asset management, operational, and investment decisions.
- Fulfil PCBU and legal obligations through effective consultation, cooperation, and coordination with PowerNet, supported by robust systems, critical risk controls, and regulatory compliance.
- Maintain safe and reliable networks by ensuring assets, plant, vehicles, and equipment are fit for purpose, well maintained, and do not create unacceptable risk.
- Promote a strong safety culture and continual improvement through leadership, workforce competence, public and industry engagement, and ongoing enhancement of the HSE management system.

Interaction of Goals/Strategies

EIL’s purpose underpins both Corporate and Asset Management Strategies with linkages between these strategies shown in Table 3.

Table 3: Corporate and Asset Management Strategy Linkages

Corporate Strategies						
Delivering a reliable and efficient electricity distribution network.						
Delivering optimum sustainable returns to the shareholder.						
A secure and stable Regulated Asset Base.						
Manage operations in a progressive and commercial manner.						
Delivering a capable and efficient electricity distribution network.						
Delivering a capable and safe electricity distribution network.						
Asset Management Strategies						
Use risk as the fundamental decision-making criterion in all expenditure decisions.	✓	✓	✓	✓	✓	
Safety by design using the ALARP (as low as reasonably practicable) risk principle.	✓		✓	✓		✓
Minimise long term service delivery cost through condition monitoring and refurbishment.	✓	✓	✓			✓
Replace assets at their (risk-considered) economic end of life.	✓	✓	✓	✓		✓
No material deterioration in the condition or performance of the networks.	✓	✓	✓			✓
Facilitate network growth through timely implementation of customer driven projects.			✓		✓	✓
Maintain supply quality and security with network upgrades to support forecast growth.			✓	✓	✓	✓
Set performance targets for continuous improvement.			✓			✓
Mitigate against potential effects of natural hazards: seismic, tidal, extreme weather.	✓			✓		✓
Utilise overall cost benefit at all investment levels including the “do nothing” option.		✓	✓		✓	
Standardise and optimally resource to provide proficient and efficient service delivery.		✓	✓			
Follow new technology trends and judiciously apply to improve service levels.			✓			✓
Undertake initiatives to increase existing asset life or capacity.	✓	✓	✓			
Consider alternatives to status quo solutions.	✓	✓	✓			
Improve efficiency of electricity distribution for the net benefit of the customer.		✓				✓
Achieve regulatory compliance.	✓		✓	✓		✓
Minimise environmental harm.	✓		✓	✓		✓

2.2 Our ownership, governance, and network management

This section describes EIL’s stakeholders and partners.

The inter-relationship of these entities with the various holding companies and shareholders (along with the accounting treatment of results), is described in EIL’s annual report.

Ownership

EIL has a single shareholder – Invercargill City Holdings Limited (ICHL) acting for Invercargill City Council as a CCTO (council-controlled trading organisation). ICHL appoints the directors of EIL, with approval from the Invercargill City Council.

Governance

EIL (as of 31 March 2026) has five directors: Stephen Lewis (Chair), Simon Young, Peter Heenan, Amanda Singleton and Matthew Russell.

The main governance accountability is between EIL’s Board and shareholder with the principal mechanism being the Statement of Intent (SOI). The SOI includes SAIDI and SAIFI as network performance targets, making EIL’s Board ultimately accountable to EIL’s shareholder for these important asset management outcomes. Similarly, the inclusion of financial targets in the SOI makes EIL’s Board additionally accountable for overseeing the price-quality trade-off inherent in projecting expenditure and network performance.

Network Management

EIL uses PowerNet as its contracted asset management company through a Network Management Agreement (NMA). PowerNet is contractually accountable to EIL. The NMA specifies a range of strategic and operational outcomes to be achieved. It was revised in 2024 to reflect the sale of EIL's interests in PowerNet, and to ensure it was appropriate for arms-length governance and has a 5 year term. Under the NMA, PowerNet operates EIL's network and carries out all asset management functions such as planning, annual maintenance works, fault response, and capital works, including overseeing sub-contracting arrangements.

2.3 Our Stakeholders and their Interests

A stakeholder is identified as any person or organisation that does or may do any of the following.

- Has a financial interest in EIL (be it equity or debt).
- Pays money to EIL (either directly or through an intermediary) for delivering service levels.
- Is physically connected to EIL's network.
- Uses EIL's network for conveying electricity.
- Supplies EIL with goods or services (includes labour).
- Is affected by the existence, nature, or condition of the network (especially if in unsafe condition).
- Has a statutory obligation to perform an activity in relation to the EIL network's existence or operation (such as request disclosure data, regulate prices, investigate accidents or District Plan requirements).
- Has a foreseeable future interaction with EIL's network arising from technology change, electrification, decentralised energy resources, or evolving customer use of electricity (including but not limited to EV uptake, distributed generation, storage, and new load types).

EIL's identified stakeholders are listed in the following tables that describe stakeholder's interests, how these interests are identified, and how they are accommodated in EIL's asset management practices.

Table 4: Interests of Key Stakeholders

Stakeholder \ Interests	Viability	Price	Quality	Safety	Compliance
Invercargill City Holdings (Shareholder)	✓	✓	✓	✓	✓
Connected Customers	✓	✓	✓	✓	
Potential Customers	✓	✓	✓	✓	
Contracted Manager (PowerNet)	✓	✓	✓	✓	✓
Ministry of Business, Innovation & Employment		✓	✓	✓	✓
Commerce Commission	✓	✓	✓		✓
Electricity Authority	✓	✓	✓		✓
Utilities Disputes					✓
Councils (as regulators)				✓	✓
Transport Agency				✓	✓
Energy Safety				✓	✓
Industry Representative Groups	✓	✓	✓		
Public (as distinct from customers)				✓	✓
Mass-market Representative Groups	✓	✓	✓		
Staff and Contractors	✓			✓	✓
Energy Retailers	✓	✓	✓		
Flexibility Service Providers	✓	✓	✓		
Suppliers of Goods and Services	✓				

Stakeholder \ Interests	Viability	Price	Quality	Safety	Compliance
Land owners				✓	✓
Bankers	✓	✓		✓	✓
Transpower	✓	✓	✓		

Table 5: Identification of Stakeholders' Interests

Stakeholder	How Interests are Identified
Invercargill City Holdings (Shareholder)	<ul style="list-style-type: none"> • By their approval or required amendment of the SOI • Regular meetings between the ICHL and EIL boards • Regular meetings between the directors and executive
Connected Customers	<ul style="list-style-type: none"> • Regular discussions with large industrial customers and generators as part of their on-going development needs • Customer contracts • Customer consultation evenings (meetings open to public) • Annual customer surveys • Contact by customers, • Consultants
Potential Customer	<ul style="list-style-type: none"> • Connection requests • Feasibility study requests • Contact by customers' consultants
Contracted Manager (PowerNet)	<ul style="list-style-type: none"> • Board Chairman weekly meeting with the Chief Executive • Board meets at least 6 times per year with Chief Executive, Chief Financial Officer and General Manager Asset Management • PNL Staff attend Board meetings when required
Ministry of Business, Innovation & Employment	<ul style="list-style-type: none"> • Legislation, regulations, and discussion papers • Analysis of submissions on discussion papers • Conferences following submission process • General information on their website
Commerce Commission	<ul style="list-style-type: none"> • Regular bulletins on various matters • Release of regulations and discussion papers • Analysis of submissions on discussion papers • Conferences following submission process • General information on their website • Default Price Path and information disclosure feedback
Electricity Authority	<ul style="list-style-type: none"> • Weekly updates and briefing sessions • Regulations and discussion papers • Analysis of submissions on discussion papers • Conferences following submission process • General information on their website
Utilities Disputes	<ul style="list-style-type: none"> • Reviewing their decisions about other lines companies
Councils (as regulators)	<ul style="list-style-type: none"> • Formally as necessary to discuss issues such as assets on Council land • Formally as District Plans are reviewed • Formally to discuss development needs

Stakeholder	How Interests are Identified
Transport Agency	<ul style="list-style-type: none"> Formally as required
Energy Safety	<ul style="list-style-type: none"> Promulgated regulations and codes of practice Audits of EIL's activities Audit reports from other lines businesses
Industry Representative Groups	<ul style="list-style-type: none"> Informal contact with group representatives
Public (as distinct from customers)	<ul style="list-style-type: none"> Word of mouth around the city Feedback from public meetings Newspapers and social media
Mass-market Representative Groups	<ul style="list-style-type: none"> Informal contact with group representatives
Staff & Contractors	<ul style="list-style-type: none"> Regular staff briefings Regular contractor meetings
Energy Retailers	<ul style="list-style-type: none"> Annual consultation with retailers
Suppliers of Goods & Services	<ul style="list-style-type: none"> Regular supply and demand meetings Contractual arrangements Newsletters
Land Owners	<ul style="list-style-type: none"> Individual discussions as required
Bankers	<ul style="list-style-type: none"> Regular meetings between bankers, PowerNet's CE & CFO EIL's treasury/borrowing policy Banking covenants
Transpower	<ul style="list-style-type: none"> Regular meetings at various organisational levels Transpower Customer Services representatives

Table 6: Accommodating Stakeholders' Interests

Interest	Description	How EIL Accommodates Interests
Viability	Viability is necessary to ensure that the shareholder and other providers of finance have sufficient confidence to keep investing in EIL.	<ul style="list-style-type: none"> Stakeholders' needs for long-term viability are accommodated by delivering earnings that are sustainable and reflect an appropriate risk-adjusted return on employed capital. In general terms this will need to be at least as good as the stakeholders could obtain from a term deposit at the bank plus a margin to reflect the ever-increasing risks to the capital in the business. Earnings are set by estimating the level of expenditure that will deliver the returns. Service levels are maximised within those constraints while keeping our network prices at affordable levels.

Interest	Description	How EIL Accommodates Interests
Price	Price influences revenue and signals underlying costs. Getting prices wrong could result in levels of revenue that could not sustain supply reliability to the levels demanded by customers.	<ul style="list-style-type: none"> EIL's total revenue is determined by the regulated price path threshold. Prices will be managed to within the limits prescribed unless doing so would compromise safety or viability. Failure to gather sufficient revenue to fund reliable assets will interfere with customers' business activities, and conversely gathering too much revenue will result in an unjustified transfer of wealth from customers to shareholders and affect business customers' viability. Insufficient revenue will compromise the long-term sustainability and ability to render services. EIL's pricing methodology is intended to be cost-reflective, but constraints such as the Low Fixed Charge (LFC) regulations can distort this. This Government is currently phasing out the LFC regulations.
Supply Quality	Emphasis on continuity, restoration of supply and voltage wave form management (amplitude, flicker, harmonics) is essential to minimising interruptions to customers' businesses and eliminating the risk of damage to customer equipment.	<ul style="list-style-type: none"> Stakeholders' needs for supply and service quality are accommodated by having a pool of resources focussed on continuity and restoration of supply. Growth-related network upgrades are implemented in time to prevent adverse supply quality. The most recent mass-market survey indicated satisfaction with the present supply quality but also that many customers would be willing to accept a reduction in supply quality in return for lower line charges.
Safety	Staff, contractors, and the public at large must be able to move around in the vicinity of network assets and work on the network in total safety.	<ul style="list-style-type: none"> The public at large are kept safe by ensuring that all above-ground assets are structurally sound, live conductors are well out of reach, protection systems are working, all enclosures are kept locked and all exposed metal within touching distance of the ground is earthed. Safety in design forms part of the asset renewal and replacement programme. The safety of staff and contractors is ensured by providing all necessary equipment, improving safe work practices, and ensuring that they are stood down in unsafe conditions. New assets are subjected to the Safety in Design process. Motorists will be kept safe by ensuring that above-ground structures are kept as far as possible from the carriage way within the constraints faced regarding private land and road reserve.
Compliance	Compliance with the many statutory requirements, ranging from safety to disclosing information is compulsory.	<ul style="list-style-type: none"> All safety issues are documented and available for inspection by authorised agencies. Use the "Comply With" system to keep up to date with changes in legal requirements. Performance information is disclosed in a timely and compliant fashion. Any non-compliances are documented, submitted to and approved by the relevant authority following the approved processes.

EIL's commercial goal is to deliver optimum sustainable returns to Invercargill City Holdings. This is a primary commercial driver for EIL, together with the network performance. The SOI and the NMA formalise these accountabilities to the shareholder.

Connected customers (via electricity retailers) provide EIL's revenue in return for the services provided by the EIL network assets. Due to the importance EIL places on meeting customer's expectations, annual customer surveys are undertaken to monitor customer satisfaction, with service level targets set to ensure standards are maintained or improved. See Section 6 (Service Levels) for details of these surveys, customer feedback and performance targets.

EIL is required to compile and publicly disclose performance and planning information (including the requirement to publish an AMP). In addition, EIL is subject to price and quality regulations and there should not be any substantial decline in network reliability measures. These requirements are listed under Part 4 of the Commerce Act 1986 and in the Commerce Commission's disclosure requirements.

Regulatory restrictions on generating and retailing energy are established under the Electricity Industry Act 2010 and requirements for the connection of distributed generation established under the Electricity Industry Participation Code.

Managing Conflicting Interests

When conflicting stakeholder interests are identified, EIL applies a materiality-based approach to determine the level of consideration required. Not all stakeholder interests have equal impact on EIL's statutory obligations, risk profile, or long-term performance. The significance of each issue is assessed based on its potential impact on safety, network performance, financial viability, regulatory compliance, and customer outcomes. The following prioritisation hierarchy is used to analyse conflicting issues and to establish available options.

- 1. Safety.** Managing safety consistent with the risk appetite of EIL and PowerNet and compliant with safety regulations is always the first priority. The safety of staff, contractors and the public are of paramount importance. These factors are highly ranked in asset management decisions.
- 2. Viability.** EIL's long term financial and technical viability is the second consideration, as EIL is expected to deliver the electricity distribution function to its customers for the foreseeable future.
- 3. Pricing.** EIL gives third priority to pricing (noting that pricing is only one aspect of viability). EIL recognises the need to adequately fund its business to ensure that customers' businesses can operate successfully, whilst ensuring that there is not an unjustified transfer of wealth from its customers to its shareholders. As a regulated entity pricing is set so that forecast revenue is not more than the maximum allowable revenue established by the Commerce Commission, with pricing levels that follow the principles established by the Electricity Authority as discussed in 2.5 below.
- 4. Supply Quality.** Supply quality is the fourth priority. Reliable and high-quality electricity supply enables customers to operate their homes and businesses effectively, which in turn supports EIL's long-term success and compliance with Commerce Commission regulation.
- 5. Compliance.** Compliance that is not safety and supply-quality related is important but ranks lower than the criteria above.

Once an appropriate resolution has been determined, a recommendation is presented to management. A decision may be taken by the management team or matters be escalated to the EIL Board if required.

2.4 External Business Influences

There are several other issues (listed below) that are not directly related to stakeholders but have a significant impact on EIL's asset management practices. Controls are in place to effectively manage these concerns.

- Competitive pressures from other lines companies that might try to supply EIL customers.
- Pressure from substitute energy sources at end-user level (such as substituting electricity with gas or biomass at a facility level) or by offsetting load with distributed generation.
- Advancing technologies such as solar generation coupled with battery storage, which could potentially strand conventional distribution assets.
- Local, national, and global economic cycles which affect growth and development.
- Changes to the Southland climate that include more storms and hotter, drier summers.
- Interest rates which can influence the rate at which new customers connect to the network.
- Ensuring sufficient funds and skilled people are available long term to resource EIL's service requirements.
- Technical regulations including such matters as limiting harmonics to specified levels.
- Safety requirements such as earthing of exposed metal and line clearances.
- Asset configuration, condition, and deterioration. These parameters will significantly limit the rate at which EIL can re-align their large and complex asset base to fit ever-changing strategic goals.
- Physical risk exposures: exposure to events such as flooding, wind, snow, earthquakes, and vehicle impacts.
- Regulatory change: for example, if the transport agency required all poles to be moved back from the carriage way.

2.5 Commerce Commission Determination – Financial Impact

EIL is subject to price-quality regulation under Part 4 of the Commerce Act 1986. The Commerce Commission is responsible for determining Default Price-quality Paths (DPPs), which set a cap on regulated revenue and establish targets for quality of supply.

The Commerce Commission publishes a DPP determination every 5 years, which sets out how each non-exempt EDB must calculate its annual cap on regulated revenues. The 2025/26 year was the first year of the DPP4 5-year period.

The DPP determination sets out the Commerce Commission’s expenditure forecasts for each Price and Quality regulated (non-exempt) EDB. The Commerce Commission uses these forecasts to set the revenue cap, but they are also used as targets in an incentive scheme (IRIS) where EDBs are rewarded for keeping expenditure below the Commission’s forecasts and penalised for exceeding them.

The Commerce Commission’s expenditure forecasts for DPP4 provide for increases in both OPEX and CAPEX when compared with DPP3, which flow through to increases in allowable revenue. These increases reflect a range of factors including that:

- inflation had risen since the DPP3 Determination was made,
- demand growth for electricity is accelerating,
- the need for EDBs to make significant investments in capacity upgrades and resilience of their networks,
- some EDBs expect to invest more in replacements and renewal of assets due to the age of their network, and
- step-changes in certain categories of OPEX.

The Commerce Commission permits reopeners for significant unforeseen or uncertain capital expenditure projects to allow EDBs to undertake investments in response to changing conditions without risking capital under-recovery, or alternatively it can seek at Customised Price-Quality Path (CPP). However, the expense of a CPP would likely be prohibitive for a small network such as EIL.

The Commerce Commission’s forecasts for DPP4 for EIL are as follows:

\$ million	2025/26	2026/27	2027/28	2028/29	2029/30
Forecast OPEX	6.808	7.064	7.306	7.562	7.829
Forecast CAPEX	6.901	9.274	9.939	8.197	9.826

2.6 Planning Processes

EIL’s planning processes and associated documents are described in the next sections.

Business Planning

The business planning, execution and performance measurement processes are presented in the next figures.

Figure 3: Business Planning and Execution Processes




Business planning takes place within the overall framework of Quality, Occupational Health and Safety and Asset Management, and is carried out by PowerNet on behalf of EIL in accordance with the Network Management Agreement (NMA). The external environment is scanned to identify threats and opportunities and to gather relevant business intelligence, including regulatory, customer, and stakeholder expectations. This information is considered alongside an assessment of the strengths and weaknesses of internal processes and capabilities.

Business performance objectives are established to meet the requirements of EIL’s shareholder and other stakeholders, and are formalised through the NMA as agreed strategic and operational outcomes, performance measures, and service levels. These NMA outcomes provide the basis for translating stakeholder expectations into measurable targets for EIL.

The following diagram illustrates this process in more detail and shows the alignment of performance objectives from company level through to team and individual performance objectives. Individual performance against these objectives is evaluated as part of PowerNet’s performance management and incentive framework, ensuring alignment between individual effort and the delivery of EIL’s agreed business and Network Management Agreement outcomes.

Figure 4: Business Support and Improvement Processes



In addition to the AMP, EIL has the following documents, which are approved by EIL as part of the company’s planning processes.

Statement of Intent

EIL’s SOI is a requirement under the constitution of the company and forms the principal accountability mechanism between EIL’s Board and the shareholder, Invercargill City Holdings. The SOI includes financial performance projections for the following metrics.

- EBIT% (Percentage Group Earnings Before Tax and Interest on Assets Employed).
- NPAT% (Percentage Group Tax Paid Profit on Equity).
- Percentage of Consolidated Equity to Total Assets.
- The quality performance projections for SAIFI and SAIDI are also included. These projections are over a three-year period and form the heart of asset management activities. The inherent trade-off between price and supply quality are acknowledged. The SOI is available at www.eil.co.nz/statement-of-intent

Annual Business Plan

Each year, the first three years of the AMP is consolidated with any recent strategic, commercial, asset or operational issues into EIL’s Annual Business Plan (ABP). The AWP for the three years ahead is an important component of the ABP.

The ABP defines the priorities and actions for the year ahead which will contribute to EIL’s long-term alignment with

their purpose, objectives, and strategies, while fully understanding that this alignment process must at times cater for “moving goal posts”.

The ABP contains the following.

- Core Business, Purpose Statement and Critical Success Factors.
- Commercial Objectives, the Nature and Scope of Commercial Activity and Company Policies.
- Annual Works Programme (first three years).
- Business Plan Financials and Business Unit Reports.

Progress updates are reported monthly to assist in monitoring of performance and delivery to plan.

Annual Works Programme

The Annual Works Programme (AWP) is produced as part of the AMP development process and is included in the AMP’s development and lifecycle planning sections. It covers the same ten-year planning horizon and lists the works to be undertaken for each financial year.

The AWP details the scope for each activity or project identified, sets the associated budget for the first year and forecasts expenditure for future years. Critical activities are to firstly ensure that this annual works program accurately reflects the projects in the AMP and secondly to ensure that each project is implemented according to the scope prescribed in the works program. Ensuring the AWP is achievable requires careful consideration of the available workforce and management capabilities which is discussed in Section 9.

Interaction between Objectives, Drivers, Strategies and Key Documents

The interaction between EIL’s corporate purpose, asset management objectives, business drivers, strategies and key planning documents is presented in the next figure.


The purpose leads to the objectives for EIL’s asset management processes. These asset management processes are documented in the AMP which serves as a guidance and communication mechanism between EIL and its asset management company PowerNet.

The asset management strategies are designed to achieve the asset management objectives aligned with EIL’s purpose and corporate strategies. Stakeholder interests and expectations as well as other external influences inform the strategy development and asset management objectives and the corporate purpose. The asset management strategies are applied to the existing network assets. The strategies include the setting of performance targets which leads the AWP development.

The AMP (and especially the AWP incorporated into the AMP) sets and drives asset management works and expenditure to extract maximal value from network assets and is prepared in a format that assists communication of the key deliverables. Delivery of the AWP projects over time creates a network closely aligned with the asset management strategies, objectives and EIL’s corporate purpose whilst meeting stakeholder expectations, especially those of the shareholder and network customers.

Capital expenditure budgets and performance targets from the AMP and the AWP are incorporated into the ABP; these together with any wider business issues provide the overall business planning summary used by the wider PowerNet management team and, through the NMA relationship, the EIL Board. The SOI incorporates performance targets (including key asset management targets) from the AWP, forming the accountability mechanism between the EIL Board and the shareholder.

Figure 5: Interaction between Objectives, Drivers, Strategies and Key Documents



This happens within the framework of our asset management policy, asset management strategy and asset management objectives. The following diagram shows the framework we use to manage our assets.

Figure 6: Asset Management Framework



Asset Management Planning

Asset life cycle management processes are demonstrated in the next figure. The asset life cycle phases are the following:

- plan;
- design;
- acquire (including construction);
- commission;
- operate and maintain; and
- dispose.

These phases are underpinned by the foundations of asset information management, financial resource management, risk management and human resource management. These are discussed in further detail in Chapter 6.

Figure 7: Asset Management Processes




2.7 Structure and Accountabilities

EIL’s ownership, governance and management structure is depicted in the diagram below. Under the Network Management Agreement (NMA), PowerNet is responsible for the operational management of EIL’s electricity network and associated asset management activities, while EIL retains governance oversight and decision-making authority in accordance with its shareholder and statutory obligations.

Financial authority limits are defined in the PowerNet Financial Authorities Policy and apply to activities undertaken by PowerNet on behalf of EIL under the NMA. These authorities include general financial approval limits, as well as increased approval levels for project work that has been previously approved through EIL’s planning and approval processes.

The majority of projects included in the Annual Works Programme (AWP) are approved by the EIL Board as part of the Annual Business Plan (ABP) approval process in the preceding year. Once approved, PowerNet is authorised under the NMA to execute the approved programme within the agreed scope, budget, and delegated financial authorities, and to report performance and expenditure to EIL in accordance with the NMA reporting requirements. Each level of management has defined financial authority limits set out in PowerNet’s Financial Authorities Policy. It includes general financial authority levels and increased levels specifically for project work previously approved in the AWP. Most projects in the AWP are approved by the EIL as part of ABP process in the previous year.

Figure 8: Governance and Management Accountabilities



EIL Board

EIL Project works delivery

Definition of a Project

For the purposes of the Annual Works Programme (AWP), a project is defined as a discrete delivery activity, typically relating to a single site or a defined group of sites, with an approved scope, schedule and budget for execution.

Asset fleet renewals or programme-based works (for example pole replacements, transformer renewals, or protection upgrades) are generally approved at a programme level through the Asset Management Plan (AMP). Individual delivery projects within an AMP-approved programme are treated as execution activities, not separate projects for approval threshold purposes, provided they remain within the approved AMP scope, delivery strategy and budget envelope.

Any new project over \$100,000 added or variation by more than +10% or -30% (for projects over \$100,000) to the approved AWP needs approval from EIL. Large projects with capital budgets exceeding \$1,000,000 are required to be supported by a business case explaining the project scope and justification. The business case will generally include a detailed cost-benefit analysis of the recommended scope over alternative options. Projects between \$500,000 and \$1,000,000 require a short-form business case to be submitted to EIL for approval.

The EIL General Manager receives monthly reports that cover the following items.

- Health and Safety – Incident summaries and progress measures.
- Network Reliability – this lists all outages over the last month, and trends regarding the SOI reliability targets.
- Network Quality – detail of outstanding supply quality complaints and annual statistics thereof.
- Network Connections – monthly and yearly details of connections to the network.
- Use of Network – trend of the energy conveyed through the network.
- Revenue – detail on the line charges received.
- Retailer activity – detail on volumes and numbers per energy retailer operating on the network.
- Works Programme – Summary expenditure actuals and forecasts by works programme category with notes on major variations.

- Works Programme – Physical progress on specific works programme categories as identified by the Board.
- Internal and external audit findings.

Accountability at Executive Level

Overall accountability sits with EIL but is delivered by PowerNet through the NMA.

Accountability at Operational Level

PowerNet - Delivery of the Annual Works Programme (AWP)

PowerNet is responsible for the planning and delivery of the Annual Works Programme (AWP) on behalf of EIL. Within PowerNet, the Major Projects Team (reporting to the General Manager - Networks), the Operations (Technical) Team, and the Operations (Distribution) Team each manage their respective major, technical, and distribution projects that collectively comprise the AWP.

PowerNet's objectives are to deliver AWP projects:

- On time
- To approved scope and quality standards
- Within approved project budgets
- In accordance with the overall AWP works categories and total CAPEX and OPEX allowances

Major Projects are typically delivered through tender processes, engaging external consultants and contractors. Technical and distribution projects are primarily delivered using PowerNet's in house field services, supported by internal technical and operational resources.

PowerNet is responsible for day to day operational decision making, project management, contractor management, health and safety performance, and delivery assurance, in accordance with EIL's approved plans, budgets, and performance expectations.

PowerNet reports to EIL through established operational and performance reporting frameworks.

EIL - Governance, Oversight and Strategic Direction

EIL retains ownership, governance and strategic accountability for the electricity distribution network and the associated investment programme. EIL has appointed a General Manager, and PowerNet now reports to the EIL General Manager on operational matters relating to the delivery of services.

EIL's role includes:

- Setting strategic objectives, asset management outcomes, and performance expectations
- Approving the Annual Works Programme, budgets, and material changes to scope or timing
- Providing oversight and assurance of PowerNet's delivery performance
- Ensuring alignment with regulatory requirements, risk appetite, and customer outcomes
- Escalating material issues to the EIL Board where required

While EIL does not directly deliver projects, it maintains accountability for ensuring that network investment and operational activities are consistent with long term network stewardship, financial sustainability, safety obligations, and customer interests.

Accountability at Work-face Level

PowerNet's internal field staff are managed within PowerNet's Operations Team to deliver work divided into technical and distribution projects. External contractors are used for vegetation management (Asplundh) and communications network maintenance and projects (Ventia). Civil works including cable trenching and earthworks for zone substations are typically completed by external contractors. External contractors are typically used to deliver major projects and occasionally when necessary to supplement workforce capacity or skillsets.

2.8 Incorporating customer requirements in our network planning

Load densities and rates of growth differ across the EIL network, which influences our asset management planning. Historically, growth rates on the network were relatively low, however, with decarbonisation and potential new commercial and industrial developments close to the city we expect this to change over the next two to five years.

Connection timeframes for new large customers are generally unpredictable as the large customers often approach EIL for new connections as late as possible to try and keep their competitive advantage. Planning in these instances tends to be more reactive than proactive to avoid over investment. However, this does impact the effectiveness with which developments can be planned holistically.

The known and firm development currently is the housing development off Racecourse Road entailing a potential 600 new houses and some commercial and educational facilities.

There are not any individual customers considered large enough to have any significant impact on our network operations or asset management planning other than ensuring that adequate supply capacity is maintained.

Currently EIL's largest customer is Southport Limited, a large port in the Bluff distribution area which regularly peaks at about 1.6 MW and consumes approximately 6.5 GWh per year. Decarbonisation initiatives involving the change from coal boilers to electricity powered heating systems may change this. The Bluff distribution area also includes port associated heavy industries as well as residential and commercial customers.

The Invercargill distribution area is predominantly residential but does include a medium-sized CBD, a heavy industrial area immediately west of the CBD and a light industrial area in the southeast. The criticality of supply for the CBD is recognised with additional protection and automatic sectionalisation provided in this area.

2.9 Quality of Service (Regulated Service Levels)

Quality of service incentives continue to be a major focus area for the Commerce Commission. Under DPP4, the intent remains to align reliability incentives with the value customers place on supply reliability, giving EDBs flexibility (within defined limits) to target a balance between reliability and price that best meets customer expectations. Normalisation continues to ensure that the impact of severe weather or other major events is not mistaken for a decline in underlying network performance.

The key principles embodied within the Commission's quality standards for DPP4 are as follows:

- Maintaining separate reliability standards for planned and unplanned interruptions.
- Setting unplanned reliability limits at two standard deviations above the normalised historical average, using a ten-year reference period (2015–2024), with compliance assessed annually, and ± 5 % caps on inter-period movement.
- Setting planned reliability limits at double (100 % uplift) the historical average, using a seven-year reference period (2018–2024), with compliance assessed over the five-year regulatory period and ± 10 % caps on movement between periods.
- Continuing the normalisation methodology from DPP3, whereby major event days are statistically identified and replaced with boundary values to ensure consistent and comparable performance assessment.

3

The Network and Asset Base

SECTION CONTENTS

3	The Network and Asset Base	42
3.1	Bulk Supply Points and Embedded Generation.....	42
3.2	Sub-transmission Network.....	42
3.3	Zone Substations.....	45
3.4	Distribution Network.....	48
3.5	LV Network	54
3.6	Customer Connections	57
3.7	Assets for Control and Auxiliary Functions	57
3.8	Summary of EIL asset base.....	59
3.9	Load Characteristics	61

3 THE NETWORK AND ASSET BASE

EIL owns and operates two separate electrical networks that are both supplied by the Grid Exit Point (GXP) at Invercargill. The Bluff network comprises two 11kV feeders supplied by TPCL zone substation situated just west of Bluff Township. EIL also owns interconnectors to TPCL's Otatara and Seaward Bush 33kV lines that provide alternative supplies to the Leven Street and Southern zone substations respectively.

This section describes the network configuration, load characteristics, and energy and demand characteristics as of 31 March 2025.

3.1 Bulk Supply Points and Embedded Generation

Invercargill GXP comprises a very reliable point in the 220kV grid which is tied to Roxburgh and Manapouri power stations and to the North Makarewa GXP. Invercargill GXP is also a major supply node for the Tiwai Point Aluminium Smelter.

The 33kV supply arrangement at Invercargill comprises an indoor switchboard that is energised by two three-phase 120MVA 220/33kV transformers. There are eleven 33kV feeders, each supplied through its own circuit breaker. EIL takes supply from seven of these feeders in normal operation, including the two parallel TPCL feeders which supply Bluff. Back-up supplies are available from other TPCL feeders and are used from time to time.

EIL owns the segments of 33kV line (but not the circuit breakers or bus) that run within the GXP land area and accommodates a backup control room for PowerNet's System Control. EIL also owns one of the two 33kV 216 $\frac{2}{3}$ Hz ripple injection plants on the west side of the GXP site. The second plant is owned by TPCL with each providing backup capability to the other.

Table 7: Bulk Supply Characteristics

Supply	Voltage	Rating	Firm Rating	Maximum Demand 2023/24
Invercargill GXP	220/33kV	240MVA	109MVA	107.941MW (09:00 10/08/2023)
EIL	(GXP assets shared with TPCL)			66.016MW (09:00 10/08/2023)

There is no significant generation embedded within EIL's network, but the wind farm at Flat Hill near Bluff (6.8MW installed capacity) is connected at TPCL's Bluff substation, from which the Bluff area network takes its supply. A small number of distributed generation connections exist but are only a few kW each in size. These generators with generation profiles (tied to sunlight conditions) have negligible effect on GXP loading.


3.2 Sub-transmission Network

EIL's subtransmission network is a 33kV network that is supplied from a single GXP at Invercargill and can take emergency supply from the North Makarewa GXP through TPCL's 33kV network as depicted in the next figure. (EIL's two Bluff 11kV feeders are supplied from TPCL's 33kV subtransmission network). The network comprises 1.4 km of 33kV overhead line and 26.8km of 33kV underground cable and has the following characteristics:

- two points of interconnection with TPCL's 33kV network which provides alternative supplies to Leven Street and Southern zone substations;
- it is almost completely underground except for short lengths of overhead line between Invercargill GXP and Racecourse Road zone substation (about 300 m long) and in the middle of the tie between Leven Street zone substation and TPCL's Otatara 33kV feeder, and
- it is predominately a ring topology except for Racecourse Road which is a spur.

EIL owns and operates two separate electrical networks - Invercargill and Bluff - that are both supplied by the transmission Grid Exit Point (GXP) at Invercargill.

Figure 9: Subtransmission Network



Basic details for EIL's subtransmission circuits are provided in the following table. All circuits are 33kV and operate within their respective ratings. Stated remaining lives are based on expected standard lives; but in practice EIL subtransmission cables (being lightly loaded) are expected to last significantly longer than expected standard life and will be replaced based on their condition.

Table 8: Subtransmission Circuit Details

Location	Type	Length	Manufactured	Remaining Life	Condition
Invercargill GXP to Southern	Oil Cable	4.7 km	1968	14 yrs.	Good, only lightly loaded, some concerns of joints and terminations.
Invercargill GXP to Doon Street ex T1	Oil Cable	3.5 km	1970	16 yrs.	Good, moderately loaded.
Invercargill GXP to Doon Street ex T2	Oil Cable	3.5 km	1975	21 yrs.	Good, only lightly loaded, some concerns of joints and terminations.
Doon St to Spey St	XLPE Cable	0.6 km	2016	47 yrs.	As new, lightly loaded.
Invercargill GXP to Spey Street	XLPE Cable	4.1 km	2015	46 yrs.	As new, lightly loaded.
Invercargill GXP to Racecourse Road	O/H Line	0.3 km	1975	11 yrs.	Good, short cross country, concrete poles.
Invercargill GXP to Leven Street	XLPE Cable	5.3 km	1983	14 yrs.	Good, lightly loaded.
Seaward Bush Line to Southern	XLPE Cable	1.4 km	1999	30 yrs.	Good, not normally loaded.
Otatara Line to Leven Street	XLPE Cable O/H Line	3.7 km 1.1 km	2000	31 yrs. 21 yrs.	Good, not normally loaded.

Subtransmission Cables


EIL has three oil filled cables taking supply from the Invercargill GXP substation, the oldest of which has approximately 16 years life remaining and is expected to be in sound condition. One of the oil cables supplies Southern substation and operates up to about half of its rating. The other two cables previously supplied Doon Street and were similarly operated up to about half of their capacity. However, these cables have now been paralleled and extended with XLPE cable to supply Spey Street which has reduced typical loading to low levels.

There have been some concerns with the rating of the cables due to poor thermal resistivity backfill used. Temperature and thermal resistivity transducers were installed on the cables in 2015 to better understand their in-service capacity. The data to date indicates no concerns although the opportunity has not yet arisen to gather data during worst-case conditions, such as over an extended dry spell. Some maintenance work is being completed on the oil tanks and associated piping.

There is also some concern over the integrity of the cable joints which have been found to be trending toward premature failure by other distribution companies. Some cable joints are to be exposed and terminations replaced to ensure the cable can be reliably operated for the remaining life of the cables. The risk of failure has been mitigated through the installation of a new XLPE cable in parallel to the oil-filled cables formerly supplying Doon St; all oil-filled cables on the network now have an alternate supply option through an XLPE cable.

The other cables are XLPE cables, lightly loaded and in good condition. Some of these are unloaded cables used occasionally for backup. Earlier XLPE cables (pre-1985) have a shorter life expectancy, however for lightly loaded cables it is more appropriate to replace on condition than on age, particularly where a parallel supply option exists. The following chart shows the commissioning year and installed length for EIL's sub-transmission cables (as of the end of March 2025).

Figure 10: Sub-transmission Cables (33kV Cables)



3.3 Zone Substations

EIL owns and operates four zone substations in Invercargill which have either AA or AAA security levels (see Development Criteria for security level definitions). However, the network area in Bluff also takes an 11kV supply from a TPCL-owned substation. Descriptions for EIL’s zone substations are provided below.


Table 9: Zone Substations

Substation	Nature of load	Description
Spey Street	CBD, Urban Residential	<p>Spey Street is a modern urban substation with dual transformers providing a capacity of 72MVA and a firm rating of 36MVA. This substation was constructed as a relocation and replacement for the Doon Street substation which had many assets at end of life and was at risk of third-party damage from a potential earthquake. It is a fully indoor site built to blend inconspicuously into its semi-commercial environment.</p> <p>The substation is supplied via a new 33kV XLPE cable and a second cable feeder consisting of the oil filled cables (that previously supplied Doon Street) paralleled and extended with a 33kV XLPE cable to Spey Street.</p> <p>The 11kV switchboard has 12 feeders and is split by two bus coupler circuit breakers, with each half located in separate fire rated rooms for added security.</p>
Leven Street	CBD, Heavy Industrial, Urban Residential	<p>Leven Street is an urban substation with dual transformers providing a capacity of 46MVA and a firm rating of 23MVA. It is supplied by a single 33kV XLPE cable from Invercargill GXP but has an alternative 33kV supply from TPCL’s Otatarā 33kV feeder (which can be supplied from an alternative GXP). This alternative supply achieves the necessary AAA security for the substation however due to its supply being from another GXP the 33kV back-feed cannot be ‘normally in service’ and therefore a short interruption (i.e., break before make) has to be accepted.</p> <p>The 11kV switchboard has 9 feeders and is split by a bus coupler circuit breaker.</p>
Southern	Urban Residential, Light Industrial	<p>Southern is an urban substation with a dual transformer providing a capacity of 46MVA with a firm 23MVA capacity. It is supplied by a single 33kV oil filled cable from Invercargill GXP. An alternative 33kV supply is available from TPCL’s Seaward Bush 33kV feeder as backup if required.</p> <p>The 11kV switchboard has 5 feeders, one of those feeders is split from the other by a bus coupler circuit breaker.</p>
Racecourse Road	Urban Residential, Rural Residential	<p>Racecourse Road is an urban substation with a single transformer providing 23MVA capacity. It is supplied by a short 33kV overhead line from Invercargill GXP. The substation supplies predominantly residential areas but also has two metered feeders which supply a small semi-rural area of TPCL’s network.</p> <p>The 11kV switchboard has 9 feeders and is split by a bus coupler circuit breaker.</p>
Bluff	Port, Heavy Industrial, CBD, Urban Residential	<p>EIL’s Bluff area is supplied from two metered 11kV feeders from TPCL’s Bluff substation to the Northwest of the town. Two other feeders are used as a supply to rural customers North of Bluff and as a connection point for Southern Generation’s Flat Hill Windfarm. The Bluff substation has two transformers providing a capacity of 26MVA and a firm rating of 13MVA. Bluff substation is supplied from two 33kV overhead lines from Invercargill GXP via TPCL’s Colyer Road substation. The size of the total load on the Bluff substation is technically only large enough to justify AA security, but due to the lack of 11kV backup capacity, it is more economic to provide AAA security at the site.</p>

Substation Buildings

EIL has buildings at each of its zone substations. The larger buildings are either concrete blocks or wooden-framed construction with some smaller buildings being made offsite using insulated metal panel construction. The age profile of the 5 buildings is shown below.

Figure 11: Substation Buildings




Subtransmission Voltage Switchgear

The 33kV switchboard at Leven Street Substation is indoor, relatively modern and in good condition. At EIL’s Southern substation an indoor 33kV switchboard was installed in 2019. The switchboard consists of 5 circuit breakers. The switchboard is split into two sections via a bus coupler. Two relatively young circuit breakers are located at Doon Street, but have now been removed from service, and options for their reuse are being considered.

Outdoor equipment at Southern Substation has been damaged by vandalism in the past. Protective barriers have been installed around critical equipment, but without fully enclosing equipment there remains an acceptable risk of insulators being damaged by thrown stones.

Figure 12: Subtransmission Voltage Circuit Breakers (33kV)



Power Transformers

The power transformers at EIL’s Leven St, Southern, and Racecourse Rd zone substations are all rated to supply load up to 23MVA with forced cooling, based on an ambient temperature of 5°C (as peak load in EIL generally occurs at the coldest times when heating requirements are greatest).

The power transformers at EIL’s remaining substation, Spey St, are relatively new and are rated up to 36MVA with forced cooling. The Spey St substation replaces the Doon St substation. The ex-Doon St 23MVA transformer has been installed at Southern substation as T1 which upgrades the substation to a dual transformer site. The existing Southern transformer 23MVA is labelled T2. Both transformers have reasonable life, and Furan analysis suggests the insulation is in sufficiently good condition to provide an extended life. Due to the good condition of the older units, there are no power transformer replacements expected within the next 10 years.

The transformer at Racecourse Road was refurbished in 2017 (major rust), with condition assessment of the insulation showing that it too can provide an extended life.

Table 10: Power Transformers


Transformer Location	Rating	Installed	Remaining Life
Spey Street T1	18/36 MVA	2015	55
Spey Street T2	18/36 MVA	2012	52
Leven Street T1	11.5/23 MVA	1983	23
Leven Street T2	11.5/23 MVA	2002	42
Southern T1 (Ex Doon St)	11.5/23 MVA	1970	10
Southern T2	11.5/23 MVA	1967	07*
Racecourse Road T1	11.5/23 MVA	1975	15

* Note remaining life expected to be greater than 10 years.

Distribution Voltage Switchgear

The 11kV circuit breakers installed at EIL’s zone substations and in the field with their year of manufacture are shown in the following graph (as of the end of March 2025).

Figure 13: Zone Circuit Breakers




- The Spey Street substation has modern switchgear and has no known issues with its switchboard.
- The Southern substation switchboard was replaced as part of a recently completed (2021) upgrade project at this substation. The new switchboard has also enabled dual transformer supply.
- The Racecourse Road substation switchboard was installed in 1975 and a replacement project is currently underway with the design stage undertaken in 2022-24 and replacement occurring in 2026/27 and 2027/28.
- The 11kV switchboard at Leven Street was installed in 1983 with an additional incomer installed in 2000 when the second transformer was installed. There are no issues noted with any of the switchboards’ circuit breakers.

DC Power Supplies

All four EIL zone substations are equipped with 24 V DC battery systems that provide dependable auxiliary supply to protection, control, and communication equipment. These battery systems have an expected service life of approximately 15–20 years. As DC batteries are critical to the safe and continuous operation of protection devices, PowerNet undertakes routine inspections and condition monitoring to ensure reliability. Battery replacement is carried out based on condition, performance indicators, and operational risk. The chart below provides an overview of the installed DC batteries and their respective ages across the EIL zone substations.

Figure 14: DC Batteries




Tap Changer Controls

Seven voltage regulating relays are in operation having been installed with their associated transformers and are in good condition. Replacements will coincide with transformer replacements when due. Unexpected failures may require replacement with the modern voltage regulating relay standardised solution based on a SEL controller.

Metering

EIL has 'Time of Use' (TOU) meters on its incoming circuit breakers to provide accurate loading information on each zone substation. There are TOU meters on some feeders to provide indicative load profiles for certain load groups. The age profile of these is shown below.

Figure 15: Metering Assets



3.4 Distribution Network

EIL's distribution network has a total length of 182 km to supply its 17,774 customers, giving an overall customer density of 98 customers per kilometre. The 11kV distribution network is heavily meshed throughout the entire Invercargill area, with almost all distribution transformers having two separate 11kV supplies. Distribution in Bluff is largely meshed except at feeder extremities. The distribution network has the following layout.

- All underground cabling within the Invercargill CBD. Cable type (PILC – Paper Insulated Lead Covered, or XLPE – Cross-Linked Polyethylene) largely depends on date of installation.
- Suburban areas of Invercargill are either XLPE cable or overhead line. A gradual overhead to underground (OHUG) program has been implemented over several decades leaving less than 10 km of overhead construction that will remain overhead.
- The Bluff network is almost completely overhead construction due to the shallow soil over rock substrata geological profile, which makes undergrounding difficult. The Bluff area was originally operated at 3.3kV distribution, with conversion to 11kV taking place after EIL took over the assets.

The split of the distribution network per substation is presented in the following table. Safety and reliability are EIL’s strongest drivers for allocation of resources, with customer density providing an indication of priority of other works.


Table 11: Distribution network per substation

Substation	Line Length (km)	Cable Length (km)	Customers	Customer density
Spey Street	-	58.95	6745	115/km
Leven Street	3.65	28.52	1785	56/km
Racecourse Road	3.12	26.24	3241	111/km
Southern	1.58	39.47	4665	114/km
Bluff – EIL feeders	13.77	6.22	1056	53/km
Unallocated	-	-	282	-
Total/average	22.12	159.4	17,774	98/km

Overhead Distribution

EIL’s overhead distribution network uses a mix of concrete and wooden poles. The Bluff area remains overhead network, as Bluff’s rocky sub-surface makes undergrounding difficult and cost prohibitive.

Figure 16: Distribution Poles




The nominal life of poles varies with pole type - 45 years for wooden poles and 60 years for concrete. Industry experience has shown that poles can last substantially longer than nominal life. Therefore, condition-based replacement is more appropriate than age-based replacement. This approach aligns with EEA guidance, which recommends using pole condition assessments to determine renewal priorities. The replacement and renewal programme are based on five-yearly condition assessments carried out on all distribution lines.

The commissioning year for distribution line conductors is displayed in the following chart. Conductors are generally replaced based on condition determined through routine inspections. At present, there are no widespread or emerging risks identified within the conductor fleet; however, isolated instances of conductor degradation, corrosion, and broken strands are occasionally identified during inspections and addressed through targeted replacement or maintenance.

The current focus is on maintaining public and worker safety by continuing regular condition assessments, prioritising replacements in high-risk areas (such as coastal and high-wind region like Bluff region), and improving data capture from field inspections to better inform future renewal programs.

Figure 17: MV Line Conductors (11kV Overhead)




EIL has two 11kV pole mount field circuit breakers and an enclosed load break switch in service on the Bluff area network, located respectively at Gore, Bann and Palmer Streets. This switchgear was installed as part of network automation and reliability enhancements and is detailed as follows:

- The circuit breaker in Gore Street is a Nulec N24 reclosing circuit breaker manufactured in 1997. It was relocated in 2015 to an optimal location. It has minor signs of aging but is in satisfactory condition.
- The Bann Street circuit breaker is a Nova 15 reclosing circuit breaker manufactured in 2006 and kept in spares before being installed in 2015. It is basically in “as new” condition.
- The Palmer Street load break switch is an Entec solid insulation vacuum breaking switch and was installed new in 2015.

The figure below shows the number of 11kV and 33kV Air Break Switches (ABS) by commissioning year. Eighteen switches are in service in Bluff.

Figure 18: Air Break Switches




Most of the drop-out fuses on the network have been removed but there is a relatively small number remaining in Bluff. These fuses are most often used where a transformer is supplied from overhead lines.

Underground Distribution

Distribution cables were installed gradually on the Invercargill network as part of an undergrounding programme. Some cables have been installed in Bluff, but the Bluff network remains mostly overhead because the rocky subsurface makes undergrounding work difficult. The following chart shows the lengths of cables on EIL’s distribution network.

Figure 19: MV Cables (11kV)



Paper lead cables were predominantly used up to about year 2000 after which XLPE became the preferred cable type due to the ease of installation and subsequent works. Actual practical life for any cable is likely to be greater than the standard life. A cable fleet plan has been implemented in late 2022, which requires periodic condition assessment of cables. Planned future replacements will be based on these assessment data.

Distribution Substations

Just as zone substation transformers form the interface between the subtransmission and the 11kV distribution networks, distribution substations form the interface between the 11kV distribution and 400V distribution networks. The distribution substations range from a few remaining pole-mounted transformers to 3-phase 1,000kVA ground-mounted transformers supplied via circuit breaker ring main units that may include remote indication and control. These larger substations typically supply Invercargill CBD customers or special customers like the ILT Stadium.

Distribution Transformers

Each distribution transformer has medium voltage (MV) protection, usually provided by fuses, although some larger units are protected by circuit breakers with basic overcurrent and earth fault relays. Generally individual protection is applied at each site, although occasionally group protection is used where a single fuse is located at the take-off from the main feeder cable, with up to five downstream units permitted. LV protection is by the DIN¹ standard High Rupture Capacity (HRC) fuses sized to protect overload of the distribution transformer or outgoing LV cables.


The following table shows the number of distribution transformers by size on EIL's network. Transformers are installed at ground level, and after the extensive undergrounding programme only a few pole-mounted transformers remain.

Table 12: Number of distribution transformers

Phases	Rating	Pole Mount	Ground Mount
1 phase	up to 15 kVA	3	-
	30 kVA	1	-
3 phase	up to 15 kVA	-	1
	30 kVA	-	4
	50kVA	-	3
	75 kVA	-	1
	100 kVA	1	16
	200 kVA	2	67
	300 kVA	2	250
	500 kVA	-	57
	750 kVA	-	21
	1,000 kVA	-	18
	1,500 kVA	-	3
Total		9	441

The following chart provides an overview of the age profiles of distribution transformers. Transformers found to be in poor condition after planned inspections will be replaced, sometimes with units removed from service and refurbished for reuse. Many ground mounted units are enclosed and the reduced exposure to the weather has kept these transformers in above average condition for their age.


Figure 20: Age Profile of Distribution Transformers



Switchgear


The circuit breakers installed at the distribution substations (which are located within the Invercargill CBD) are shown in the next figure.

Figure 21: Field Circuit Breakers at Distribution Voltage (11kV)



The age profile of ring main units (RMUs) is displayed below. It should be noted that the quantities in this graph are expressed in terms of RMU modules – modern RMUs are individual modules sharing a common bus, while some older models of RMU integrate all connections into a single housing.

Figure 22: Age Profile of Ring Main Units



Operating restrictions are placed on some RMU equipment. This is to reduce risks and to manage hazards associated with oil-filled switchgear (as identified by incidents occurring in the wider industry). A solution has been developed that allows safe operation of suitable models of equipment without compromising arc-flash boundaries. A RMU fleet plan was implemented in 2022 which requires periodic condition assessments. Planned future RMU replacements will be based on these assessment data.


Remote Terminal Units

The early GPT mini RTUs were installed in 1995-98 to automate circuit breakers at distribution substations in the CBD. These units are at end-of-life and have proven unreliable. Replacements are done in tandem with switchgear replacements where most of these RTUs are located.

The Doon Street RTU has been retained to provide indications for the oil filled cables after the decommissioning of the power transformers, 11kV switchboard and associated auxiliary equipment. Another smaller Kingfisher PC-1 RTU was installed in 2004 at a distribution substation in the CBD and will be replaced at end of life.

Two modern SEL RTUs were installed at the Spey St zone substation in 2013 for secure remote indications and control for each half of the AAA security substation. A third SEL unit was installed at Leven St substation in 2016 to replace an end-of-life Harris RTU. An overview of the quantity and commissioning years of RTUs is presented in the next figure.

Figure 23: Number of Remote Terminal Units



3.5 LV Network

EIL monitors LV network performance through transformer loading, volt-drop assessments, and outage data. While specific LV failure rates and defect trends are tracked at an aggregate level, detailed maintenance analytics are currently limited due to the distributed nature of the LV network.

EIL's LV network (400/230 V) has a total length of 451 km to supply its 17,774 customers giving an overall customer density of 40 customers per kilometre. The proportions per substation of overhead and underground network, customer count and density are presented in the table below.

The 230/400 LV network almost totally overlays the 11kV distribution network and is present on virtually every street. The coverage of each individual distribution transformer tends to be limited by volt-drop to about a 200m radius.

The LV network has a moderate degree of interconnection that enables many customer connections to be supplied from "either end" in the event of a transformer failure. Transformer loading and volt drop tend to be the limiting factors in utilising these backups.

The reticulation of Invercargill CBD and most of the suburban areas is underground cable (mostly PVC with some older PILC cables). A couple of areas have overhead lines remaining. Bluff has overhead construction with underbuilt LV reticulation on most 11kV poles. Some undergrounding has occurred in a few locations. The growth in the LV network remains modest; however, the increasing penetration of distributed energy resources (DER), such as solar PV, is being carefully monitored. Any new connection requiring network upgrades is assessed to ensure that both current and future capacity needs are considered during the planning process.

Table 13: LV Network Characteristics per Substation


Substation	Line Length (km)	Cable Length (km)	Customers	Customer density
Spey Street	0.2	168.15	6745	40/km
Leven Street	3.13	51.87	1785	33/km
Racecourse Road	0.8	78.14	3241	41/km
Southern	1.2	119.49	4665	39/km
Bluff – EIL feeders	24.39	3.61	1056	38/km
Unallocated	-	-	282	-
Total/average	29.72	421.26	17,774	40/km

Overhead LV Conductors

EIL’s age profile for overhead LV conductors and poles is shown in the following charts. Almost all LV lines in the city have gradually disappeared from the Invercargill network as the services have been undergrounded with less than 6 km line length remaining. Most of the LV line length is on the Bluff area network where undergrounding is difficult due to the rocky subsurface.

Overhead LV conductors are replaced based on their condition. New overhead lines are ABC (Aerial Bundled Conductors) which do not require cross arms or insulators and has PVC insulation which improve line safety.

Figure 24: Overhead LV Conductors



LV poles are renewed as required based on their condition as identified during the regular inspections of the network. The number of poles and their commissioning year is presented below.

Figure 25: LV Poles




Underground LV Cables

The LV cable commissioning year profile, depicted in the following figure, shows several assets beyond nominal life of 45 years. Ageing and capacity constrained LV cables represent a quantifiable risk to SAIDI and SAIFI and may lead to customer voltage complaints or power quality issues, which are actively monitored and managed through smart meters.

Several 400 V cables installed in the early 1970s are now reaching capacity due to in-build and greater demand per household. This is typically seen as an increase in voltage complaints received due to excessive volt drop during periods of peak loading. Smart meters installed at customers’ premises improve the network’s ability to monitor voltage quality and proactively address issues before they are noticed by customers.

Figure 26: LV Cables



LV Cable replacement

Low voltage (LV) cable replacement is a critical process that begins with a thorough assessment of the existing LV network, including reviewing historical fault data, customer complaints, and smart meter readings to identify underperforming or deteriorated cables. Load flow studies are often performed to assess network performance, ensure adequate capacity, and verify voltage profiles under various loading conditions.

Once the need for replacement is confirmed, detailed planning is undertaken, including route surveys, load considerations, and coordination with network switching operations to minimize supply disruption. Replacement activities are frequently synchronized with other network interventions, such as service upgrades, transformer replacements, or network reconfigurations, to optimize efficiency. The outcomes of LV cable replacement enhance

network reliability, mitigate risks associated with aging infrastructure, and support the long-term performance and resilience of the low-voltage distribution network.

MV Cable testing

Medium voltage (MV) cable testing is a critical part of ensuring the reliability, safety, and performance of an electrical distribution network. The process typically begins with a thorough review of the network configuration and historical performance data, including smart meter data, which allow engineers to identify voltage drops, load imbalances, or potential weak points across ICPs and transformers. Following this initial assessment, targeted diagnostic tests are carried out on the MV cables.

Additionally, load flow studies are performed to simulate network performance under various operating conditions, helping to pinpoint areas where voltage drops, or overloading may occur. The testing process is often coordinated with planned maintenance and for network upgrades, such as 11 kV cable replacements, to ensure minimal disruption to supply while addressing potential faults. The results of these tests inform maintenance decisions, highlight cables requiring immediate replacements, and guide long-term network planning, ensuring that the electrical distribution system remains safe, efficient, and resilient. The recent MV cable testing programme has returned generally positive results, confirming that most 11 kV cables remain in good condition and continue to operate safely. While this is reassuring, EIL is taking a cautious, safety-led approach by planning a modest and carefully prioritised 11 kV cable replacement programme.

3.6 Customer Connections

EIL provides a connection to the network via sixteen retailers which convey electricity over the network. Customer connections generally involve assets ranging in size from a simple fuse on a pole or in a suburban distribution pillar to dedicated lines and transformer installations supplying single large customers. In most cases the fuse forms the demarcation point between EIL’s network and the customer’s assets (the “service main”) and this is usually located at or near the physical boundary of the customer’s property. All EIL network assets convey energy to customers and are a cost that must be matched by the revenue derived from customer connections. The number and classes of customer connections are listed below.

Table 14: Classes of Customer Connections

Date	Small (≤ 20 kVA)			Medium (21 – 99 kVA)			Large (≥100 kVA)			Total	
	1 kVA 1ph	8 kVA 1ph	Low User	15 kVA Mixed Phase 15 kVA 3ph	30 kVA 3ph	50 kVA 3ph	75 kVA 3ph	100kVA 3ph	Non ½hr Metered Individual		½hr Metered Individual
Mar-21	49	309	6479	9199	654	385	133	74	48	123	17,453
Mar-22	46	311	6386	9351	48	123	17,453	78	41	131	17,524
Mar-23	45	308	6367	9449	650	388	137	81	38	132	15,595
Mar-24	45	312	6568	9327	656	399	137	82	31	137	17,694
Mar-25	55	308	6417	9512	660	405	139	84	27	144	17,751

3.7 Assets for Control and Auxiliary Functions

EIL has a range of other assets to provide control or other auxiliary functions as described in the following tables and paragraphs.

Bulk Supply Assets

The company owns an injection plant at Invercargill GXP which was commissioned in 1989, with all plant enclosed within the building. This provides protection from the elements and therefore an extended life is expected for the non-electronic components. The electronic components continue to provide good service with the power supply unit upgraded in 2005, after failures at other sites. While the plant has reached end of expected standard life, the 2005 upgrade and the general condition indicate that the plant will last until the completion of smart meter rollout makes it redundant.

Load Control Assets

Table 15: Load Control Assets

Load Control Assets	
Ripple Injection Plant and Receivers	EIL currently owns and operates a 33 kV 216 $\frac{2}{3}$ Hz 125 kVA ripple injection plant at Invercargill. Ripple relays at customers' premises respond to the injected ripple signal and switch controllable load (such as hot water cylinders and night-store heaters) providing effective load control for the network. The ripple injection plant is backed up from the adjacent TPCL plant and vice versa.

Protection and Control

Table 16: Protection and control

Protection and Control	
Circuit Breakers	Circuit breakers provide switching and isolation points on the network and generally work with protection relays, to provide automatic detection, operation, and isolation of faults. They are usually spring charged or DC coil operated and able to break full load current as well as interruption of all faults.
Protection Relays	Protection relays have always included over-current and earth-fault functions, but more recent equipment also includes voltage, frequency, directional and circuit breaker fail functionality in addition to the basic functions. SOLKOR differential protection is also used extensively on 11kV cables in the Invercargill CBD. Other relays or sensors may drive circuit breaker operation. Examples include transformer and tap changer temperature sensors, gas accumulation and surge relays, explosion vents or oil level sensors.
Fuses	Fuses provide fault current interruption of some faults and may be utilised (by manual operation) to provide isolation at low loading levels. As fuses are simple over-current devices, they do not provide a reliable earth fault operation, or any other protection function.
Switches	Switches provide no protection function but allow simple manual operation to provide control or isolation. Some switches can interrupt considerable load (e.g., ring-main unit load break switches) but others such as air break switches may only be suitable for operation under low levels of load. Links generally require operation when de-energised and so provide more economic but less convenient switch points.
Batteries and Chargers	Batteries, battery chargers, and battery monitors provide the direct current (DC) supply systems for circuit breaker control and protection functions and allow continued operation of plant throughout any power outage.
Voltage Regulating Relays	Voltage Regulating Relays (VRRs) provide automatic control of the 'Tap Change on Load' (TCOL) equipment integral to power transformers and regulate the outgoing voltage to within set limits.
Neutral Earthing Resistors (NERs)	Neutral Earthing Resistors (NERs) installed at zone substations limit earth fault currents on the 11kV network. These significantly reduce the earth potential rise which may appear on and around network equipment when an earth fault occurs.

SCADA and Communications

The PowerNet-owned SCADA was updated and re-commissioned in 2017. The planned upgrade for Racecourse Road substation in 2023/24 was completed in 2024/2025 and included a communications upgrade to fibre. This will be the last zone substation to be changed over to fibre communications in EIL. The fibre installation project has been completed in 2024/25.

Table 17: SCADA and Communications

SCADA and Communications	
SCADA Master Station	Supervisory Control and Data Acquisition (SCADA) is used for control and monitoring of zone substations and remote switching devices, and for activating load control plant. EIL's SCADA is provided as a service by PowerNet Ltd, with the master station located at Findlay Road GXP with backup at PowerNet office at Racecourse Road. This system is based on the process industry standard 'iFIX' with a New Zealand developed add-on 'iPOWER' to provide full Power Industry functions.
Communication Media	EIL currently owns and operates a fibre optic network to communicate between all zone substations. Communication is mostly fibre between CBD distribution substations and the SCADA master station at System Control from where control commands may be issued. Mesh radio used for communication to other distribution sites outside the CBD, including Bluff.
Remote Terminal Units	Spey Street zone substation has a modern SEL based RTU. Leven Street and Southern substation RTUs have been upgraded from the older Kingfisher RTUs. Kingfisher RTUs are only used in Doon Street substation and Racecourse Road substation (planned upgrade to new RTU in /2026/27). All RTUs communicate with DNP3.0 protocol.

Mobile Plant/ Load Correction/ Generation

EIL does not own any mobile substations, power factor correction plant, mobile generation, or standby generation plant; however, PowerNet owns three mobile diesel generators rated at 500 kW, 350 kW and 275 kW which EIL uses to maintain supply to customers when assets are removed from service for maintenance.

Table 18: Other Assets

Other Assets	
Generation	EIL does not own any mobile generation plant but may utilise three diesel generators owned by PowerNet. These are rated at 450 kW, 350 kW and at 220 kW. There are no stand-by generators owned or able to be utilised by EIL.
Power Factor Correction	Customers are required to draw load from connection points with sufficiently good power factor to avoid the need for network scale power factor correction. As such EIL does not own any power factor correction assets.
Mobile Substations	EIL can utilise a TPCL owned trailer mounted 3 MVA 11kV regulator and circuit breaker with cable connections though it is unlikely to be required due to the excellent backup capability of the 11kV network. EIL can utilise a TPCL owned trailer mounted 5 MVA 33/11kV mobile substation with cable connections.
Metering	Most zone substations have time-of-use (TOU) meters on the incomers that provide details of energy flows and power factor.

3.8 Summary of EIL asset base

EIL applies lifecycle strategies to major asset classes to ensure renewal forecasting reflects asset condition, obsolescence, and end-of-life considerations. These strategies consider operational limitations, safety constraints, and expected asset lifespans. The annual work programme ensures that lifecycle strategies are systematically linked to the AMP's capital renewal forecasts, maintaining reliability, safety, and service continuity while addressing obsolescence and asset replacement needs.

The EIL asset base can be summarised as per the following table:

Table 19: EIL Asset Base Summary

Asset Class	Group	Total number in EIL
Distribution Transformer	OH (Up to 100kVA)	9
Distribution Transformer	UG (up to 1MVA) + Platform	441
Power Transformer	1-4MVA	0
Power Transformer	4-8MVA	0
Power Transformer	8-16MVA	0
Power Transformer	> 16MVA	7
Overhead Switch	ABS	42
Overhead Switch	LBS (Solid Mould)	3
Protection Relay	G1 - Substation	127
Protection Relay	G2 - Field	52
Battery	G1 - Substation	70
Battery	G2 - Field	54
Distribution Earth	G1	591
RMU	Oil + Solid Insulation	450
RMU	Gas Insulation	0
Metalclad Switchgear	All	4
Field CB	Field	2
Field CB	Zone	0
Poles	Wood	185
Poles	Concrete/steel	759
Cables	HV Cable XLPE	15
Cables	HV Cable Oil Pressurised	12
Cables	MV Cable XLPE / PVC	68
Cables	MV Cable PILC	92
Cables	LV Cable < 1000V	426
Instrument Transformers	VT	19
Instrument Transformers	CT	135
Neutral Earthing Resistor	Zone Subs	4
Regulators	Zone Subs	0
VRR	All	9
PLC	All	0
Injection Station	All	1
Capacitor Banks	All	0
CT-VT Units	Field	2
CT-VT Units	Zone	0

Asset Class	Group	Total number in EIL
Generators	network-owned, <=600kVA	0
LV Outdoor Cubicles	All	9240
OHL	km	53
Statcom	All	0
Battery Chargers	Zone	26
Battery Chargers	Field	0
Fibre	All	34
Fault Indicator	All	243
Power Supply	All	0
RTU	Zone	13
RTU	Field	17
Earth Mat	Zone	5
Earth Mat	Field (regulator site)	0
Fault Throw Switch	All	0
Oil Separator	All	3
Surge Diverter	Zone	73
Surge Diverter	Field	10
Zone Substation	Buildings	4

3.9 Load Characteristics

Load profiles for domestic households and the CBD are described in the following paragraphs.

Domestic Load Profiles

Standard household demand peaks in the morning (10:30am) and evening (6:30pm). The use of heat pumps is increasing electricity usage, with no noticeable impact over the summer hot period yet. Peaks normally occur in the winter months as heating requirements increase. A typical daily domestic load profile and a typical annual domestic load profile are shown in the following charts.

Figure 27: Domestic Feeder Daily Load Profile (July, Racecourse Road CB8)





Figure 28: Domestic Feeder Yearly Load Profile (Racecourse Road CB8)



CBD Load Profiles

Load peaks in the CBD later in the day (10am-12pm) as people migrate into the area for their workday. Weekday loading is typically significantly higher than over the weekends corresponding to work patterns of the businesses in the CBD. Seasonal variation in the CBD load profile is similar to that of domestic loading with peak load occurring over the winter months. The CBD profiles shown in the two charts below include some industrial load which tends to follow similar consumption patterns.

Figure 29: CBD Feeder Daily Load Profile (July, Leven Street CB10)





Figure 30: CBD Feeder Yearly Load Profile (Leven Street CB10)



Energy and Demand Characteristics

Key energy and demand values for the year ending 31 March 2025 are presented in below.

Table 20: Energy and Demand Values

Parameter	Value	Long-term trend
Energy Conveyed	268.50 GWh	Variation around minimal growth
Maximum Demand ²	66.02 MW	Large variation around minimal growth
Load Factor	47%	Reasonably constant
Losses	4.7%	Varying

Maximum demand and total energy conveyed (as recorded for any year) are greatly affected by the weather and determining growth rates from this historical data is challenging. Mathematical treatment such as “best fit” curve application yields completely different results when applied to different past time periods, for instance five (5), ten (10) or twenty (20) years. Shorter time periods give variable results due to the large influence of each calendar year, while longer time periods do not account for recent trends. Growth rates are often based on an educated estimate from the planning engineer and confidence in the growth rates shown in the above table is low.

² This is different from the sum of the individual demands at each GXP, which will be greater than the coincident demand due to diversity.

4

Risk Management

SECTION CONTENTS

4	Risk Management.....	66
4.1	Risk Strategy and Policy.....	66
4.2	Risk Management Methods.....	66
4.3	Company related risks (general).....	70
4.4	Asset Management Risks.....	72
4.5	System Risks.....	83
4.6	Asset Criticality.....	85
4.7	Price Elasticity of Demand.....	85

Tay Street, Invercargill

4 RISK MANAGEMENT

EIL uses risk management techniques to keep our risk exposure within acceptable levels. Risks can often not be fully eliminated and therefore an acceptable level of residual risk needs to be determined along with appropriate timeframes for the implementation of risk treatment measures.

This section examines our risk exposures, focussing on the asset management risks. It describes the management of these exposures and activities to reinstate service levels should disaster strike.

4.1 Risk Strategy and Policy

“Understand and Effectively Manage Appreciable Business Risk” is a key corporate strategy and critical business task within EIL. As a result, EIL’s asset management strategies directly or indirectly also incorporate risk management.

EIL has agreed to work within the PowerNet-developed risk management policy. Following the change in ownership of PowerNet and the signing of a new NMA, EIL is developing its own risk framework. Currently the PowerNet risk management policy informs the risk management framework to formalise the practices for the effective management of risks that EIL’s business faces. This ensures greater consistency in the quantification of various risks and correct prioritisation of their mitigation, as well as ensuring regularity of review. The framework is consistent with the ISO Standard ISO 31000:2018 Standard: Risk Management - Guidelines.

4.2 Risk Management Methods

EIL requires PowerNet to manage asset management risks on EIL’s behalf and, where risks exceed operational authority or risk appetite, to escalate them through the EIL General Manager for consideration and, where appropriate, onward escalation to the EIL Board. Decision-making related to EIL’s asset management risks is guided by the following principles.

- Risk plans will, in general, only focus on one major event occurring at any given time.
- Safety of the public and staff is paramount.
- Essential services are the next priority.
- Large impact work takes priority over smaller impact work.
- Switching to restore power supply takes priority over repair work.

Risk Identification

Risks need to be identified before they can be mitigated. Many risks might seem obvious, yet the identification of others require experience and insight into the many factors that could have a significant impact on business objectives. The following risk categories have been established to ensure that various risk types are considered, and that review responsibility is allocated to the applicable manager.

- Health and Safety.
- Environmental.
- Financial.
- Network Performance.
- Operational Performance.
- Reputation.
- Governance.
- Regulatory Change and Compliance.

This top-down approach is supplemented by a less formal bottom-up process where staff are required to consider and report any risks as they become evident. The Health and Safety category is an exception as a formal policy exists to ensure as many incidents as possible are proactively reported (including near hits) to help identify hazards and control measures as a priority.

Risk categories are reviewed when there is a change in perception of the risks that EIL faces, especially following events which may affect local networks, other catastrophic events which might have global impact, or a change in regulations which may require risk to be considered in greater detail.

In this AMP, risk is defined as any potential but uncertain occurrence that may impact on EIL’s ability to achieve its objectives and ultimately the value of its business.

Risk Quantification

Once a risk has been identified it is quantified by determining the following.

- The severity of consequences associated with the risk.
- The probability that the consequences will manifest.

These factors are categorised using the terms described in the following tables to encourage an intuitive assessment of consequence and probability. This categorisation also allows for the use of more robust calculations where practical (especially regarding probability).

Table 21: Consequence Descriptions

Consequence	Description
Insignificant	Operational impact easily handled through normal internal control processes
Minor	Some disruption possible; able to be managed with management input
Moderate	Significant disruption possible; managed with additional management input and resources
Major	Business operations severely damaged or disrupted; requires extraordinary management input and resources
Extreme	Disaster; extreme impact on staff, plant, and/or operations

Table 22: Event Consequence Categorisation

Risk Category	Consequence				
	Insignificant	Minor	Moderate	Major	Extreme
Health and Safety	First aid treatment	Medical treatment injury or illness	Lost time injury or illness	Serious permanent disabling injury/illness	Fatality/fatalities
Environmental	Reversible impact, addressed immediately, remediated < 24 hours	Reversible impact, addressed short term, remediated < 1 week	Reversible impact, addressed medium term, remediated < 1 month	Long term recovery typically taking years	Irreversible widespread damage to environment
Financial	Asset impact of < 0.1% or revenue impact of < 0.1%	Asset impact > 0.1% and < 0.2% or revenue impact > 0.1% and < 1%	Asset impact > 0.2% and < 1% or revenue impact > 1% and < 10%	Asset impact > 1% and < 20% or revenue impact > 10% and < 50%	Asset impact of > 20% or revenue impact of > 50%
Network Performance	Exceeding SAIDI/SAIFI limits during a year, actively managing performance	Exceeding SAIDI/SAIFI limits during year, increased management effort and intervention required	Recoverable and explainable breach of SAIDI or SAIFI regulation (no underlying asset condition issues)	Significant breach of SAIDI/SAIFI regulations triggering investigation and penalties (underlying systemic asset condition issues)	Ongoing repeated significant breaches resulting in loss of control of AMP programme due to regulatory intervention
Operational Performance	Operational impact easily handled through normal internal control processes	Some disruption possible; able to be managed with management input	Significant disruption possible; managed with additional management input and resources	Business operations severely damaged or disrupted; requires extraordinary management input and resources	Disaster; extreme impact on staff, plant, and/or operations

Risk Category	Consequence				
	Insignificant	Minor	Moderate	Major	Extreme
Reputation	Social media attention - one-off public attention	Attention from recognised regional media - short term impact on public memory	Ongoing attention from recognised regional media and/or regulator inquiry	Attention from recognised national media and/or regulator investigation - medium-term impact on public memory	International media headlines and/or government investigation - long-term impact on public memory
Governance	Board awareness	Board and shareholder awareness	Perception of systematic underperformance, shareholder concern	Ongoing shareholder dissatisfaction	Dysfunctional governance - major conflicting interests or fundamental change in governing board of directors
Regulatory Change and Compliance	Audit provisional improvement notice	Minor non conformance	Breach with risk of prosecution or emerging regulatory change with potential to affect business	Prosecution of Director and/or officers or regulatory change enacted	Breach resulting in imprisonment of Director and/or officers or appointment of statutory board to a network or impact of regulatory change resulting in complete business transformation

Table 23: Event Probability Categorisation

Likelihood	Description	Frequency
Almost Certain	The consequence is expected to occur in most circumstances	Occurs three times or more per year
Likely	The consequence has a reasonably high chance of occurring in many circumstances	Occurs once or twice per year
Possible	The consequence could conceivably occur in some circumstances	Typically occurs in 1-10 years
Unlikely	The consequence is unlikely to occur in most circumstances	Typically occurs in 10-100 years
Rare	The consequence would occur only in exceptional circumstances	Greater than 100-year event

Risk Ranking

Consequence and probability provide an overall measure of a risk. The following risk matrix indicates how these factors can be combined to present a relative risk level.

Table 24: Risk Ranking Matrix

		Consequence				
		Insignificant	Minor	Moderate	Major	Extreme
Likelihood	Almost Certain	3	4	6	7	8
	Likely	3	3	5	6	7
	Possible	2	3	4	5	7
	Unlikely	1	2	3	4	6
	Rare	1	1	2	3	5

The figures in each cell of the table indicate the relative risk level.

The risk matrix inherently recognises High Impact Low Probability (HILP) events and gives them a high-risk level ranking. Risks that are within the EIL Board’s risk appetite receive appropriate attention, as described below. Risks that are outside the EIL Board’s risk appetite are managed by the EIL Board..

Table 25: Management attention to risk rankings

Low	Medium	High	Critical
Risk managed through routine management/ internal control procedures	Risk to be reported to relevant manager, may require additional risk treatment actions	Risk to be reported to chief executive and senior leadership team to approve and monitor risk treatment actions	Risk to be reported to the board to approve and monitor risk treatment actions
Levels 1 & 2	Level 3	Level 4 & 5	Level 6, 7 & 8

Risk Treatment and Mitigation

Risks often cannot be eliminated and therefore an acceptable level of residual risk needs to be determined along with appropriate timeframes for the implementation of risk treatment measures. Often several treatment options are available, and each is likely to have different cost, effort and timeframes associated. Furthermore, each treatment option could be more or even less effective than another option. Treatment options are not necessarily mutually exclusive and may be used in combination where appropriate. The table below summarises the types of treatment options that are considered for any risk. These options are ordered by effectiveness for the control of risk.

Risk management is a core input into PowerNet’s asset management, operational planning and investment decision making processes.

Risks identified through the risk framework are assessed for their likelihood and consequence, and where treatment is required, are translated into appropriate asset and operational responses. These responses may include changes to maintenance and inspection regimes (OPEX), asset renewal or replacement, network reinforcement, resilience initiatives or other capital works (CAPEX).

For material risks, potential treatment options are evaluated on a risk cost benefit basis, considering:

- the expected reduction in likelihood and/or consequence of the risk,
- the impact on safety, reliability and service levels,
- whole of life cost and timing, and
- alignment with regulatory, statutory and organisational objectives.

Treatment options are rationalised and prioritised through investment forecasts, Annual Works Programmes and the Asset Management Plan, ensuring that expenditure is targeted toward those risks that present the greatest threat to the business, customers and stakeholders.

Table 26: Options for Treatment of Risk

Option	Description
Terminate	Deciding not to proceed with the activity that introduced the unacceptable risk, choosing an alternative more acceptable activity that meets business objectives, or choosing an alternative less risky approach or process.
Treat	Implementing a strategy that is designed to reduce the likelihood or consequence of the risk to an acceptable level, where elimination is excessive in terms of time or expense.
Transfer	Implementing a strategy that shares or transfers the risk to another party or parties, such as outsourcing the management of physical assets, developing contracts with service providers, or insuring against the risk. The third-party accepting the risk should be aware of and agree to accept this obligation.
Tolerate	Making an informed decision that the risk rating is at an acceptable level or that the cost of the treatment outweighs the benefit. This option may also be relevant in situations where a residual risk remains after other treatment options have been put in place. No further action is taken to treat the risk; however, ongoing monitoring is recommended.

Good risk management recognises that limited resources are available and that not all risks can be effectively mitigated immediately. The desired outcome for risk treatment is the lowest-cost option or combination of options that reaches an acceptable residual risk level within an appropriate timeframe. A low-cost option providing very effective mitigation compared with a higher cost option providing less effective mitigation might be an obvious choice, however deciding between high cost but effective treatments and low cost, but less effective risk treatment options may be difficult and requires careful evaluation of all factors involved.

Depending on the magnitude of risk identified, a large-scale programme may be initiated to quickly reduce risk. Often asset management related risks will have mitigating solutions that become a part of design standards used on the network. The level of risk will determine if standards are retrospective i.e., applied to shape the existing network rather than only applying to new assets installed.

Effective risk management requires prioritisation of the many risk reduction actions identified and to do this the “greatest risk reduction utilising available resources” is used as a guiding principle. Appropriate resourcing needs to be considered, and adjustment of available resources may be required to control risk appropriately. This is explicitly recognised as part of the Health and Safety at Work Act (2015) and through EIL corporate risk where sufficient resources to reduce hazards “as low as reasonably practicable (ALARP)” must be provided.

PowerNet has developed and operates an Incident Management and Business Continuity Plan that activates in the event of a significant risk materialising. PowerNet are now utilising the national Coordinated Incident Management System (CIMS) (3rd edition). CIMS represents New Zealand’s official framework to achieve effective co-ordinated incident management across responding agencies. A number of the Senior Leadership Team members and other staff have been trained in CIMS to manage the Incident Management Team should any such events occur. Training is ongoing to ensure sufficient resources will be available in any high-risk event. The Incident Management and Business Continuity Plan is tested on a regular basis using real life scenarios to ensure that it functions effectively. PowerNet will activate CIMS for any event that occurs outside business as usual, and which requires a focussed team to resolve.

4.3 Company related risks (general)

Significant company related risks that were identified are described in the next paragraphs.

Cyber Security

PowerNet has a cyber strategy that is reviewed and updated on an annual basis. Continuous improvement is supported by assessments against industry frameworks and planned enhancements to strengthen security across both corporate and operational technology environments. Annual penetration testing and cyber audits are performed to measure the cyber risk.

PowerNet’s Security Operations Centre (SOC) provides 24/7 monitoring and analysis of both PowerNet’s Corporate IT and Operational OT networks.

Cyber tabletop exercises are run in conjunction with other New Zealand EDBs including Aurora and Vector. Staff awareness is reinforced through ongoing training and simulated exercises.

Industry Regulation

Risks pertaining to industry regulation have been identified as the following.

- Investment – providing business processes that ensure appropriate contracts and guarantees are agreed prior to undertaking large investments.
- Loss of revenue – loss of customers through by-pass or economic downturn could reduce revenue. EIL manages this risk through ensuring that it invests capital in a prudent and efficient manner to benefit its customers with a reliable and resilient connection.
- Customer price shock – DPP4 will see significant price increases. EIL is working closely with industry stakeholders to communicate the reasons and benefits of the investments being made in the electricity sector
- Management contract – failure of PowerNet as EIL’s asset manager. EIL monitors and manages the contract to confirm PowerNet is delivering the required value to TPCL and its shareholders.
- Regulatory – failure to meet regulatory requirements.
- Central government electricity reforms and changes in policy on any number of industry-related issues:
 - Decarbonisation
 - Industry structure
 - Electricity pricing, etc.

EIL is managing this risk by working with industry and government to effectively influence and deliver the change that is being proposed.

International Labour Market

Internationally, many economies continue to manage elevated inflationary pressures. While inflation has moderated in some regions, interest rates remain higher than previously anticipated, constraining economic activity while increasing the cost of capital. Governments are responding by maintaining or accelerating investment in infrastructure to support economic resilience and energy transition objectives. In parallel, capital expenditure associated with electrification and climate change mitigation continues to grow, particularly within the energy sector. This has increased global demand for skilled labour across all worker categories.

PowerNet staff working on the EIL network are being approached and offered sometimes significant increases to move to other utilities in New Zealand but also Australia. This leads to:

- A shortage of field staff required to undertake operation, maintenance, renewal, up-sizing, expansion, and retirement of network assets.
- A shortage of other technical staff such as engineers and project managers that must plan and manage the work issued to the field staff.
- Increased demand for corporate staff such as GIS, IT, analysts and accountants with industry experience.
- A shortage of industry knowledge and experience as skills have to be attracted from other sectors.
- Increased emphasis on succession planning for an industry that has an ageing work force and is losing sector knowledge.
- Increased requirement and cost to upskill and train technical and non-technical staff in the industry.

Increases in the cost of equipment

A significant proportion of materials and equipment used in the electricity supply industry is imported. Equipment prices continue to increase at rates exceeding CPI, driven by global supply and demand imbalances, exchange rate volatility, and the potential for tariff or trade-related cost pressures. Demand is being reinforced by national and international decarbonisation and electrification initiatives, particularly in transmission, distribution, and generation infrastructure.

War in the Ukraine

Although the war in Ukraine does not directly affect EIL operations, it continues to contribute to global energy market volatility, particularly fuel prices. These cost increases flow through to contractor pricing, logistics, and operational costs. Given the revenue cap framework under which EIL operates, sustained cost inflation directly reduces the volume of work that can be delivered within allowable expenditure..

Conflict in the Middle East

Conflict in the Middle East has the potential to increase global economic uncertainty and, if it continues or further escalates, may affect the supply and pricing of crude oil and other commodities. While the direct impact on EIL is currently limited, any resulting increase in fuel or material costs would place additional pressure on operating and capital programmes.

Table 27: Industry Regulation Risks and Responses

Event	Likelihood	Consequence	Responses
Impact of economic factors (on prices to customers and returns to shareholders)	Possible	Major	<ul style="list-style-type: none"> Hedge interest rates as per treasury policy and treasury advisor Monitor interest rate and Commerce Commission WACC changes
Failure of the NMA	Rare	High	<ul style="list-style-type: none"> Continue managing the management contract with PowerNet noting that it operates a Business Continuity Plan PowerNet investment in improving its business management systems and processing Continued regular bi-directional feedback interactions with the relevant stakeholders
Regulatory breaches	Possible	Moderate	<ul style="list-style-type: none"> Continue to contract PowerNet to meet regulatory requirements. Ensure PowerNet has and operates to an Incident Management and Business Continuity Plan.
Inability to attract and retain required skills for PowerNet to meet its core purpose	Almost certain	Moderate	<ul style="list-style-type: none"> PowerNet undertakes overseas recruitment, when required, to access skills that are scarce in NZ, and takes steps towards growing local talent Continued development of attraction strategies and recruitment brand

4.4 Asset Management Risks

The following extract from the corporate risk register indicates risks specifically relating to asset management.

Table 28: Asset Management Risks

Category	Risk Title	Risk Cause	Worst Case Scenario	Treatment	Containment Plan Summary
Network Performance	Failure of Asset Lifecycle Management	Mechanical or electrical failure, ineffective maintenance ineffective fleet plans Budget constraints Lack of future network planning	Reliability collapse/ fall; Voltage limits not maintained; Safety compromised; mechanical or electrical failure; ineffective maintenance and operations leading to loss of value; networks cannot supply future loads; environmental issues	Treat	Standardised designs and equipment Inspection and testing of primary and secondary plant Safety in design process Development of asset fleet plans Asset management plans and work plans Implemented AMMAT Improvements Business Management framework
Network Performance	Operational systems failure due to breakdown in telecommunications	SCADA communications has one centralised communications point that all information is passed through	Loss of SCADA would require resorting to manual oversight of the networks	Treat	Revert to manual operation of substations

Category	Risk Title	Risk Cause	Worst Case Scenario	Treatment	Containment Plan Summary
Network Performance	Intentional Damage	Terrorism, theft, vandalism Reputation	Damage to equipment; Compromise or damage to systems/ data; requirement for change in network configuration; SAIDI/ SAIFI Impacts; Reputational Impacts	Treat	Physical security at substations Inspections Monitored alarms, security beams at some depots Security cameras at some depots and substations based on previous incidents SMS Audits Operational network isolated from Corporate network
Network Performance	Loss of right to access or occupy land	Risk of assets losing / not having the right to occupy particular locations (e.g. Aerial trespass, subdivision)	Objection of landowner where line is over boundary; Demand for removal of assets and/ or legal action	Tolerate	Move equipment Audit of processes in place Awareness Obtain easements Renegotiate land boundaries where historic issues exist
Operational Performance	Damage due to high impact low probability extreme Physical Event (i.e., Christchurch earthquake)	Damage caused by force majeure to our infrastructure or equipment (e.g., floods, earthquakes)	Limited staff, facilities or equipment available	Treat	Strengthening of buildings and equipment. Move resources between depots Approach other South Island Lines Companies for assistance (MA) Seismic review of sites. CIMS training and readiness Mobile substation Network planning to avoid high risk sites
Operational Performance	Full sector reputation damage	Loss of stakeholder confidence due to nationwide issues and concerns with electricity industry or EDB sector specifically DPP4 step change in pricing and distribution may cause political and or consumer reaction	Significant dissatisfaction with electricity industry due to adverse impacts for customers, such as price shock through changes in sector pricing. Could be triggered by electricity shortage, change in pricing methods impacting on specific customer groups and/ or distribution price increases as a result on DPPQ reset and higher WACC	Treat	Communication of Shared Purpose, specifically focus across Safety, Efficiency and Reliability. Assist stakeholders understand the role PowerNet and managed EDBs play in the electricity supply chain, i.e. education of customers. Changes to sensitive triggers such as pricing considered, and wider impacts understood prior to proceeding. Benefits of local community ownership understood by stakeholders
Operational Performance	Potential liability for private lines and connections	Regulatory change; Poor historical process/records Fatality with some repercussion for PowerNet - legal advice has not been tested in court	Obligation to maintain assets vested in the network	Treat	Inspection regime Legal advice Operational management around interacting with private lines Reports to Energy Safety Public education

Category	Risk Title	Risk Cause	Worst Case Scenario	Treatment	Containment Plan Summary
Operational Performance	Major Contractual Breach	Breach of contractual obligations in place with key counterparties, resulting in legal action with potential serious financial implications and/or reputational damage	Breach of agreement results in loss of ability to continue to provide the service. This results in a significant reduction in value the business	Treat	Contractual obligations well understood and appropriate persons managing key commercial contracts, including training on contractual management. Understanding of key obligations and how these are being met is understood by responsible persons. Legal opinions and review. No recourse clauses in commercial contracts
Operational Performance	Unavailability of critical spares	Poor future work planning; High impact low prob; ability events causing high spares usage; Supply chain disruptions	Inability to supply	Treat	Network modelling Project management planning process Detailed critical spares requirements Annual works programme Standardisation of equipment
Operational Performance	Loss of key critical service provider	Economic environment; Lack of sufficient work to sustain; unexpected inability of contractor to complete work; Major health event/ pandemic	Inability to build or maintain assets; Unable to service existing contracts	Treat	Tendering of capital projects Work planning Providing contractors with clarity of future work Contingency planning Testing alternate suppliers Internalise the resource SLA/Contract management with critical service providers
Operational Performance	Major event causing significant network disruption	Damage caused by wind, snow, storm events	Delayed or limited provision of power to customers; Loss of ability to provide power to customers for extended periods;	Treat	Moving resources between depots Alternative supply (Mobile Sub & Generators) Use of neighbouring subs - where available New work to current codes/ standards Business Continuity planning Use of satellite phones Implementation of CIMS

Category	Risk Title	Risk Cause	Worst Case Scenario	Treatment	Containment Plan Summary
Financial	Change to EDB Environment	External decision makers trigger industry disruption and change; Regulatory intervention in industry structure and/or economic return framework	Forced amalgamation of EDBs with asset value and sales transaction set/ influenced by third parties with risk of significant shareholder value destruction	Tolerate	<p>Significant input into EDB industry regulatory direction, through presentation in industry bodies at both Board and Working Group level.</p> <p>Advancement of initiatives and shared services to demonstrate PowerNet / managed EDB and wider EDB sector efficiencies (for example, SI EDB Forum, and EDB collaboration on standards).</p> <p>Direct engagement by PowerNet and managed EDBs with key stakeholders, outlining the PowerNet business model and demonstrating scale and efficiency benefits whilst ownership not impacted.</p> <p>Direct relationship building with key</p>
Regulatory Change & Compliance	Gaps or breaches in Industry regulation	Changes to the industry environment result in uncertainty of accountability and authority to operate	Ability to operate in part of the industry restricted or removed due to regulatory gap, for example, own / operate new technology and gain value from that opportunity	Tolerate	<p>Understanding of emerging risk areas and motorising and managing the situation directly and/or through industry bodies</p> <p>Ensuring aware of regulatory obligations and where risks of breaches may occur. Appropriate persons managing and monitoring these risk areas</p>

Category	Risk Title	Risk Cause	Worst Case Scenario	Treatment	Containment Plan Summary
Health & Safety	Public coming into contact with live assets	Unexpected public actions affecting our assets or asset integrity affects public safety. Network System protection is not designed to protect human life, during Incidents involving high resistance, low current faults. These faults do not generate sufficient current to trigger the network protection devices yet produce sufficient current to cause harm.	Serious injury or fatality; Prosecution under H&S Act	Treat	Asset inspections Assets fail to a safe condition (protection systems) Network design specifications External auditing Public safety management system Extensive signage for warning and awareness around all HV and LV assets Road corridor management in liaison with Waka Kotahi to address any dark spots where poles on road reserve are located in high crash rate areas Education campaigns including schools, before you dig, nurseries, field days, vegetation management staff discussing risk with homeowners and commercial entities Close approach process Manual reclose procedures
Environmental	Breaches of environmental legislation	Failure of assets, oil spill, bunding, hazardous goods breach	Breaches of environmental legislation Cost of rehabilitation	Tolerate	Hazardous good storage, Retrofits, Bunding, Regular inspections, Condition monitoring, Design standards

Asset management specific risks are in the categories of Network and Operational Performance, Health & Safety and Environmental. These risks can partly or in full be addressed through the asset management system. A summary of the risk assessment under each of these categories is described in the next paragraphs.

Network and Operational Performance

The following network and operational performance risks were identified, and the quantification and treatment responses are summarised in the following table.

- **Equipment Failures** – equipment failures can interrupt supply or prevent systems from operating correctly, for example, failure of a padlock could allow public access to restricted areas.
- **Fire** – transformers are insulated with flammable mineral oil and buildings contain combustible materials. Fire could be triggered by internal or external sources and will impact electricity supply.

Table 29: Risks Associated with Equipment Failures

Event	Likelihood	Consequence	Responses
33 kV & 66 kV Lines and Cables	Possible	Minor	<ul style="list-style-type: none"> • Regular inspections and maintain contacts with experienced faults contractors. • Provide alternative supply by ringed sub transmission or through the distribution network. • All new lines designed to AS/NZS 7000:2016

Event	Likelihood	Consequence	Responses
Power Transformer	Unlikely	Minor to Moderate	<ul style="list-style-type: none"> At dual power transformer sites, one unit can be removed from service due to fault or maintenance without interrupting supply. Continue to undertake annual DGA to allow early detection of failures. Relocate spare power transformer to site while damaged unit is repaired or replaced.
11 kV Switchboard	Unlikely	Moderate	<ul style="list-style-type: none"> Annual testing including PD¹ and IR². Replacement at end of life and continue to provide sectionalised boards. Able to reconfigure network to bypass each switchboard.
11 kV & 400 V Lines and Cables	Possible	Minor	<ul style="list-style-type: none"> Regular inspections and maintain contacts with experienced faults contractors. Provide alternative supply by meshed distribution network.
Batteries	Unlikely	Moderate	<ul style="list-style-type: none"> Continue monthly check and six-monthly testing. Dual battery banks at critical sites.
Circuit breaker Protection	Unlikely	Moderate	<ul style="list-style-type: none"> Continue regular operational checks. Engineer redundancy/backup into protection schemes. Regular protection reviews. Mal-operations investigated.
Circuit Breakers	Unlikely	Minor	<ul style="list-style-type: none"> Backup provided by upstream circuit breaker. Continue regular maintenance and testing.
SCADA RTU	Unlikely	Minor	<ul style="list-style-type: none"> Monitor response of each RTU at the master station and alarm if no response after five minutes. If failure then send faults contractor to restore, if critical events then roster a contractor onsite.
SCADA Master-station	Rare	Minor	<ul style="list-style-type: none"> Continue to operate as a Dual Redundant configuration, with four operator stations. This requires both Servers to fail before service is lost. Continue to have a support agreement with the software supplier and technical faults contractor to maintain the equipment.
Load Control	Unlikely	Moderate	<ul style="list-style-type: none"> Provide backup between EIL and TPCL ripple injection plants at Invercargill. Manually operate plant with test set if SCADA controller fails.
Fire	Rare	Major	<ul style="list-style-type: none"> Supply customers from neighbouring substations. Maintain fire alarms in buildings.

While the timing and location of equipment failures and network events are often unpredictable, the potential consequences and response requirements are well understood based on asset condition, network criticality, and historical performance.

To manage these risks, PowerNet operates a central control room staffed 24 hours a day, providing continuous monitoring and coordination of network operations. Engineering staff are available on standby to provide technical support and decision making assistance for network incidents.

PowerNet field staff and approved contractors provide onsite support for the repair of minor failures. For medium to large failures, or during major weather events, on-call PowerNet staff and contractors are mobilised in accordance with

¹ PD = Partial Discharge, indication of discharges occurring within insulation.

² IR = Infrared, detection of heat of equipment that highlights hot spots.

established emergency and storm response procedures.

Inspection outcomes, significant equipment failures, and notable network events including their impacts and responses are reported to EIL's General Manager through the monthly management report, with material matters escalated further in accordance with EIL's governance and reporting requirements.

The following additional network and operational performance risks were identified, and their treatment responses are described in the next table.

- **Animals** – could physically connect with overhead conductors (e.g., birds, possums) or cause conductor clashing (e.g., cattle against stays).
- **Third party accidental damage to network** – e.g., car versus pole, over-height loads breaking conductors. The presence of a pole may also increase the damage done to a car and its occupants if the driver veers off the road.

Table 30: Other Network and Operational Performance Risks

Event	Likelihood	Consequence	Responses
Animal	Possible	Minor	<ul style="list-style-type: none"> • Possum guards all poles • Cattle guards, bird spikes as required
Third party accidental	Possible	Major (Safety) Minor (Network)	<ul style="list-style-type: none"> • Design (assets, protection settings) to minimise electrical safety consequences of failure • Underground particularly vulnerable areas • Approval process for railway crossings, etc. • Regular inspections for sag etc. • Protection review and testing • Resource available to bypass and repair.

Health and Safety

Health and safety risks that were identified are listed below with treatment responses indicated in the table below.

- **Accidental public contact with live equipment** – whether through using tall equipment near overhead lines or through excavating near cables.
- **Step & touch** – faults/lightning strikes causing a voltage gradient, across surfaces accessible to the public, which can cause electric shock.
- **Arc flash** – potential for significant injury to staff from a fault on or near equipment they are using/working on.
- **Underground assets** – safety risks amplified by close proximities and confined space.
- **Staff error** – causing worksite safety risk.
- **Historical assets** – not meeting modern safety requirements.
- **Site security** – unauthorised persons approaching live components through unlocked gate.
- **Vehicles crashing into assets** – locate assets away from potential crash sites where feasible.

Table 31: Health and Safety Risks

Event	Likelihood	Consequence	Responses
Public Accidental Contact	Possible	Major	<ul style="list-style-type: none"> • Public awareness program – social media, radio, print, signage at high-risk areas • Offer cable location service and Before U Dig • Emergency services training • Relocate/underground near high-risk areas e.g., waterways where feasible • Include building proximity to lines in local body consent process • Audit new installations for correct mitigation, e.g., marker tape/ installation depth/Magslab for cable • Regular inspections of equipment to detect degraded protection of live parts

Event	Likelihood	Consequence	Responses
Step & Touch	Unlikely	Major	<ul style="list-style-type: none"> Adopt & follow EEA Guide to Power System Earthing Practice in compliance with Electricity (Safety) Regulations 2010
Arc Flash	Rare	Major	<ul style="list-style-type: none"> Install arc flash protection on new installations Mandate adequate PPE for switching operations De-energise installation before switching where PPE inadequate
Staff Error	Possible	Major	<ul style="list-style-type: none"> Standardised procedures Training Worksite audits Certification required for sub entry, live-line work, etc. Monitor incidents and investigate root causes
Historical Assets	Possible	Moderate to Major	<ul style="list-style-type: none"> Replace old components with new components meeting current standards: scheduled replacement or replacement on failure, check specifications and replace if risk significant
Site Security	Rare	Major	<ul style="list-style-type: none"> Monthly checks of restricted sites Alarms on underground sub hatches Standardised exit procedures in 3rd party building Above ground sub clearances to AS2067 s5 Design to avoid climbing aids etc.
Broken Neutral	Possible	Major	<ul style="list-style-type: none"> Detection through Smart Meter analysis

Environmental

The following environmental risks have been identified and their quantification and treatment responses are presented in the next tables.

High Impact Low Probability (HILP) Events

- **Earthquake** – no recent history of major damage. The November 2004 7.2 Richter scale quake 240 km south-west of Te Anau caused no damage to the network. The earthquakes in Christchurch demonstrated that large and unexpected events may occur, and these would have a significant impact on the network.
- **Tsunami** – may be triggered by large offshore earthquake.
- **Liquefaction** – post Christchurch’s 22 February 2011 6.3 magnitude earthquake, the hazard of liquefaction as a risk needs to be considered.

Table 32: High Impact Low Probability Risks

Event	Likelihood	Consequence	Responses
Earthquake (>8)	Rare	Extreme	<ul style="list-style-type: none"> Business Continuity Plan. Projects underway to investigate and improve survivability through large seismic events.
Earthquake (6 to 7)	Rare	Major	<ul style="list-style-type: none"> Specify so buildings and equipment will survive. Review existing buildings and equipment and reinforce if necessary.
Tsunami	Rare	Major	<ul style="list-style-type: none"> Review equipment in coastal areas and protect or reinforce as necessary.
Liquefaction	Rare	Moderate	<ul style="list-style-type: none"> Specify buildings and equipment foundations to minimise impact. Locate equipment outside of liquefaction zones.

Other Potential Environmental Risks

- Oil spills from transformers or oil circuit breakers
- Release of SF6 into the atmosphere

Table 33: Other Environmental Risks

Event	Likelihood	Consequence	Responses
Oil spill (zone sub)	Unlikely	Moderate	<ul style="list-style-type: none"> • Oil spill kits located at some substations for the faults contractor to use in event of oil leak or spill. • Most zone substations have oil bunding and regular checks that the separator system is functioning correctly. • Bunding is installed in the remaining substations as the opportunity arises. • Regular checks of tank condition
Oil spill (distribution transformer)	Possible	Minor	<ul style="list-style-type: none"> • Distribution transformers located away from waterways, etc. • Installations designed to protect against ground water accumulation
SF ₆ release	Unlikely	Minor	<ul style="list-style-type: none"> • SF6 storage and use recording and reporting • Procedures for correct handling.
Noise	Unlikely	Minor	<ul style="list-style-type: none"> • Designs incorporate noise mitigation • Acoustic testing at sub boundaries to verify designs • Adhere to RMA and district plans requirements
Electromagnetic fields	Unlikely	Minor	<ul style="list-style-type: none"> • Adhere to RMA and district plans requirements • Electromagnetic test at sub boundaries to demonstrate requirements met

Weather Related Risks

The following are potential weather-related risks, and their quantification and treatment responses are summarised in the table below.

- **Wind** – strong winds that either cause pole failures or blow debris into lines.
- **Snow** – impact can be by causing failure of lines or limiting access around the network.
- **Flood** – the experience of 1984 floods caused Environment Southland to install flood protection works, but it is still necessary to consider a scenario where similar water levels occur again. Flood prone areas have been identified and is indicated on the GIS system to assist in the placement of new infrastructure.

Table 34: Weather Related Risks

Event	Likelihood	Consequence	Responses
Wind	Possible	Moderate	<ul style="list-style-type: none"> • Impact is reduced by undergrounding of lines. • Design standard specifies wind loading resilience levels. • If damage occurs on lines this is remedied by repairing the failed equipment. • Inspections recognise asset criticality and resilience requirements.

Event	Likelihood	Consequence	Responses
Snow	Unlikely	Minor	<ul style="list-style-type: none"> • Impact is reduced by undergrounding of lines. • Design standard specifies snow loading resilience levels. • If damage occurs on lines this is remedied by repairing the failed equipment. • Inspections recognise asset criticality and resilience requirements. • If access is limited then external plant is hired to clear access or substitute.
Flood	Unlikely	Moderate	<ul style="list-style-type: none"> • Impact is reduced by undergrounding of lines. • Transformers and switchgear in high-risk areas to be mounted above the flood level. • Zone substations to be sited in areas of very low flood risk.

Resilience

Reliability and resilience are two important but distinct concepts when it comes to electricity distribution networks. They both pertain to the ability of the network to provide continuous and dependable electric service, but they address different aspects of the network’s performance and response to various challenges. The following section provides an explanation of the key differences between reliability and resilience:

Reliability refers to the consistency and predictability of electricity supply within the distribution network. It focuses on the network’s ability to deliver power to customers without frequent or extended interruptions. Key characteristics of reliability include:

- **Minimal Outages:** A reliable network experiences minimal power outages, and when outages do occur, they are typically short in duration.
- **Consistent Voltage and Frequency:** Electricity is delivered with stable voltage and frequency, ensuring that it meets the quality and quantity requirements for various electrical devices.
- **High Uptime:** A reliable grid has a high uptime, which means it operates without significant disruptions for extended periods, providing continuous service to customers.
- **Low Frequency of Failures:** Infrequent equipment failures, such as transformer or circuit breaker malfunctions, can be an indicator of a reliable network.

Resilience, on the other hand, focuses on the network’s ability to withstand and recover from various disruptions, including unexpected events and extreme conditions. Resilience addresses how quickly the network can withstand and/or bounce back from disruptions and continue to provide electricity. Key characteristics of resilience include:

- **Rapid Recovery:** A resilient network can quickly recover from outages, damage, or disturbances and restore power to affected areas in a timely manner.
- **Adaptability:** Resilience includes the ability to adapt to changing circumstances, whether it’s severe weather, equipment failures, or other unforeseen challenges.
- **Redundancy:** Resilient networks often incorporate redundancy in their design, allowing for alternative pathways and resources to deliver electricity in case of disruptions.
- **Robustness:** Resilience involves robust infrastructure and operational practices that can withstand extreme conditions, such as hurricanes, wildfires, or cyberattacks.

In summary, reliability primarily focuses on day-to-day prevention of power outages and the consistent delivery of electricity, emphasizing the quality and stability of service. Resilience, on the other hand, focuses on the network’s ability to withstand and/or recover and adapt to major events and disruptions, ensuring that power can be restored quickly after incidents or adverse events. Both reliability and resilience are critical for maintaining a dependable and secure electricity distribution network, and they often go hand-in-hand to provide a high level of service to customers, especially in the face of changing climate conditions and other external challenges.

A further resilience complication is introduced by decarbonization. The impact of power outages will increase significantly when consumers switch from using gas and petrol for transportation and heating to using electricity as the primary source of energy for homes. In contrast, by using their batteries to power essential home appliances, EVs can improve the resilience of their households.

The adoption of any new technology on the distribution network must first be thoroughly examined via the resilience lens. One must not allow the failure of communication systems, such as the hot water control system used for emergency load shedding, which is essential to maintaining network security and its recovery after an incident. The operation of these systems would be placed at risk if they transitioned to new technology that was reliant on cell phone networks, due to the inevitable overloading of cell phone networks that occurs following a major event, and the short battery backup times at cell towers. This vulnerability has been demonstrated by the Christchurch and Kaikoura earthquakes, and again during Cyclone Gabrielle. It is essential that telecommunications network operators, as providers of critical infrastructure, adjust their contingency plans to accommodate the long outages on the electrical supply network that can occur during major events, rather than continuing to optimise their systems for business-as-usual operation.

Climate Change

Climate change is reshaping our planet in profound ways, and one of its less discussed but critical consequences is the impact on electricity distribution networks. As global temperatures rise and extreme weather events become more frequent and severe, the reliability and resilience of our electrical network is being put to the test. The following section explores the effects of climate change on electricity distribution networks, the challenges it poses, and the strategies being adopted to mitigate these impacts.

Extreme Weather Events

One of the most immediate and tangible effects of climate change on electricity distribution networks is the increase in extreme weather events. Hurricanes, tornadoes, floods, and wildfires have become more common and destructive. These events can damage power lines, substations, and other critical infrastructure, leading to widespread power outages. The cost of repairing and upgrading the grid to withstand such extreme weather is a significant burden on utility companies and, ultimately, customers.

Temperature Extremes

Climate change also brings temperature extremes. Hotter summers and more severe winter storms can strain electricity distribution networks. In hot weather, the demand for electricity spikes due to increased use of air conditioning, potentially overloading the system. During cold spells, heating demands similarly increase. To meet these demands, grid operators must continually adjust generation and distribution, which can stress the infrastructure and raise operational costs.

Sea Level Rise

Sea level rise, driven by climate change, poses a unique threat to coastal electricity distribution networks. Many power stations, substations, and transmission lines are situated near the coastlines. As sea levels rise, these facilities are at greater risk of inundation and saltwater damage. Even minor flooding can disrupt electricity supply and result in costly repairs or upgrades to protect these assets from saltwater intrusion.

Renewable Energy Integration

While renewable energy sources like solar and wind power are essential for mitigating climate change, they also introduce new challenges for electricity distribution networks. These sources are intermittent and variable, making grid management more complex. Climate change can exacerbate this intermittency, affecting the consistency of renewable energy generation. This requires better grid infrastructure and energy storage systems to manage the fluctuations effectively.

Mitigation and Adaptation Strategies

To address the challenges posed by climate change, EIL employs various strategies:

- a. Infrastructure Resilience: Reinforcing and upgrading existing infrastructure to withstand extreme weather events.
- b. Improved Monitoring and Analytics: Investing in advanced monitoring and data analytics to predict and respond to weather-related disruptions and optimize network operations. To this effect the deployment of an OMS/ADMS system is under investigation and a Business Plan for implementation of a system will be presented to the EIL Board.
- c. Renewable Energy Integration: Expanding and modernizing the electricity distribution networks to accommodate the growing role of renewable energy sources, including smart grids and energy storage systems.
- d. Disaster Preparedness: Developing robust disaster recovery and preparedness plans to respond quickly to extreme weather events, minimizing service interruptions and recovery costs. To this end, CIMS has been deployed.
- e. Public Awareness: Raising awareness among customers about the importance of energy conservation and grid reliability and encouraging energy-efficient practices.

In Invercargill, the summers are cool; the winters are short and very cold; and it is wet, windy, and partly cloudy year-round. Over the course of the year, the temperature typically varies from 3°C to 18°C and is rarely below -1°C or above 23°C.

The warm season starts from 7 December to 19 March, with an average daily high temperature above 16°C. The hottest month of the year in Invercargill is January. The cool season starts from 30 May to 19 August, with an average daily high temperature below 11°C. The coldest month of the year in Invercargill is July. In Invercargill, the average percentage of the sky covered by clouds experiences mild seasonal variation over the course of the year. The clearest month of the year in Invercargill is February, during which on average the sky is clear, mostly clear, or partly cloudy 50% of the time.

Invercargill does not experience significant seasonal variation in the frequency of wet days. The month with the most days of rain alone in Invercargill is May. Rain falls throughout the year in Invercargill. The month with the least rain in Invercargill is August. The length of the day in Invercargill varies significantly over the course of the year. The wind experienced at any given location is highly dependent on local topography and other factors, and instantaneous wind speed and direction vary more widely than hourly averages. The average hourly wind speed in Invercargill experiences mild seasonal variation over the course of the year. Invercargill experiences an average of 109 days per year with wind gusts exceeding 61 km/hr. The windiest month of the year in Invercargill is October, with an average hourly wind speed of 21.0 kilometres per hour. The calmest month of the year in Invercargill is July, with an average hourly wind speed of 18.2 kilometres per hour.

To get the region ready for the effects of climate change, utilities and local authorities must coordinate their reaction. To effectively defend the network against these threats, PowerNet is updating its policies and guidelines. PowerNet rules and standards must be closely matched to a cohesive plan throughout, which will necessitate more collaboration with local authorities to comprehend their defence measures and impact revisions to the District Plan. Climate change is having a profound and multi-faceted impact on electricity distribution networks. Extreme weather events, temperature fluctuations, sea level rise, and the integration of renewable energy sources are all challenging the resilience and reliability of the network. Utility companies and policymakers must work together to implement mitigation and adaptation strategies to ensure a sustainable and secure energy future. As we confront the effects of climate change, our electricity distribution networks must evolve to meet the changing demands of a warming planet.

4.5 System Risks

Existing risks to the EIL electricity system are associated with 33kV oil-filled cables and oil-filled ring main units (RMUs). It is expected that the majority of the “Unspecified Projects” budget in years 6 to 10 of forecast CAPEX will be devoted to RMU and cable replacements.

33kV Oil Filled Cables

There is a potential systemic vulnerability in the 33kV oil filled cables which supply Spey St and Southern substations. Similar cables on other distribution companies’ networks are showing signs of insulation damage due to weakness in the cable joints allowing movement of the cores with thermodynamic expansion and contraction. The associated reliability risk has been mitigated through ensuring that all oil-filled cables on the network have an alternate supply option through an XLPE (solid insulation) cable. In addition, the UK Regulator’s (Ofgem) DNO Common Network Asset Indices Methodology (CNAIM) was applied to these cables to determine their probability of Failure. A sensitivity analysis was done to determine the sensitivity of the model to the initial health score. Currently the cables are rated at health level 4 (NZ4), but the graphs also show the outcomes should the cables be at health level 3 (NZ3). The following graph shows the outcome of this analysis.

Figure 31: Oil filled cables health score

33kV Oil filled cables - Ofgem Model - Health over time
- UK scoring system (0-10)




Figure 32: EEA Model using Ofgem criteria





Figure 33: Oil filled cable Probability of failure over time



The graphs show that the cables are still well within their operational life limits but that the Probability of Failure starts to increase from about 2032. Based on this analysis, provision should be made in future AMPs to replace these cables starting around 2038.

Oil Filled RMUs

Many oil-filled RMUs have operating restrictions in place to mitigate safety risks due to arc flashes. Short-term solutions were developed for some models of RMU, which allow safe operation without the inconvenience and reliability impact of operating restrictions. Where these solutions are not available or not practical, operation of these RMUs has been suspended. This mitigates the risk to field staff operators, however, in-situ risk to the public remains and the network has reduced capacity to segment resulting in wider outage areas. Longer term management of these issues is likely to require early replacement of many RMUs.

Some models of RMUs have exhibited faster than usual corrosion which is likely to adversely affect the service life of

the assets. Repairs will be carried out where economic and practical to do so, but it is expected that many of these assets will need to be replaced ahead of their nominal life, causing their replacement to overlap with the older but sturdier models that preceded them. It is expected that the majority of the “Unspecified Projects” budget in years 6 to 10 of forecast CAPEX will be devoted to RMU and cable replacements.

EIL has experienced water ingress issues with early ABB SD type RMUs that utilise high voltage busbar insulation tape (HVBT) in the bus couplings. All such RMUs had their bus coupling boxes filled with Guroflex insulating compound that succeeded the original HVBT bus coupling kit to prevent water ingress and consequential failures.

Other Systemic Issues

The condition and operation of circuit breakers are being monitored as:

- Over time, circuit breakers can experience mechanical or electrical failures, causing them not to trip or close as intended. This can compromise system protection, potentially leading to larger outages or damage.
- A second type of monitoring is for moisture ingress and corrosion.

Infrared- and dielectric discharge monitoring and tracking are the main tools used in this regard.

4.6 Asset Criticality

Good practice asset management decisions should not be solely based upon asset health either from condition or non-condition factors. Good practice decision making should also consider the operating context and how failure can affect outcomes such as safety and environment, customer service levels, and lifecycle costs.

The EEA Asset Criticality Guide defines Criticality as “A measure reflecting the relative seriousness of the Credible Consequences of Failure”. The EEA guidelines are not yet fully operationalised within EIL. We do however take the location of assets into account when we make asset management decisions.

The plausible consequence of an asset failure next to a school or public facility is the same as when the same asset would be installed somewhere in a paddock. However, the credible consequence of the asset failure in the first location is much higher than the credible consequence of the asset failing in the second location, so more intensive risk mitigation measures will be applied to the first asset.

EILs stated intention is to base all asset related decisions on risk (of which criticality is one component). To give effect to this intention, various systems based on the UK Regulator’s (Ofgem) DNO Common Network Asset Indices Methodology (CNAIM) are being investigated. This a comprehensive and common framework of definitions, principles, and calculation methodologies, adopted across all GB Distribution Network Operators, for the assessment, forecasting and regulatory reporting of Asset Risk. PowerNet has developed a spreadsheet-based system to understand the basic principles being utilised in the CNAIM. This has been applied to distribution transformers, ring main units, switchgear, and air-break switches to rank these items according to their Probability of Failure. Location criticality (access to the public) was applied over the Probabilities of Failure to determine the assets that will be replaced.

The EEA Asset Criticality Guide draws heavily on the principles embodied in this document.

4.7 Price Elasticity of Demand

Price increases over the DPP period will generally be higher than what customers are used to. There are no specific and up-to-date studies that indicate what the price elasticity for the demand for electricity may be from customers. There are a number of possible customer responses to these price increases:

- Customers just continue to use electricity as in the past as they regard electricity as an essential service
- Customers initially try to save electricity but after a time return to current usage patterns. This leads to an initial dip in peak demand but returning to the current state after some months
- More customers move on to time of use tariffs, causing the flattening of peak demand on the network and a shift to afterhours energy consumption
- Customers implement energy saving measures leading to an overall reduction in energy usage and peak demand
- The payback period of distributed generation, mainly solar panels and batteries, become shorter and more people move to these systems, reducing demand. This trend is reinforced by the continuing drop in price of distributed generation systems.

The impact on the load of the price increases will be closely monitored. From a network perspective it is envisaged that overall energy flowing through the MV networks may decrease, but that the LV network may become congested in certain areas.



5 Service Levels

SECTION CONTENTS

The Langlands, Invercargill

5	Service Levels	88
5.1	Customer Oriented Service Levels	88
5.2	Efficiency Levels	92
5.3	Service Level Justification	93
5.4	Service Level Target Setting	93

5 SERVICE LEVELS

This section details how well EIL is meeting its service level objectives and what trade-offs exist between differing stakeholders. Considerations include: the desire for Return on Investment (ROI) versus desire for cost effective and reliable services while allowing for cost recovery including a reasonable Return on Investment (ROI); prioritising safety while accepting residual risk; and balancing rapid supply restoration with regulatory and procedural compliance obligations.

Safety is our top priority and is a primary consideration in the AMP. However, safety is and has always been a key consideration in network design and the residual risk that can be additionally addressed through effective management of our assets is extremely low.

EIL sets its broad range of service levels according to the safety, viability, quality, compliance and price objectives that are most important to stakeholders.

5.1 Customer Oriented Service Levels

Customer surveys and how we use them to set service levels are described in the following section.

Customer Surveys

Annual customer engagement surveys measure customer perceptions around a range of service levels. This involves contacting a large sample of customers by telephone and asking a predetermined set of questions. The Curiosity Company independently surveys EIL customers and collates the results into a customer satisfaction report for presentation. The Curiosity Company was also engaged to conduct interviews with major customers to help understand service level requirements and satisfaction with current service levels.

EIL keeps statistics on complaints to measure how often customers experience supply quality issues. Issues are dealt with at the time of complaint, but these statistics give an indication of how supply quality and the response services are trending over time. In the last two years, EIL have received 8 formal justified complaints, with a small percentage of them due to voltage issues. The results of these surveys are monitored, and any comments received are reviewed and responded to as appropriate.

Survey results show that customers are mostly happy with high ratings for the current service level performance in areas such as caring for customers, being safety conscious and efficient in-service response. The biggest area of concern was the discrepancies between the communicated planned outage and restoration times and the actual outcomes. This is being improved through the implementation of a more efficient call centre system and the planned implementation of a Customer Relationship Management System.

Service levels such as a limited number of interruptions are most valued by customers. These strongly depend on network assets and require financial expenditure solutions (as opposed to process solutions), with the following challenges.

- Limited substitutability between service levels – for example, customers prefer EIL to keep the power on rather than answer the phone quickly.
- Averaging effect - all customers connected to an asset (or chain of assets) will receive more or less the same level of service.
- Free-rider effect – some customers would still receive a higher level of service due to their common connection, for example, Invercargill and North Makarewa GXPs are more secure than their size would normally deserve based on the reliability required by the New Zealand Aluminium Smelter at Tiwai point.

Primary Customer Service Levels

As described above, customers value continuity and restoration most, therefore, these are EIL's primary service levels. EIL uses two internationally accepted indices to measure performance for these service levels.

- SAIFI (system average interruption frequency index) is a measure of how many system interruptions occur per year per customer connected to the network.
- SAIDI (system average interruption duration index) is a measure of how many system minutes of supply are interrupted per year per customer connected to the network.

These indices align with the Commerce Commission's requirements in its regulation of local Electricity Distribution Business (EDBs). EIL's projections for these measures over the next ten-year period ending 31 March 2036 are shown in the table below.

These projections are averages only, because extreme weather events can cause volatility in reliability measures.

EIL’s medium-term aim is to reduce this average, although given that the EIL network is mostly underground, weather has less of an effect.

The treatment of outages that are needed for planned work but where the customer notification timeframes could not be adhered to or where the planned work had to be cancelled is unclear. We have adopted an approach whereby these outages are classified as unplanned outages – cause unknown. This has caused an increase in this reliability category.

In addition to reporting SAIFI and SAIDI at a network level, EIL monitors interruption causes by asset class (for example, cables, transformers, switchgear, protection systems). This allows EIL to better understand the relationship between reliability performance, asset condition, and underlying failure modes.

Incorporating asset class failure data into service level planning strengthens the link between reliability outcomes and asset risk profiles. Where specific asset classes contribute disproportionately to SAIFI or SAIDI, this informs prioritisation of inspection, maintenance, renewal and replacement programmes.

This approach ensures that projected improvements in service levels are supported by targeted investment strategies aligned with asset condition, criticality and risk exposure.

Table 35: Reliability Projections

Measure	Class	2025/26	2026/27	2027/28	2028/29	---	2034/35	2035/36
SAIDI	B (Planned)	23.9	28.0	28.0	28.0		28.0	28.0
	C (Unplanned)	34.7	38.2	37.8	37.4		35.2	34.9
	Total	58.6	66.2	65.8	65.4		63.2	62.9
SAIFI	B (Planned)	0.084	0.110	0.110	0.110		0.110	0.110
	C (Unplanned)	0.608	0.680	0.674	0.668		0.635	0.630
	Total	0.692	0.79	0.784	0.778		0.745	0.74

Note: All figures in this table assume that there will not be any normalisation event days as these are difficult to predict. Historically normalisation varies between 0 and 25% of annual SAIDI.

Table 36: Reliability History

Measure	Class	2019/20	2020/21	2021/22	2022/23	2023/24	2024/25
SAIDI	B (Planned)	13.10	13.77	28.18	27.75	23.97	25.75
	C (Unplanned)	65.40	35.90	77.06	35.74	17.07	21.00
	Total	78.5	49.67	105.24	63.49	41.04	46.75
SAIFI	B (Planned)	0.050	0.080	0.110	0.081	0.093	0.092
	C (Unplanned)	1.250	0.680	1.050	0.491	0.328	0.347
	Total	1.30	0.76	1.16	0.572	0.421	0.439

Note: All figures in this table are normalised.

The frequency of faults and estimated restoration levels for significant network areas are summarised in the following table.

Table 37: Expected fault frequency and restoration time

General location	Frequency of faults	Estimated restoration ¹
Invercargill CBD		
33 kV Fault	One every 15 years	1 min
11kV Fault	2 every year	30 min
Invercargill other than CBD		
33 kV Fault	One every 7 years	15 min
11kV Fault	5 every year	45 min
Bluff		
33 kV Fault	3 every year	1 min
11kV Fault	6 every year	75 min

Due to elevated levels of inflation in recent years in New Zealand and forecast price increases under DPP4, we have asked EIL customers about their willingness to pay extra in line charges to retain the same level of reliability of supply. EIL customers were willing to incur an increase of 3.85% of their line charge fees on average to maintain the same reliability of power supply.

Table 38: Reliability Thresholds – DPP4

Index	Class	Target	Collar	Cap	Limit	Boundary	Extreme Event	Incentive Rate (per SAIDI)
SAIDI	C (Unplanned)	16.16	0	27.15	27.15	5.00	120	\$ 4,909
	B (Planned)	18.05	0	25.19	125.94 (5-year)	-	-	\$2,455
SAIFI	C (Unplanned)	-	-	-	0.6608	0.09	-	-
	B (Planned)	-	-	-	0.5702 (5-year)	-	-	-

Boundary values	Boundary values represent the threshold for normalising major events. If the sum of SAIDI or SAIFI for unplanned interruptions in any 24-hour rolling period (commencing in any half-hour period) exceeds the respective boundary, the contribution to the overall annual SAIDI or SAIFI is capped at 1/48th of that boundary value (for each half hour of the event).
Limit	Limit values are the values set by the Commerce Commission for planned and unplanned SAIDI and SAIFI which an EDB shall not exceed. Planned values are set to apply over the five year regulatory period while unplanned values are the annual limits measured in every regulatory year.

Secondary Customer Service Levels

Secondary service levels have lower customer satisfaction rankings than the primary attributes of supply continuity and restoration. These attributes include how satisfied customers are with communication regarding tree trimming, connections or faults, the time taken to respond to and remedy justified voltage complaints and the amount of notice before planned shutdowns. The following table sets out targets for these service levels for the next ten years. Some of these service levels are process-driven which has the following implications.

- Solutions tend to be cheaper than fixed asset solutions. For example, staff could work a few hours overtime to process a back log of new connection applications, an over-loaded phone system could be diverted, or the shutdown notification process could be improved.
- Improved service levels could be provided exclusively to customers who are willing to pay more. This contrasts with fixed asset solutions that will equally benefit all customers connected to an asset regardless of whether they pay.

¹ Except if supplied directly off the faulty section of line or cable.

Table 39: Secondary Service Level Projections

Attribute	Measure	2026/27	2027/28	2036/37
Planned Outages	Provide sufficient information. {CES}	>80%	>80%	>80%
	Satisfaction regarding amount of notice. {CES}	>80%	>80%	>80%
	Acceptance of one planned outage every two years lasting four hours on average. {CES}	>80%	>80%	>80%
Unplanned Outages (Faults)	No impact or minor impact of last unplanned outage. {CES}	>50%	>50%	>50%
	Information supplied was satisfactory. {CES}	>80%	>80%	>80%
	PowerNet first choice to contact for faults. {CES}	>35%	>35%	>50%
Supply Quality	Number of customers who have made supply quality complaints {IK}	<6	<6	<6
	Number of customers having justified supply quality complaints {IK}	<3	<3	<3

{ } indicates information source; CES = Customer Engagement Survey using independent consultant to undertake phone survey, IK = Internal KPIs.

Other Service Levels

In addition to the primary and secondary service levels described in the sections above, there are several other services that benefit stakeholders. These include safety, amenity value, absence of electrical interference, and performance data as presented in the following table. Many of these service levels are imposed on EIL by statute and are necessary for the proper functioning of a safe and orderly community.

Table 40: Other Service Levels

Service Level	Description
Safety	<p>Various legal requirements require EIL's assets (and customer's plant) to be compliant to safety standards which include earthing exposed metal and maintaining specified line clearances from trees and from the ground:</p> <ul style="list-style-type: none"> • Health and Safety at Work Act 2015. • Electricity (Safety) Regulations 2010 • Electricity (Hazards from Trees) Regulations 2003. • Maintaining safe clearances from live conductors (NZECP34 or AS2067). • EEA Guide to Power System Earthing Practice 2019 as a means of compliance with the Electricity (Safety) Regulations.
Amenity Value	<p>EIL's is limited by several Acts and other requirements in the adoption of overhead lines.</p> <ul style="list-style-type: none"> • The Resource Management Act 1991. • The Operative District Plans. • Relevant parts of the Operative Regional Plan. • Land Transport requirements. • Civil Aviation requirements. • Land Transfer Act 1952 (easements)
Industry Performance	<p>The Commerce Act 1986 empowers the Commerce Commission to require EIL to compile and disclose prescribed information to specified standards.</p>
Electrical Interference	<p>Under certain operational conditions EIL's assets can interfere with other utilities such as phone wires and railway signalling or with the correct operation of customer's plant or EIL's own equipment. The following publications are used to prevent issues from interference:</p> <ul style="list-style-type: none"> • Harmonic levels (NZECP 36:1993). • Single wire earth return limitations (EEA High Voltage SWER Systems Guide). • NZCCPTS: coordination of power and telecommunications (several guides).

Planned outage information are conveyed to customers through the retailers as well as the PowerNet website and social media. Retailers are informed of planned outages 20 days in advance. Key customers and dependent customers are contacted directly by telephone. Key customers are also directly informed where the networks are operating under reduced security.

Communications about new or altered connections are generally done telephonically and confirmed through emails or letters.

Future communication enhancements under consideration include:

- Real-time outage mapping via digital platforms.
- Automated SMS and/or email notifications for outage updates.
- Improved mobile accessibility of outage information.

This initiative is intended to provide improved visibility of outage locations, status updates, and estimated restoration times to customers and stakeholders.

5.2 Efficiency Levels

EIL also sets financial and energy efficiency targets. The company is required to disclose a range of internal performance and efficiency measures as required by the Commerce Commission’s Information Disclosure Determination. The targets that EIL sets are based on measures that are included in those disclosures, which means that EIL’s performance on those measures is externally audited and can be readily benchmarked against other EDBs.

Financial Efficiency

Financial efficiency falls into two groups, namely:

- Network OPEX metrics; and
- Non-Network OPEX metrics.

For effective benchmarking, OPEX metrics need to be at least account for the relative size of other EDBs (and ideally also other characteristics that affect cost). A single fair measure of the “size” of an EDB is not available, therefore EIL adopted the following measures from Information Disclosure Schedule 1 to unitise financial efficiency targets.

- Interconnection Points (ICPs) as at year end.
- Total km network length.
- Total MVA of EDB-owned distribution transformer capacity.

EIL has six financial efficiency targets, as shown in the following table.

Table 41: Financial Efficiency Targets

Measure	Network			Non-Network		
	OPEX/ICP	OPEX/km	OPEX/MVA	OPEX/ICP	OPEX/km	OPEX/MVA
2026/27	\$132	\$3,604	\$14,963	\$228	\$6,217	\$25,809
2027/28	\$132	\$3,604	\$14,963	\$230	\$6,270	\$26,027
2028/29	\$132	\$3,604	\$14,963	\$228	\$6,217	\$25,809
2029/30	\$132	\$3,604	\$14,963	\$228	\$6,217	\$25,809
2030/31	\$132	\$3,604	\$14,963	\$228	\$6,217	\$25,809
2031/32	\$132	\$3,604	\$14,963	\$228	\$6,217	\$25,809
2032/33	\$132	\$3,604	\$14,963	\$228	\$6,217	\$25,809
2033/34	\$132	\$3,604	\$14,963	\$228	\$6,217	\$25,809
2034/35	\$132	\$3,604	\$14,963	\$228	\$6,217	\$25,809
2035/36	\$132	\$3,604	\$14,963	\$228	\$6,217	\$25,809

* Dollar values as constant 2026 dollars.

Energy Efficiency

Energy delivery efficiency measures are the following.

- **Load factor** – [kWh entering EIL’s network during the year] / [(max demand for the year) x [hours in the year]].
- **Loss ratio** – [kWh lost in EIL’s network during the year] / [kWh entering EIL’s network during the year].
- **Capacity utilisation** – [max demand for the year] / [installed transformer capacity].

Projected energy efficiency forecasts and targets are shown in the following table. Slight improvements are targeted but changes in peak management requirements impact on the load factor. The loss ratio is wide-ranging due to reliance on annual sales quantities from retailers. Retailers do not read customers’ meters at midnight on 31 December, and therefore an estimation methodology is utilised.

Table 42: Energy Efficiency Targets

Measure	2026/27	2027/28	2028/29	...	2035/36
Load Factor	46%	46%	45%	...	43%
Loss Ratio	4.3%	4.1%	4.0%	...	3.3%
Capacity Utilisation	41%	41%	41%	...	42%

5.3 Service Level Justification

The reasoning behind the service levels presented in this AMP is:

- Customers have indicated preference for paying the same line charges for the same service levels.
- Improvements provide positive net benefits within revenue capability.
- Customers make specific requests to receive a different mix of reliability and pricing from what would otherwise be available. For example, customer contributions fund uneconomic portions of upgrade or alteration expenses to achieve a desired service level for an individual or group of customers.
- There are constraints on what can be achieved due to skilled labour and technical shortages.
- External agencies impose service levels either directly or indirectly where an unrelated condition or restriction manifests as a service level – for example, a requirement to place all new lines underground, or a requirement to increase clearances, or cost recovery allowances do not permit renewal rates.
- Customer expectations of service levels set by historic investment decisions and resultant network performance.

Over the last five years customer surveys indicated that preferences for price and service levels are reasonably constant and a general requirement for increased supply reliability is absent. However, the following challenges exist.

- The service level called “Safety” is expected to continually improve as public perceptions and regulations are updated to decrease industry related risk.
- EIL’s cold storage customers require higher levels of continuity and restoration with interruptions to cooling and chilling being less acceptable as food and drink processing, storage and handling are subject to increasing scrutiny by overseas markets.
- Economic downturn may increase the incidence of theft of materials and energy.

5.4 Service Level Target Setting

Service level targets are based on historical trends and benchmarked against other local distribution networks.

Historical Trends

In setting service level targets, we consider the recent history of service level measures. These measures are slow to change and not easy to influence. We determine trends from historic results and then project forward to forecast future service levels. Projections are adjusted to incorporate CAPEX and OPEX initiatives and other issues that might affect service levels.

Results from the last five years for reliability and energy efficiency targets are listed below, followed by a table that summarises customer satisfaction outcomes from past surveys.

Table 43: Reliability and Energy Efficiency History

Measure	2019/20	2020/21	2021/22	2022/23	2023/24	2024/25
SAIDI	47.2	49.67	105.24	63.50	41.05	46.75
SAIFI	0.92	0.76	1.15	0.57	0.42	0.43
Load Factor	48%	47%	47%	42%	50%	47%
Loss Ratio	5.7%	4.8%	3.2%	4.6%	4.7%	4.7%
Capacity Utilisation	42.0%	41.4%	40.2%	45.5%	38.12%	41.25%
Network OPEX / ICP	\$119	\$89	\$105	\$118	\$104	\$110
Network OPEX / km	\$3,145	\$2,341	\$2,763	\$3131	\$2,753	\$2,918
Network OPEX / MVA	\$13,785	\$10,288	\$11,709	\$13,332	\$11,581	\$12,266
Non-Network OPEX / ICP	\$117	\$183	\$189	\$200	\$230	\$255
Non-Network OPEX / km	\$4,671	\$4,795	\$4,972	\$5,275	\$6,120	\$6,783
Non-Network OPEX / MVA	\$20,475	\$21,074	\$21,071	\$22,467	\$25,742	28,516

DPP3 encouraged EDBs to move towards doing more planned work and in so doing to change the ratio between planned and unplanned work and this philosophy is continued in DPP4. This is done by setting planned work limits and incentivising planned work by allowing deductions on SAIDI minutes for notified planned interruptions.

Table 44: Customer Satisfaction History

Attribute	Measure	2019 /20	2020 /21	2021 /22	2022 /23	2023 /24	2024 /25
Planned Outages	Provided sufficient information {CES}	93%	96%	92%	88%	96%	96%
	Satisfaction regarding amount of notice {CES}	96%	95%	91%	91%	91%	96%
	Acceptance of one planned outage every two years {CES}	31%	43%	98%	96%	95%	94%
	Acceptance of planned outages lasting four hours on average {CES}	-	-	85%	85%	86%	87%
	Acceptance of one planned outage every two years lasting four hours on average {CES}***	-	-	84%	84%	84%	84%
Unplanned Outages (Faults)	Power restored in a reasonable amount of time {CES}*	-	63%	78%	73%	58%	66%
	No impact or minor impact of last unplanned outage {CES}***	-	57%	46%	56%	54%	62%
	Information supplied was satisfactory {CES}*	-	72%	55%	62%	75%	82%
	PowerNet first choice to contact for faults {CES}**	-	21%	17%	40%	48%	55%

Attribute	Measure	2019 /20	2020 /21	2021 /22	2022 /23	2023 /24	2024 /25
Voltage Complaints	Number of customers who have made supply quality complaints {IK}	11	7	13	0	1	3
	Number of customers having justified supply quality complaints {IK}	3	4	8	0	8	0

{ } indicates information source: CES = Customer engagement survey using independent consultant to undertake phone survey, IK = Internal KPIs

* As these questions are limited to customers experiencing an unplanned outage in the last six months, the sample size is very small for a network as reliable as EIL. This can lead to substantial year-to-year fluctuations.

**Noting that each year a proportion of responses (12% in 2022) simply state that the customer would not call anyone.

***Survey questions were changed from the 2017/18 surveys and onwards. The modified questions provided a wider range of options compared to previous surveys, which has influenced the response.

Benchmarking

Benchmarking against other local distribution networks helps to identify potential improvements in the current service levels that EIL offers. Comparisons with Nelson Electricity and, to a lesser extent, Orion and Wellington Electricity are useful as these networks are the most similar to EIL in terms of customer density and types of assets. Several indicators are benchmarked against other EDBs' performance in Section 10.

6

Asset Management Strategy

SECTION CONTENTS

Civic Theatre, Invercargill

6	Asset Management Strategy	98
6.1	Lifecycle Stages.....	98
6.2	Lifecycle Support.....	101
6.3	Lifecycle Management and Growth	102
6.4	Fleet Plans.....	102

6 ASSET MANAGEMENT STRATEGY


EIL’s Asset Management Strategy is developed within PowerNet’s asset management model and focuses on a lifecycle management approach. The strategy is structured to address the main activities and challenges faced in each lifecycle stage as well as the support processes. Our strategy identifies clear objectives for each activity and recommends initiatives to achieve those objectives. In each case, responsibilities are defined, and realistic timeframes are suggested.

The defined strategic objectives and initiatives are aligned with the relevant stakeholder’ business plans. These are aimed at achieving continuous business improvements through balancing risk, performance, and cost.

The following chart shows the various asset lifecycle stages and support processes that cut across the entire value lifecycle.

In 2023, EIL (through PowerNet) became TELARC-certified as compliant with ISO 55001 – the international standard for Asset Management Systems.

Figure 34: Lifecycle Model for Asset Management



6.1 Lifecycle Stages

The asset lifecycle stages of our asset management approach – planning, designing, acquiring, commissioning, operating and maintaining, and retiring – are described in the following sections.

Planning – Network Development

The function of network planning ensures that the optimal expansion of the power system can sustain demand. Expansion needs to occur at the right time to balance optimal investment of capital, but at the same time avoid network overloading. The power network needs to continuously meet power quality, reliability, statutory, safety, security of supply, resilience and environmental requirements.

Our planning philosophy is to implement the least lifecycle cost option. To do this, we make decisions that balance CAPEX and OPEX spending. There should be a formal correlation between capital planning (CAPEX) and maintenance planning (OPEX) and the investment in assets should produce the expected network reliability and performance.

Our key objectives for network planning are:

- Asset planning and management are the foundation of EIL's business plan and enable the integration of CAPEX and OPEX budgets.
- Planning for network expansion, strengthening and/or refurbishment is based on whole life cost.
- Planning incorporates the connection of new customers.
- Flexibility services (non-asset solutions) take priority.
- High Impact Low Probability (HILP) event and climate change risks are mitigated to be as low as reasonably practicable (ALARP).
- Capital projects are prioritized based on safety, regulatory compliance, risk, and whole of economic value, consistent with the asset management objectives outlined in section 2.

Project prioritization is undertaken in direct alignment with the Asset Management objectives in section 2. Investment decisions are structured to avoid any material deterioration in network condition, reliability, and performance, while maintaining safety and regulatory compliance. Risk assessment, asset criticality, condition information, and lifecycle cost analysis are applied to formally integrate CAPEX and OPEX planning. This ensures assets are replaced or maintained at their risk adjusted economic end of life and that the network continues to meet required service levels and stakeholder expectations.

Plant or Network Design

The design lifecycle stage includes the design and specification of plant, as well as the design and engineering of the power network. There are several standards and guidelines available that cover the design and engineering of the power network. PowerNet creates and maintains many accessible standards, specifications and guidelines for power as well as control plant. Where an internal standard is not available, PowerCo's standards are used.

Standards and specifications are often developed around technical, safety, environmental and statutory requirements without considering lifecycle cost, maintenance, risk or reliability necessities. Spares distribution and asset disposal arrangements are often also not considered during the design and/or specification of a specific asset. This is contrary to our Asset Management Policy which focuses on the full life cycle of assets.

To address this EIL's key objectives for the Design lifecycle stage are the following:

- Efforts are focused on improving asset life and performance while minimising cost and risk;
- Equipment standards and designs support network reliability and performance at lowest lifecycle cost and risk;
- Safety in Design practices are incorporated into every design;
- Sustainability is incorporated into all design activities by allowing for future generations where economically possible;
- Potential impact of climate change is considered in designs; and
- Flexibility services are incorporated into designs.

Acquiring

The acquiring stage includes the procurement of new plant and equipment based on specifications developed during the design stage. It also includes obtaining construction services from contractors. This is followed by activities such as project management, contract management, construction and/or installation of the asset and quality assurance. This lifecycle stage is supported by PowerNet's commercial services and supply chain processes.

The physical construction and installation of assets are critical activities that influence the life expectation and lifecycle cost of a specific asset. Incorrect construction and installations can lead to premature equipment failures. This makes quality assurance in terms of both equipment and installation of vital importance.

Our key objectives for the acquire lifecycle stage are:

- Procurement policies support lifecycle costing and risk management.
- Construction and installation quality will not compromise the asset life.
- Consider sustainability and the potential impact on climate change in equipment selection decisions.
- Flexibility services are incorporated into designs.

Commissioning

The commissioning phase starts when the contractor has completed the implementation of an asset or plant (based on the design stage) and indicates that the asset or system is ready for utilisation. Final testing of the installation needs to be carried out, the as-built data be recorded/captured and the maintenance and operating staff needs to be instructed in the requirements of the new plant. The phase ends when the new asset is put into commercial operation.

Our key objectives for the commissioning lifecycle stage are:

- The quality of networks and assets handed over for operation is to specification.
- As-built documentation and records are properly generated and managed.
- Maintenance requirements are well understood, maintenance staff have been trained and the required manuals, tools and equipment are available.

Operate & Maintain

During the operate and maintain lifecycle stage, physical assets are expected to perform their designed function at (or above) the specified performance and reliability parameters. Operating and maintenance practices greatly influence the performance, reliability and life expectancy of the asset. Good management of assets during this lifecycle phase will extend life expectancy, reduce overall lifecycle costs and ensure availability and reliability. When there is collaboration between asset operators and maintainers, the best performance (at the optimum cost) of the asset will be experienced. Deterioration and poor performance are often the result if either operations or maintenance teams work in isolation of each other.

The following are EIL's key objectives for the Operate & Maintains lifecycle stage.

- Assets are operated and maintained in a manner that minimises system lifecycle cost, with consideration of risk.
- Electricity delivery networks and associated electrical systems are maintained so that the requirements of customers, internal stakeholders and legal authorities are met at minimum lifecycle cost.
- Defect and liability periods as well as equipment guarantees are documented and managed.
- Operating practices mitigate potential risk from network equipment.
- Maintenance drivers are the following.
 - Support continued reliable service to customers.
 - Economic viability when compared to replacement.
 - Continued safety.
 - Operational efficiency.
 - Rate and extent of deterioration.
- Criticality.
- Probability of failure.

Given the resource constraints in terms of skills and money, maintenance for new or relatively new equipment is prioritised, but older equipment is not completely neglected. This approach has been shown to deliver the best long-term value to organisations.

Retire

This lifecycle stage includes the following potential activities:

- **Replacement** – The planned replacement of assets for reasons other than system expansion – for example, degraded performance experienced at the end of its useful life.
- **Retirement** – The removal of equipment from service due to system expansion, but retention of the asset for strategic reasons such as spares.
- **Disposal** – The complete removal and disposal of an asset when it is no longer required.

Our key objectives for the retire cycle stage are:

- Asset replacement decisions are based on reliability, operating cost, condition and predicted end-of-life; and
- Asset disposal will create minimal long-term safety risks or risks to the environment.

6.2 Lifecycle Support

Lifecycle support activities include management of asset risks, asset information, human resources and financial resources.

Management of Asset Risks

Risk Management can be defined as:

“The continuous, proactive and systematic process to understand, manage and communicate risk from an organisation-wide perspective. It is about making strategic decisions that contribute to the achievement of an organisation’s overall corporate objectives. Risk refers to the uncertainty that surrounds future events and outcomes. It is the expression of likelihood and impact of an event with the potential to influence the achievement of an organisation’s objectives.”

Risk is the product of “consequence” and “probability”. Consequence refers to the potential impact of a failure incident on the business. In the context of asset management, this relates to the criticality (its importance to the business) of each asset. Risk is not limited to a single stage in the asset lifecycle, but cuts across all the phases. Risk management and economic optimisation is applied to all relevant business activities and is the fully inclusive basis for prioritising all activities, including engineering projects and investments.

Management of Asset Information

EIL is working with PowerNet to improve the security and information held on its assets.

The improved quality of data enhances asset management decision-making and assists in extracting the maximum value from assets.

The key objectives for asset information management are the following.

- Asset management information systems shall link asset history, technical design, performance and risk information, as well as financial data of individual assets.
- Data and information shall be consistent across all systems.
- Asset information maturity shall be regularly assessed across major asset classes using a structured framework to identify gaps and prioritise improvement initiatives.
- A phased uplift programme shall be implemented to progressively improve data quality, completeness and integration across all critical asset classes.
- Critical asset classes include zone substations, overhead and underground network assets, protection and control systems, distribution transformers, and enabling operational systems such as SCADA and GIS.

Management of Human Resources

Effective asset management requires that personnel responsible for the design, construction, operation and management of assets have appropriate education, training and/or experience. Procedures should be in place to ensure that employees or third parties such as contractors are aware of the following.

- The importance of complying with the requirements of the asset management system, including the asset management policy, processes and procedures.
- Their roles and responsibilities in achieving compliance including emergency preparedness and response requirements.
- The potential consequences of deviating from stipulated operating procedures; and
- Long-term asset management training requirements are identified and adequately planned for.

The electricity supply industry is experiencing shortages in critical skills. These shortages are driven by the significant global development of electricity networks driven by decarbonisation and artificial intelligence driven innovation. The pipeline for technical skill development is inadequate, and it remains a challenge to obtain and retain appropriately skilled resources. This applies to all categories and levels of staff, but particularly to technical and field staff.

Our key objective for the management of human resources is that: *the necessary resources and skills to plan, acquire, operate and maintain the assets that PowerNet manage, be attracted, developed, retained and be available when required.*

Management of Financial Resources

Financial resources are required to manage assets efficiently over their entire lifecycle. Asset management requires processes for defining and capturing as-built, maintenance and renewal unit costs and methods for the valuation and depreciation of its assets.

The following is the key objective for the management of financial resources: *the necessary financial reporting to plan, acquire, manage, operate, and maintain EIL's assets shall be developed, and finances made available when required.*

6.3 Lifecycle Management and Growth

Growth in the demand for electricity can be either due to an increase in the number of customers or to an increase in demand by a single customer, or a combination of both. Customers are considering electricity as an alternative to coal or other carbon-based fuels due to the drive towards cleaner sources of energy in industrial processes. Supplying this increased demand often requires utilisation of all spare network capacity. In those situations, redesign and development of networks are needed to accommodate these load increases. We accommodate this in the Planning and Design Lifecycle Stages.

Maintenance (and operation) of assets is the prominent lifecycle process post installation (commissioning). Maintenance can be defined as a combination of all technical and administrative actions (including supervisory actions), intended to retain an asset in, or restore it to a condition that allows it to perform a required function. Maintenance does not extend the life of an asset or increase its capacity, but it is an essential function to ensure that an asset reaches its expected life.

There is a correlation between network development, lifecycle management practices and network service levels. Over time, supply reliability is impacted by the increased demand on fixed network assets. More customers and associated service levels are affected with supply interruptions. In the long term, lifecycle maintenance counteracts declining reliability in the face of network aging and deterioration. Similarly, network development offsets declining reliability when demand growth occurs.

6.4 Fleet Plans

Our Fleet Plans describe how a specific asset or type of asset will be managed over its entire lifecycle – that is, how the Asset Management Strategy will be applied to every individual asset.

For each asset classification, the material cost and time required to execute the following activities have been estimated:

- Installation of the asset;
- Execution of each type of maintenance action, as well as the time interval between the activities; and
- Decommissioning and disposal of the asset.

Through the development of Fleet Plans, EIL can improve forecasting of:

- Capital funding requirements for the next 10-20 years;
- The number of people required, their skill type and equipment needed to operate and maintain the electricity networks for the next 10-20 years; and
- Operational expenditure requirements for the next 10-20 years.

These requirements are aggregated across the Annual Works Program for each CAPEX and OPEX category, contributing to a “bottom-up” approach to setting budgets.

7

Capital Expenditure

SECTION CONTENTS

Troopers War Memorial, Invercargill

7	Capital Expenditure	104
7.1	Asset and Network Development Planning	104
7.2	Asset and Network Design	124
7.3	Asset Acquisition.....	133
7.4	Commissioning of Assets.....	139
7.5	Retiring and Disposal of Assets	140
7.6	Capital Expenditure Forecast	141

7 CAPITAL EXPENDITURE

Capital Expenditure (CAPEX) is required to increase the capacity of assets or networks: to extend the network to new customers, to extend the life of assets, to install new assets for safety or reliability purposes, or to replace aging assets, or for a combination of these reasons. This section describes our capital expenditure plan for the next ten years and how we have developed it by applying the plan, design, acquire, commission, and retire lifecycle stages of our asset management model.

For regulatory disclosure purposes, we categorise each of our planned capital investments into one of the following categories that have been defined by the Commerce Commission.

- Customer Connection.
- System Growth.
- Asset Replacement and Renewal.
- Asset Relocations.
- Reliability, Safety and Environment.

The prioritisation and decision-making for our CAPEX program is guided by a holistic assessment of multiple factors, ensuring that investments deliver maximum value and reliability to our network and customers. The key considerations we integrate into our CAPEX planning include:

- All CAPEX proposals are explicitly assessed against EIL's Asset Management Objectives, including safety, reliability, regulatory compliance, customer service levels, sustainability, resilience, and financial efficiency. Projects must demonstrate clear contribution to one or more of these objectives to be progressed within the capital programme.
- Continuous monitoring of asset condition through inspections, maintenance records, and performance data ensures that deteriorating or end-of-life assets are prioritised for replacement or renewal, reducing the risk of failures and unplanned outages.
- Assessing the likelihood and consequence of asset failures, considering impacts on safety, reliability, customer service, and environmental outcomes. High-risk assets are prioritised to mitigate significant disruptions or hazards.
- Critical assets that support large customer bases, or essential services are given higher priority to maintain continuity and reliability.
- Expected growth in customer connections and network load are considered to ensure that CAPEX investments support future capacity needs. Projects are aligned with projected demand to avoid under or over investment in network expansion.
- CAPEX planning incorporates the ability of the network to withstand natural events.

These factors are integrated into our CAPEX decision making process through a structured prioritisation framework. This approach ensures resources are allocated efficiently, balancing immediate operational needs with long-term strategic objectives, and delivering a safe, reliable, and sustainable network while managing asset-related risks and preparing for future growth.

7.1 Asset and Network Development Planning

Long-term asset and network expenditure requirements are determined in the planning asset life cycle stage. We consider the following aspects during this phase.

- Network configuration.
- Asset and asset system redundancy.
- Capacity of the assets and the systems.

EIL monitors existing network assets and ensures that they operate within limits imposed by capacity constraints and service level requirements. Regular updating of demand forecasts enables predictions for future network operation and in line with EIL's development criteria helps us identify the need for network development.

Based on our expectations of demand growth and our evaluation of asset-related risk, we expect to make capital investments of \$87.8 million over the next 10 years.

Planning Phase Risks

The following risks are addressed during the planning phase.

Table 45: Planning Phase Risks

Category	Risk Title	Risk Cause	Risk Treatment
Operational Performance	Damage due to extreme High Impact Low Probability (HILP) Physical Event	Damage caused by force majeure to our infrastructure or equipment (e.g., floods, earthquakes)	Determining areas prone to physical events such as earthquake (liquefaction), tsunami and flood zones. Plan networks to reduce vulnerability to HILP risk areas. Substations in flood risk areas are designed for the critical assets to be located higher than the surrounding area.
Network Performance	Failure of Asset Lifecycle Management	Mechanical or electrical failure, ineffective maintenance ineffective fleet plans Budget constraints Lack of future network planning	Environmental scans to determine potential growth industries and geographical growth areas. Determine the impact of potential technology changes on the networks, e.g., electrification of fossil fuel process heat, distributed generation as well as changes in distribution asset technology. Plan the networks to cater for the envisaged growth and technology changes.
	Operational systems failure due to breakdown in telecommunications	SCADA communications have one centralised communications point that all information is passed through.	Second phase of Enhancement project was completed, and third phase is planned to extend the telecommunication network to Balclutha - due for completion 2027/28.
	Loss of right to access or occupy land	Risk of assets losing / not having the right to occupy particular locations (e.g., Aerial trespass, subdivision)	Plan any new networks along public service corridors as far as possible. Ensure that rights of way and easements are obtained as part of the planning process.
Health and Safety	Public coming into contact with live assets	Unexpected public actions affecting our assets or asset integrity affects public safety	Plan the networks and asset locations to reduce the probability of incidents to a minimum.

Network Development Drivers

EDBs across New Zealand are aware that they have a key role to play as their networks enable the decarbonisation and electrification of society, particularly in the transport and industrial sectors. As EDBs confront this challenge, they recognise the importance of providing clear signals to their customers, communities, and other stakeholders, of the likely medium-to long-term implications of this transition. It is important for stakeholders to understand that this is not 'just' an EV story – different EDBs will experience increased demands for investment in their networks for a range of different reasons.

The following discussion describes what EIL anticipates being the most significant sources of demand growth that the EIL network will experience over the coming decades, out to 2050. It should be noted that for many EDBs, ongoing 'business as usual' maintenance and renewal of their existing distribution network is, and will continue to be, a very significant driver of investment, however this is not presented here as it is not a 'new' driver of investment.

Readers should also appreciate that while certain elements of the transition are well-understood and reasonably well-fixed (for example, the net zero by 2050 target), other elements which may have a significant impact on EDBs, are still uncertain. We have made an educated assessment of what might be expected on the EIL network, but there are significant uncertainties and assumptions built into this.

EIL has begun utilising a more nuanced scenario-based forecasting method using collaborative work supported by the Electricity Networks Aotearoa (ENA). This will be further developed using data science and a refined set of assumptions to develop a more rigorous and structured set of demand forecasts and scenarios.

Development demands include the following scenarios.

- Large generation or an aggregation of small generators may require increased capacity on some areas of the network.
- Requirements for maintaining or improving service levels (whether statutory, customer and other stakeholders' needs or internal strategic initiatives).
- Connection requests from potential customers require an increase in network capacity to match their additional load requirements.
- Load growth exceeding a threshold for increased security – the threshold is based on a predetermined strategic “line in the sand” which is designed to provide particular service levels when applied consistently across the network.
- While asset renewal is generally a lifecycle management requirement, it may present an opportunity as the most economic time for development initiatives such as additional capacity, the introduction of new technology, or more efficient alternative solutions.
- Offsetting these development demands are anticipated arising of new energy flexibility services and demand management techniques that will attempt to defer or even avoid network upgrades. Many of the drivers of growth will have inherent flexibility (for example, EV charging) that may be leveraged to keep demand within development triggers. Security triggers may also need to be redefined where flexibility is actively used to manage demand. EIL is planning for capability to support these developments.

Development projects can take many months or even years to complete, therefore a good understanding of trigger points and when they may be exceeded in the future is required. This is to ensure that capacity can be made available by the time it is needed. The network development process involves demand forecasting (based on historical trends) as well as considering the various demand drivers that may cause deviation from status quo trends. Some of these trigger points are discussed below.

All development planning undertaken during the asset lifecycle planning phase is aligned with EIL's Asset Management objectives. Network configuration, redundancy, and capacity planning decisions are assessed not only against technical requirements but also against safety outcomes, resilience targets, customer service standards, and long-term financial sustainability. This ensures that development expenditure supports the strategic direction set by the Board and delivers measurable value to stakeholders.

Customer behavioural changes

While many factors could change our future operating environments, of particular importance is the way our customers will use, generate, and manage energy in the future. Our approach is to understand and address changing customer requirements and energy use patterns. These changes on the customer side will likely be driven by a combination of factors, including the increased use of new technology (including generation ownership, EVs, and new types of appliances), increasing efforts to reduce carbon emissions, and an ongoing drive to reduce energy costs. We have a responsibility to help facilitate these changes, allowing our customers to achieve their goals.

Effective demand management, energy storage and tariff incentives will help maximise the utilisation of existing energy infrastructure and defer or minimise future investment. Electricity should also offset other less environmentally friendly forms of energy, and the network should facilitate this, for example EVs offsetting the demand for petroleum.

Transitioning to this future will require considerable effort and investment in providing the required visibility, controllability, flexibility, and stability of all parts of the network – particularly in LV networks where the needs and impacts will be most severe. However, the timing at which this investment will be required is highly uncertain.

Declining costs of distributed energy resources (DER), including residential and commercial solar PV and batteries, continue to drive the growth of this technology's adoption.

Between 2010 and 2025, the cost of residential solar PV systems has fallen by approximately 60-70%, with battery storage costs dropping by up to 75%. While the rate of cost decline is expected to moderate through 2030, incremental reductions are still forecast, supported by ongoing advances in manufacturing, materials, and smart technology. The integration of digitisation, automation, and real-time data is increasingly critical for maximizing the value and uptake of DERs. Electric vehicles, while primarily purchased for transport, are also emerging as distributed energy resources across networks.

New smart technologies like automation, AI, Internet of Things (IoT), real-time communication, and network visibility by household will revolutionise the way electricity systems are operated. As technology improves and the cost of IoT sensors decline, it is likely that DER will be able to interact in real-time with the electricity system. This provides a significant opportunity to increase customer participation in markets and more effectively manage complex multi-directional electricity flows that will emerge in future. These changes create the need for system smarts to integrate DER – such as such as rooftop solar, battery storage, EVs, hot water systems, smart appliances, smart meters, and home energy management technologies – will play an important role in New Zealand's decarbonisation.

Ongoing electricity demand growth (residential, commercial, and industrial)

Most of our customers continue to use centrally generated electricity as their key energy source. We do not predict this changing significantly in the foreseeable future. Importantly, our networks provide the “last mile” connection to customers. Even when renewable generation or grid-connected energy storage becomes much more widespread, it would not reduce customers’ reliance on our networks to access these. Likewise, to fully realise the potential benefit of locally generated electricity, customers will still need the distribution network to export their excess electricity, or to import at lean times. Therefore, it would be imprudent to materially adjust investment and asset management plans now to make provision for uncertain needs that may arise in future.

For the AMP planning period, we see most of our network expenditure remaining on conventional electricity network assets and practices. Accordingly, we will continue to keep a strong focus on the health, capacity, and operation of our existing network, as well as expand the network to meet the increased demand of new – and existing – customers. In terms of this AMP, this means that investment on asset renewal, maintenance and growth of conventional network assets will also remain paramount.

Electrification of transport

Road transport accounts for about 17% of carbon emissions in New Zealand. The electrification of these fleets, starting with passenger vehicles, is therefore another obvious focus area to reduce emissions in New Zealand. While current uptake of EVs is relatively low, we expect it to accelerate, especially if more government incentives emerge to support this. The impact of increasing numbers of EVs on electricity demand is highly uncertain, as it is subject to multiple factors such as:

- Number of EVs in a network area.
- Average distance travelled per day (and hence energy required to recharge).
- Use of charging infrastructure structure (public infrastructure versus residential/business charging).
- Time of charging (off-peak charging will have little impact, but should it coincide with the early evening demand peak, it will add to total network demand).
- Energy required by the type of vehicle.
- Rate of charging.
- The expected demand increase can be largely avoided if we can encourage charging during off-peak hours. Various means of achieving this are being investigated.

Demands for decarbonisation

One of the focus areas for reducing New Zealand’s carbon footprint is the decarbonisation of process heat. Industrial processes and waste represent about 11% of New Zealand’s carbon emissions.

When point demands start to exceed about 30MVA, it becomes generally impractical or uneconomic to connect to distribution networks, even at 33kV. Direct grid connections are generally necessary, even where these may still be provided by distribution utilities. Where large processes are electrified, we therefore expect that these will be directly connected to the transmission grid. However, there are still significant numbers of smaller industrial and commercial heat processes, such as heating for hospitals and schools, operating at lower temperature levels, where converting to electricity from current carbon-based heat sources is viable. At least part of the additional electricity capacity required to achieve this will be drawn from distribution networks. As the pressure on business and other entities to reduce emissions increases, we see potential for significantly higher electricity demand associated with process heat conversion. This impact can be even more substantial on those parts of our network where heat loads are concentrated.


Greater reliance on renewable energy

Networks’ investment in electricity networks will need to increase significantly to enable electrification and renewable energy. A significant number of large-scale renewable power stations will need to be connected to the transmission grid over the next 30 years. Modelling shows that the country needs 4.8 GW in the next 8 years (Concept Consulting modelling). New core grid interconnections will be required to enable these new connections and electrification. Historically, transmission connections have been in very large, centralised power stations, which has kept the number of required connections low and has enabled greater predictability in the associated core grid upgrades required. As the pace of change accelerates, the future needs of the grid will become more uncertain. Annual investment of about \$1 billion in transmission is needed to enable renewable generation and electrification.

Current Demand Profiles

Maximum demand (MD) for individual areas do not occur at the same time. For example, in the 2020/21 year, the peak occurred at 08hr00 on the 15th of October 2020 and the Bluff MD of 4.096 MW occurred at 18h00 on the 18th of May 2021. The EIL Coincident Demand (CD) at the time of the LSI peak was 49.93 MW with 3.104 MW of that load contributed by Bluff EIL. The individual maximum demands are displayed in Figure 35.

Figure 35: GXP and Generation Demands



Demand History


Random variations over and above the main growth patterns impact the accuracy of growth trends. In general, a ten-year rolling average will vary substantially between successive years. Longer term trends tend to average out random variations but also obscure recent changes to underlying growth. Some causes of variations might be identified with hindsight, but these are difficult to predict, for instance a drought that leads to increases in irrigation load.

Growth patterns over various time periods need to be considered including known events that impact consumption before a reasonable estimate of growth can be determined (to be used for forecasts of future demand and consumption).

Analysis of historic demand and energy usage indicates maximum demand growth has been stabilising in recent years after an increasing trend at the start of the decade, while energy consumption is showing a clear and consistent downward trend. The following chart shows the overall maximum demand from 1950 and highlights the flattening out of demand since the late '80s.

The data presented is for supply to customers' connection points and excludes transfers between networks. Increases in maximum demand have been affected by changes in Transpower's transmission pricing methodology (TPM) – these changes are not apparent in energy growth.

Figure 36: Maximum Demand and Energy Transmitted



Demand Trends

The following sections examine the most significant drivers of the network demand over the next 10 to 15 years in detail.

The next table shows the maximum demand recorded at each zone substation for the past 7 years. The 99.9 percentile demand is applied to compensate for short term load transfers and to produce a more accurate figure of actual maximum demand (per area). In recent years, extended or permanent load transfers between the zone substations have distorted these numbers. When conducting analysis at substation level, allowance must be made for these load transfers. The overall EIL maximum demand gives a good representation of growth, but extended load transfers outside the network (for example, from TPC’s Seaward Bush substation to Southern substation) still needs to be considered.

Table 46: Zone Substation Demand

Zone Substation	99.9 Percentile Demand (MVA)						
	2025/26	2024/25	2023/24	2022/23	2021/22	2020/21	2019/20
Spey St*	25.5	24.67	24.67	27.32	23.1	24.4	23.9
Leven St	14.5	14.47	14.47	15.34	14.5	16.3	14.3
Racecourse Rd	11.28	12.98	12.98	12.42	11.0	12.8	10.0
Southern	15.61	15.61	15.61	13.86	12.4	11.1	12.0
Bluff (TPCL)	4.34	4.66	4.66	6.05	5.3	5.1	5.2

*Load was transferred to the new Spey Street substation from Doon St sub over 2015/16.

In the past, growth rates were slightly higher in the commercial and industrial areas of the network. In recent years, substation loads and security risks around staging of development projects were managed by shifting loads between substation feeders. This impacts on the accuracy of trends for these areas. However, regardless of the variation of growth affecting the distribution network areas, the loading on each zone substation can be monitored and managed by shifting loads as required.

Development Triggers (based on growth)

Demand is basically created by individual customers withdrawing (or introducing) energy through their individual connection points. The demand at each connection aggregates “up the network” through LV reticulation to the distribution transformer, then through the distribution network, the zone substation, the subtransmission network to the GXP, and ultimately through the grid to the power stations. As the load aggregates through the network, load diversity tends to support better load factor and capacity utilisation.

Demand growth is the predominant driver for network development. We have identified growth triggers and set corresponding thresholds to achieve desired service levels (where appropriate). In meeting future demand (while maintaining service levels), the first step is to determine if the projected demand will exceed any of the trigger points for asset location, capacity, reliability, security, or voltage. The trigger points for each asset class and typical network solutions are outlined below.

Table 47: Development Triggers

Development	Trigger Point	Typical Network Solution
Extension	New customer requests a connection outside of the existing network footprint; often within the network area but not immediately adjacent to existing infrastructure.	New assets are required to extend the network to the new customer. Additional capacity may also have to be built into the nearest existing network and upstream assets depending on customer size. Off-grid remote area power supply systems may be assessed where network extension economics are unfavourable.
Capacity	When either load or generation exceeds the capacity rating of network assets—or encroaches on the required spare capacity—voltage levels can fall outside acceptable limits, such as dropping below 0.90 pu at the customer’s premises. These constraints may arise from high demand (load) or from increased local generation, each posing risks to network stability and asset performance. Proactive identification is achieved through network modelling and continuous monitoring of load and generation data from meters or MDIs. However, issues may still occasionally manifest as overload protection operations, temperature alarms, or voltage complaints. Smart meters significantly enhance our ability to estimate both loading and utilization of asset capacity, enabling earlier detection and more effective management of both load- and generation-driven voltage constraints.	Replace assets with greater capacity assets. May utilise greater current ratings or increase voltage level (extension of higher voltage network, use of voltage regulators to correct sagging voltage or introduction of new voltage levels). Alternative options are considered prior to these capital-intensive solutions but generally provide a means to delay investment; may be network based such as adding cooling fans to a zone substation transformer or non-network e.g., controlling peak demand with ripple control.
Security and Reliability	Load reaches the threshold for increased security as defined by EIL’s security standard. Customers (especially large businesses) may request and be willing to provide a capital contribution for increased security or accept a reduced level of security for their own facility.	Duplicating assets to provide redundancy and continued supply after asset failures. Increase meshing/interconnection to provide alternative supply paths (backups). Additional switching points to increase sectionalising i.e., limit amount of load which cannot have supply reinstated by switching alone after fault occurrence. Automation of switching points for automatic or remote sectionalising or restoration.

*MDI = Maximum Demand Indicator – device that monitors the highest demand on the equipment

When a trigger point is exceeded, EIL will identify options to bring the asset’s operating parameters back within the acceptable range. New capacity has an impact on the balance sheet, depreciation, and ROI. There is an overall preference for avoiding new capital expenditure and EIL endeavours to meet demand by other, less investment-intensive means. The following potential responses and options are considered.

- Pricing signals.
- Demand side management and flexibility services
- Partnerships for non-traditional solutions.

Future Demand

Future demand forecasts are determined by an understanding of historical trends and then projecting these into the future. Projections are adjusted by factors which are likely to cause demand deviations from current trends.

In this AMP, two scenarios have been developed: likely and prudent. The likely scenario represents the most probable outcome based on current assumptions, while the prudent scenario incorporates a more cautious outlook, considering factors that could increase demand. In addition, sensitivity analysis has been applied to reflect potential variations in key drivers such as population growth, electric vehicle adoption, solar generation, and heat electrification. By considering those scenarios, the AMP provides a comprehensive view of future uncertainty, supporting robust planning and investment decisions. The difference between the Likely and Prudent scenarios is less than 1 MVA.

Figure 37: Demand Growth Forecast (Likely)





Figure 38: Demand Growth Forecast (Prudent)



Population, Demographics and Lifestyle Drivers

A description of demographic and lifestyle drivers of future demand is provided in the next table, followed by population projections.

Table 48: Demographic and Lifestyle Drivers

Population Growth and Decline	<p>Effect: Population increasing in future years by ~3.6% by 2033. This corresponds to a similar increase in demand of 3.6% assuming similar housing and living arrangements and that employment is available under a similar business profile.</p> <p>Description: The population of EIL’s distribution area is approximately 57,100 (2023) of which the Bluff area accounts for approximately 4.6%. Statistics NZ estimates that the population under EIL’s distribution network would have grown by approximately 0.4% per annum from 2023 to 2028. Long term growth is expected to be relatively flat with medium growth rate assumptions. The upper bound projection of population growth for EIL’s distribution area is 10% by 2033 (with an assumed growth rate of 0.9% per annum), a lower bound of –0.18% by 2033 (with an assumed growth rate of 0% per annum), and a mean estimate of 5.08% growth by 2033 at an assumed growth rate of 0.4% per annum. It is expected that the vast majority of growth would occur in urban areas of which Invercargill is Southland’s largest metropolitan area. Invercargill would attract the majority of potential migrants however the Invercargill area supplied by EIL is surrounded by TPCL which supplies the outer regions of the city. Expansion of Invercargill for additional housing would therefore often be outside of EIL’s network boundary. EIL does have some undeveloped land suitable for housing and there is further potential for in-build with subdivided sections which, if increased demand eventuates would be utilised to some extent. Business expansion is also a target for the Southland Regional Development Plan and again Invercargill would expect to be a key location for this to occur. Commercial subdivision to support any potential new commercial building is available within EIL’s Invercargill network area.</p>
Housing Density and Utilisation	<p>Effect: Overall support of domestic power demand growth from increasing population as described above. Effects of increased housing density is somewhat offset by increasing housing utilisation as more people share heating and other power requirements.</p> <p>Description: Housing density and utilisation can be expected to increase to some degree as the population increases. The trend for low care properties especially with an aging population is expected to continue while at the same time in-build is expected to continue as property owners subdivide in line with this demand. An increase in the student population may increase demand for higher density student accommodation facilities near central Invercargill.</p>
Rural Migration to Urban Areas	<p>Effect: Population growth in the EIL network area, especially from retirees (baby boomers), is expected to be a limited driver for increased demand. This effect is captured in population growth effect above discussed above.</p> <p>Description: Urbanisation is a trend seen worldwide with rural people migrating into metropolitan areas and this trend has also been seen in Southland. Farming has been shedding jobs for some time as improved technology means fewer people are required per unit of production. This supports the above assumption that Southland’s urban areas, particularly Invercargill, are likely to see the vast majority of population. The number of people 65 years and older is projected to increase from about 15% to between 20% and 25% in 2026. The impact of farmers retiring to urban areas increases demand for townhouses in desirable locations. Building in new areas on the outskirts of Invercargill outside of EIL’s network area or demolishing older houses to replace with more efficiently heated homes may be common for these retirees. Some additional support for retail business in Invercargill may result but overall, this would have a minor impact on power demand. As this is not a new effect it is largely included in previous years trending.</p>
Remote Working	<p>Effect: Shift from commercial office spaces to residential zones.</p> <p>Description: Since Covid forced many people to work from home during lockdowns, remote working has been embraced by many workplaces and become a normalised option for many people. Many people will only work from home sporadically for personal convenience with only small shifts in energy use in commercial spaces (they will still be heated for remaining staff) but often with more impact on the residential spaces that are more likely to require increased heating, lighting etc. Some people will have regular work from home schedules that may contribute to reduced need for office space and associated energy use in the workplace and increased periods where residential energy use is impacted.</p>

Increasing Energy use per Customer

Effect: Growth minimal and included in existing demand trends.

Description: The use of heat pumps as air conditioners is becoming more common especially in commercial buildings. However, this effect would improve load factor rather than increase peak demand as it occurs in summer while peak demand is driven by heating which occurs over the winter months. Customer goods including appliances and electronic technology are generally becoming more affordable however while the numbers of these goods per household may be increasing, they are often not used at the same time. Energy efficiency is also improving for many of these items offsetting any increases in household demand.

Convenience of Electrical Heating

Effect: The effect of heat pump conversion is expected to be small, estimated to be about 0.5% growth in demand for EIL over the next ten years. Incorporates growth anticipated from council fuel burner constraints.

Description: Electrical heating is generally the most convenient form of heating being available at the flick of a switch. Around 8% of energy consumption comes from gas and solid fuel-based space heating and has the potential to be replaced by electrical heating. There is a trend of conversion to and greater reliance on electrical heating due to convenience and low running costs of electrical heating when using heat pumps. For EIL’s customers, concerns with loss of heating during outages are negated by the high supply reliability these customers receive.

However, heat pump installation cost is a barrier for many people, and some prefer the ambience of other heat sources. Therefore, complete conversion to electrical heating cannot be expected and further conversions will occur over an extended period. The additional demand that arises will be partly offset by increased use of heat pumps over other traditional electric heaters which can use three to four times the power to run.

Conversion will be both driven and constrained by the Breathe Easy clean air initiative.


Electricity Affordability

Effect: Minimal change in demand for power supply is expected due to changes in electricity prices. Future change is likely to be a continuation of current demand trends.

Description: Consumption and demand are relatively inelastic to changes in power prices as electricity is seen as an essential service for most people. This may not be the case for a proportion of people in energy hardship that may choose to consume less. While most customers do not consume significantly less, EIL has observed customer responsiveness to price signals that shift when electricity is consumed.

The current population projections for EIL’s network area are based on estimates from the 2023 Census data from Statistics New Zealand. Projections for the 65+ age group indicates a significant aging of the population as highlighted in the following chart.

Figure 39: Population Projections



Environmental and Climate Drivers

Drivers of future demand based on changes in the environment and climate are discussed below.

Table 49: Environment and Climate Drivers

Council Fuel Burner Constraints	Effect: Continuation of existing trends towards electrical space heating
Description: The Regional Air Quality Plan has included prohibition of open fires since 1 January 2017 in the Invercargill airshed area. Further prohibition of non-approved burner/boilers in the Invercargill airshed area occurs from the following dates.	
Burner installation date	Prohibition date
Before 1 January 1997	1 January 2019 (wood) 1 January 2017 (other fuels)
1 January 1997 – 1 January 2001	1 January 2022
1 January 2001 – 1 September 2005	1 January 2025
1 September 2005 – 1 January 2010	1 January 2030
1 January 2010 – 6 September 2014	1 January 2034
Approved boilers and burners are those which meet the national environmental standards for emissions and thermal efficiency. Any burners installed after September 2005 may be on the Ministry of the Environment’s list of approved burners and not require replacement. This phase-out of inefficient heating will require replacement and some degree of conversion to electrical heating with heat pumps is to be expected.	
Energy Conservation Initiatives	Effect: Customers are responding to marketing, strategies, and the availability of energy efficient products to reduce their consumption. Considered a significant driver of demand contraction however is mostly recognised within existing trends. Energy savings are likely to increase to some degree, estimated at 0.5% (demand contraction) over the next ten years.
Description: Energy efficiency in customer appliances is increasingly popular due the combination of government or local council drivers, marketing, and customer demand. Replacement of appliances with improved energy efficiency provides customers with the same benefits or standard of living while requiring less power consumed and so reduces power bills. Similar drivers are contributing to further installations of insulation which also assists in reduced power requirements for heating (see above section on Energy Efficiency).	
Increasing Average Ambient Temperature	Effect: No impact on maximum demand but potentially some improvement in load factor.
Description: Increasing average ambient temperature predicted by climate scientists may create increased demand for cooling systems. This increased consumption would occur in the warmer months and therefore not coincide with the current peak demand occurring in the winter months being dominated by heating requirements. It would take a very large change in ambient temperature for peak consumption to be dominated by cooling in summer months and, as a result, an increasing ambient average temperature is expected to simply improve load factor by a small degree.	
Wider Range in Weather Variations	Effect: Potential impact on maximum demand, and worsening load factor. Some impact on network reliability.
Description: Climate scientists forecast a potential for increasing frequency and/or intensity of storms, along with wider variations in seasonal weather. Colder periods may increase heating load, adding to current peak demand. Hotter and drier summers will lead to an increased garden irrigation demand that will manifest itself as an increase in the water purification load.	

Economic Drivers

Economic drivers of future demand include major industry growth as well as variation in the value of the New Zealand dollar and commodity cycles. These drivers are presented in the next table.

Table 50: Economic Drivers

Major Industry Continuance or Growth	Effect: The most likely scenario is considered in which existing industries will continue or grow in load, some new major new industries will eventuate in the region but this will not affect EIL therefore no change from existing trends forecasted.
Description: Dairy Industry, Tiwai, Major Petrochemical Extraction or Processing etc. The Tiwai aluminium smelter takes supply directly from the transmission grid; but it helps support many businesses and individuals in the EIL area, both directly and indirectly. Approximately 1000 full time equivalent employees and contractors work at the smelter. There are a number of industries that have lodged enquiries for connections in the Southland region. These industries will have an indirect effect on the EIL network, in that the demand for housing in the EIL area may grow, causing an increase in domestic load growth. This has been taken into account in load growth projections.	
\$NZD Variation & Commodity Cycles	Effect: Regional growth remains steady despite global volatility.
Description: Past global shocks like the GFC and COVID-19 slowed investment, but Southland has shown resilience. Currently, the NZD is relatively low, increasing import costs for infrastructure; however, strong export gains from dairy and meat largely offset this impact. Recent interest rate cuts may encourage investment. The removal of the GIDI scheme has slowed decarbonization projects, yet inquiries for renewable generation remain strong, signalling continued interest in clean energy.	

Technology Drivers

Electric and autonomous vehicles, distributed generation, energy efficiency and storage as well as the Internet of Things (IoT) are included in technological drivers of future demand. These are discussed in the following table.

Table 51: Technology Drivers

EVs	Effect: Some demand growth toward the end of the ten-year planning horizon.
Description: EVs have the potential to have a large impact on network. EVs are becoming more widely used and it is forecast that by 2030, 10% or more of the light passenger fleet could be electric. EIL intends to use strategies such as cost-reflective pricing to encourage EVs owners to charge their vehicles during off-peak hours, reducing the impact on peak demand and increasing load factor. However, EIL must allow for the possibility that customers may not respond well to price signals, causing vehicle charging to occur on-peak. In this scenario, modelling shows that the EIL medium voltage network will be able to cope with the increased demand, with minor adjustments to normal configuration. However, the lower diversity on the LV network makes it both more likely that voltage issues will occur, and more difficult to predict in advance where those issues will occur. EIL, through PowerNet, has planned an upgrade of data analysis of ICP smart meters to provide increased visibility of power flow on the network. This data when analysed together with supplementary Maximum Demand Indicators at distribution substations, will better enable EIL to identify vulnerable points on the LV network and proactively upgrade to remove the constraints.	
Autonomous Vehicles	Effect: Potential for significant shifts in EV charging locations and timing that are hard to predict. May cluster charging around urban fast charging hubs or reduce commute barriers shifting demand away from urban centres.

Description: Autonomous vehicles have the potential to have a large impact on the spread of network demand if there is regulatory acceptance and sufficient penetration into the passenger transport sector. Impacts may be hard to predict as new business models may arise.

For example, vehicle ownership may shift to businesses that create efficiencies by maximising vehicle utilisation as a shift from the status quo where many vehicles are used for commutes to work but then sit ideal most of the time. This could lead to clustering of charging around urban fast charging hubs to keep vehicles moving. These models would be expected to arise first in larger urban centres outside of EIL network so would have some increased time to plan for these impacts.

Alternatively, lowering cost and downtime for commuting to workplaces may support some customers to shift away from urban centres with associated network demand shifts.

Housing cost drivers would contribute to such a shift although there is less housing cost pressure in Southland.

Adoption and network impact is highly correlated to uptake of electric vehicles, as the technology is often packaged into newer electric vehicles and impact will be monitored closely as a significant driver of growth.


Distributed Generation

Effect: DG could have significant customer and market benefits. From the distribution network, their impact is expected to be more limited, particularly if effectively managed. Almost all new generation on our network is from solar PV, whilst the network peak is historically on winter evenings.

Description: As of March 2025, there are 191 distributed generation (DG) connections in EIL. This is approximately 1.07% of the total connected customers. 22/30 (73.3%) of the DG connections seen so far has been solar installations and this trend is expected to continue for the foreseeable future.

Through our annual customer engagement survey, intentions to buy and installing solar panels on rooftops across all PowerNet managed networks in the next five years has increased to 38%; an increase of 5% from 2021. The main barriers to adoption related to economic reasons where projected payback period was a large influence on the purchase intention. Other considerations that may limit solar uptake are property ownership and energy cost reduction options such as home insulation and EVs now receiving increasing attention and better returns.

Figure 40: Distributed Generation Uptake on EIL



The LV network can be vulnerable to solar DG installations which, without energy storage, depresses the midday trough in demand (or can even reverse power flow) whilst leaving the evening peak unaffected. This increases the range of load currents (and therefore voltage drops) under which the LV network must operate. A network tuned to deliver the minimum acceptable voltage in the evening may still exceed the maximum acceptable voltage at midday if customers connect sufficient solar generation without sufficient storage and controls.

The impact of DG installations on the network can be significantly reduced when the inverters employ Volt-VAR compensation, so PowerNet has made it a requirement for the majority of connections.

Similar to EVs, the concentration of effects on the LV network makes the location of future voltage problems difficult to predict. Availability of smart metering data allows us to predict economic viability of DG installations such as solar to better understand potential clusters that may emerge in the future. Conducting congestion studies by running multiple penetration levels of DG scenarios on the LV network can also be useful to identify network capacity thresholds and constraints prior to approving new DG connections or requiring controls to be in place so that voltage problems are minimised.

Energy Storage

Effect: Not expected to have a significant presence within the ten-year planning horizon and therefore negligible effect on network demand. It is estimated that battery storage will reduce peak demand by less than 2% by 2035/36.

Description: As mentioned above, almost all new DG is from solar PV, while EIL’s network peak is historically on winter evenings. Coupling solar PV generation with energy storage could change this dynamic, but at present rates the storage capacity provided is immaterial. Storage gives customers some control over their demand without impacting their consumption and could make it feasible for customers to go “off-grid” with a sufficiently sized generation source. However, there is significant uncertainty in this area around the viability of alternative battery chemistries and the timing of their introduction; the regulatory environment and the extent to which electricity distribution businesses will be able to promote/utilise/market storage services; and future pricing structures and the level of responsiveness of the public to load-driven pricing signals.

Under the status quo this technology is not economic except in exceptional circumstances, and it is not expected that there will be major developments in this area for the next five years. If any such developments occur in the second half of the planning period, it is expected that they will take several years to have an impact at the network level, during which time EIL can respond in a focused manner. Any impact these devices have is likely to be beneficial in terms of network constraints, as they act to reduce rather than increase the peak demand on network assets.

Energy Efficiency

Effect: Energy conservation initiatives provide a negative growth driver.

Description: Improving energy efficiency has been a government strategy for several years (energy conservation initiatives). It is also desired by customers as a means of keeping their power bills down. More efficient appliances, lighting and heating are being developed to meet this demand. Other initiatives such as subsidies for home insulation are also helping customers to use energy more efficiently.

On-line shopping

Effect: Likely to negatively affect the business sector in EIL’s network area however the overall effect on demand is expected to be relatively insignificant.

Description: Shopping online continues to become more and more popular, with these online shops tending to be based out of the larger centres. This in turn means less demand for retail businesses within EIL’s network area. However, there is also some opportunity for local businesses to connect with customers outside of Invercargill or even worldwide and this will somewhat offset the potential loss of business. It is expected the overall effect will be a loss for the business sector in EIL’s area.

DER Interconnectivity

Effect: This is a key enabler of DER control and orchestration across networks to support maximum benefit reducing network costs and rewarding customers for their participation

Description: Regulators are working with industry to prepare regulatory settings and standards that support standardised open protocols that support interoperable connectivity of DER. This allows strong competition to arise around the development of flexibility services that leverage DER supporting new efficient and innovative services to arise. Open protocols allow access to all innovators to compete and contribute to developments while benefiting from standardisation in the coordination of large numbers of devices. Interoperability means customers are not locked into single providers such as OEMs that may control price and innovation associated with services from their devices.

Demand Forecasts

We estimate that the overall impact of the future demand drivers is a 1.2% per annum maximum demand growth rate. Growth per substation is the most appropriate level for identifying constraints on the network.

The projected substation demands indicate the expected growth forecast. This is the most likely outlook, and these projections are the basis for EIL’s network development planning. EIL also carries out an internal prudent growth forecast with appropriate contingency planning. Actual future demands may deviate significantly from the growth projections. Forecasts are updated annually to ensure that plans can rapidly respond to changes from previous assumptions.

EIL endeavours to realise growth opportunities as they arise, which means developing the network to alleviate constraints as required within the parameters of acceptable risk. With declining growth rates, projects to address capacity constraints are postponed, minimising over-investment risks. The risk of stranding of new assets is managed through capacity guarantee contracts with new customers (where appropriate). Risk is also minimised through avoidance of investment until necessary yet still maintaining the desired service levels. Higher than anticipated growth rates present a risk of missed opportunity for growth for both EIL and our customers.

It is expected that growth affecting the entire network will be determined with sufficient timing to allow for resource

adjustments. Large scale developments are likely to be funded by external investors through capital contributions. In general, EIL has the ability to quickly respond to unforeseen large-scale developments that occur once-off. Limits to this capability might be negotiated around timing of project delivery. While all efforts are made to inform customers of potential lead times for providing additional network capacity, requests for supply are often made late in customers' planning processes due to commercial sensitivities.

As was shown in the chart of future demand (Figure 37), the forecast demonstrates a steady long-term increase in total EIL network demand, with residential growth and EV uptake driving the gradual upward trend.

The demand forecast indicates a moderate but steady increase in total network demand through to 2050, primarily driven by long-term residential growth and the accelerating uptake of electric vehicles. Commercial and agricultural/irrigation loads remain relatively stable, with only incremental increases anticipated. Solar generation and battery impacts remain minimal in the current forecast window, while heat-related demand (efficiency and electrification) shows only gradual change. The overall trend reflects a predictable and manageable rise in demand, with no major step-changes observed. This supports a planned, phased investment approach focused on maintaining capacity, resilience, and adaptability as underlying growth continues across the network.

It is recognised that as the uptake of EVs and other technologies increases, some parts of EIL's LV network may become constrained. EIL has fortunately invested in smart meters across its network, completed the deployment and is seeing the benefits of data availability of low voltage (LV) network visibility. This is further enhanced due to EIL's relationship with SmartCo (of which EIL is a shareholder). That has enabled the development of electronic tools to provide this greater visibility of the LV network, providing valuable information for PowerNet as network manager to monitor network loading and congestion and forecast future growth, including use of wider data analytics. Having this insight will enable us to seek the most efficient solution to LV congestion, which may be either a network upgrade or a non-network solution.

PowerNet is currently developing load forecasting and scenario planning tools to allow constraint mapping and modelling of the LV growth. This will allow better forecasting of LV and MV constraints with the forecast constraints identified and published, and solutions sought.

Network Constraints

The Invercargill GXP has a firm capacity of 143 MVA with the historical GXP maximum demand at 96.5 MW. There is capacity for growth well beyond the ten-year planning horizon based on the growth rate estimates, however, this GXP is shared with the TPCL network, which is experiencing abnormally high load growth due to decarbonisation initiatives. This growth on the TPCL network could potentially trigger capacity upgrades at the GXP.

There are no constraints on the sub-transmission network that could prevent the zone substation capacities being utilised. In addition, load control could potentially be utilised to limit EIL load if required.

The table below displays the projected maximum demand for zone substations at the end of the ten-year planning horizon and the expected provisions for future growth. The assumption is that unforeseen changes in growth rates or step changes due to connection or loss of large customers will not occur.

Table 52: Substation Demand Growth Rates

Substation	MD '26/27	MD '35/36	Provision for Growth
Spey Street	25.5	27.1	Spey Street has a capacity of 72MVA and a firm rating of 36MVA and is adequate for the anticipated load over the ten-year planning horizon.
Leven Street	14.5	18.7	Leven Street has a capacity of 46MVA and a firm rating of 23MVA. The firm rating is unlikely to be exceeded by the end of the ten-year planning period; if a capacity constraint did arise, it could be managed through load transfer to Spey St substation. The Invercargill CBD redevelopment is expected to have slightly net positive increase on long term electricity demand, as older buildings are replaced with newer buildings (more energy efficient but larger floor area).
Southern	15.61	19.9	Southern substation has a capacity of 46MVA and a firm rating of 23MVA. The firm rating is not expected to be exceeded within the ten-year planning horizon. Should a capacity constraint arise, it could be managed through load transfer to adjacent feeders.

Substation	MD '26/27	MD '35/36	Provision for Growth
Racecourse Road	11.28	11.4	Racecourse Road substation has a capacity of 23MVA available from its single transformer. Maximum demand has exceeded the 12MVA security trigger in recent years, due to load transfers from other substations. As the Southern Substation project has been completed, the load is being re-balanced between the Invercargill substations. This will avoid triggering development of the Racecourse Road substation until after the planning period.
Bluff (TPCL)	4.34	5.7	<p>Demand in Bluff is historically flat. Recent increases in demand are attributed to activity at SouthPort, which may reduce back to historic levels if an economic downturn were to occur.</p> <p>The introduction of Flat Hill wind farm produced a downward trend in the annual demand totals. The influence of the wind farm must be removed for forecasting purposes, due to the intermittent nature of wind generation.</p> <p>The economics of EVs will be particularly attractive to Bluff residents who regularly commute to Invercargill. On-peak charging of these vehicles would lead to growth beyond the expected level, however Bluff substation has a firm capacity of 13 MVA, which is sufficient for a prudent growth forecast well beyond the ten-year planning horizon.</p>

Projected annual maximum demands incorporating growth provisions are presented below. Sites with high loads will be closely monitored to determine if capacity will be exceeded in the short term. Annual preparation of data will highlight sites with capacity constraints, and the planned works will be adapted for each situation. This would entail some capacity upgrades being delayed or brought forward.

Table 53: Substation Maximum Demand (incorporating growth)

Substation	'26/27	'27/28	'28/29	'29/30	'30/31	'31/32	'32/33	'33/34	'34/35
Spey Street	25.7	25.08	25.08	25.9	26.1	26.6	27.1	27.1	27.1
Leven Street	15	17.0	17.2	17.6	17.9	18.3	18.7	18.7	18.7
Racecourse Rd	11.28	11.3	11.3	11.3	11.4	11.4	11.4	11.4	11.4
Southern	14.9	15.2	15.5	15.8	16.1	16.5	16.9	16.9	16.9
Bluff	4.34	4.7	4.7	4.7	4.7	4.7	4.7	4.7	5.3

EIL also manages other general constraints on its network as described in the following table.

Table 54: Network Constraints and Intended Remedy

Constraint	Description	Management Approach
MV Cables	Some MV cables operate near full capacity and would be unable to supply load in backup scenarios.	<p>When cables are replaced, the capacity is reviewed to ensure new cables have capacity for forecast growth and load transfers.</p> <p>Operational measures ensure cables are not overloaded and smaller MV cables are protected with fuses.</p>

Constraint	Description	Management Approach
MV Transformers	Some transformers are near full capacity.	Maximum Demand Indicators (MDIs) are monitored, and transformers will be upsized or supplemented with additional units as appropriate. MDIs will be upgraded in the medium term to provide improved data for transformer loading and LV network analysis. Underutilised transformers may be relocated before purchasing new.
LV Switching in CBD	Limited locations are available for above ground equipment.	Communication with the Council to determine appropriate locations for above ground link boxes has worked well.
Overhead Lines	The District Plan prohibits new overhead lines in the Invercargill City area.	Underground cables have been utilised throughout Invercargill. (Bluff is still supplied through an overhead network)

Where we have known or forecast injection constraints on the LV network, these are published in map format on our website with the constrained locations indicated. <https://powernet.co.nz/future-energy/generation-and-storage/get-connected>

Distributed Generation and Demand Management

Distributed Generation (DG) influence on maximum demand is currently negligible due to the estimated low connection density of DG and the prevalent winter conditions in the area. It is possible that only a small percentage of the capacity may be available during winter peaks. Increased electricity prices together with the decreases in costs of solar panels and batteries may change this in future.

Load management may be used when substation equipment is nearing overload as well as with load transfers for maintenance purposes. The assumption is that load management has a minimal influence on projected demand, although historical demand records will include these effects.

Flexibility Services and Non-Network Solutions

As we continue to develop and enhance the electricity networks, our planning approach increasingly considers flexibility services and non-network solutions as viable alternatives to traditional network investments. These solutions provide an opportunity to optimize network performance, defer capital investment, and enhance resilience, particularly as energy demand patterns evolve and distributed energy resources become more prevalent.

Our current practice is to assess flexibility services and non-network options as part of the business case development for network upgrades and expansions. This ensures that all potential solutions—both conventional and innovative—are evaluated on a technical and economic basis to determine the most cost-effective and reliable approach.

Key areas where these solutions may provide value include:

- **Peak Demand Management** – Reducing the need for infrastructure expansion by leveraging demand-side response, battery storage, and distributed generation.
- **Grid Stability and Resilience** – Utilizing flexibility services to support voltage control, frequency response, and contingency planning.
- **Deferring Capital Expenditure** – Optimizing the use of existing assets before investing in new infrastructure, ensuring cost efficiency for both the network and consumers.

As we move forward, we aim to expand the role of flexibility services and non-network solutions, ensuring they are systematically considered in all major network planning processes. Collaboration with market participants, technology providers, and regulators will be essential in unlocking the full potential of these innovative approaches.

Non-network solutions, including demand response, distributed generation, and energy storage, are considered as part of the network planning process where they may provide a cost-effective alternative to traditional network augmentation. The potential contribution of these solutions to addressing network constraints is assessed during the planning and business case development stages, alongside conventional network investment options. Where applicable, these solutions may be delivered by third-party providers or through market-based flexibility services.

Service Level Changes

The general approach of monitoring network demand, and initiating projects when standardised development triggers are reached, serves to maintain existing service levels. Where a change in service level is desirable, this may be undertaken either directly (for example, targeted seismic remediation program to improve safety and resilience under earthquake conditions), or indirectly through the adjustment of the thresholds used for the triggers (for example, lowering the minimum number of downstream customers required to justify a dual transformer substation). These decisions tend to be strategic in nature and go beyond the general approach of monitoring network demand and initiating projects when standardised development triggers are reached.

These projects may be triggered by a complex interaction of many factors or driven (or required) by external influences. Examples are the shifting perceptions around staff/personnel safety or acceptable levels of risk, and these will create drivers for network development projects which are not a requirement arising from demand growth.

Development Programme

The following tables present EIL’s development projects according to whether they are: underway or planned for the next 12 months, planned for the the following four years, or are being considered for the remainder of the planning period.

Table 55: Non-routine Development Projects (next 12 months)

Project Description	26/27 CAPEX Cost
<p>Customer Connection Projects: This budget provides allowance for new connections to the network including subdivisions where a large number of customers may require connection. Each specific solution will depend on location and customer requirements. Scope and timing of works are adjusted to customers’ works plans as communicated to EIL. Expenditure and timing may differ from that published as customer developments progress.</p>	\$306,930
<p>Asset Relocation Projects: This budget captures costs for general minor relocation works required such as shifting a pole or pillar box to a more convenient location. Costs budgeted represent a long-term average with actual spend being reactive and typically above or below budget in any year.</p>	\$7,754
<p>Quality of Supply Projects: On the LV network, operation beyond capacity typically manifests as decreased voltage levels experienced by customers during periods of peak loading. This may occasionally require a new transformer site with associated 11 kV extension if required. However, in most cases replacing LV cables with larger cables will be a more economic option to maintain acceptable voltage for all customers. The minimum standard cable size which provides the existing and spare capacity for expected growth will be used.</p>	\$114,189
<p>Reliability, Safety and Environment (including Pillar Box Lid Upgrades): EIL has traditionally used concrete pillar boxes with aluminium lids on the front to enclose the fusing for individual customers’ supplies. However, in very rare cases the internal cables can come into physical contact with the lid, and the cable insulation can be gradually abraded – for example, because of minute vibrations caused by nearby traffic. If the insulation were to abrade sufficiently between pillar box inspections, this situation could result in livening of the aluminium lid.</p> <p>A supplier has been sourced for plastic lids that offer similar mechanical protection to the aluminium lids whilst being electrically nonconductive. These plastic lids are being installed as a part of the pillar box inspections.</p>	\$570,3452

Table 56: Non-routine Development Projects (next five years)

Project Description	CAPEX Cost & Timing
<p>Customer Connections: This budget provides allowance for new connections to the network including subdivisions where many customers may require connection. Each specific solution will depend on location and customer requirements.</p> <p>Connection activity has increased in recent years and is expected to continue due to the Invercargill CBD redevelopment and other known customer-initiated works. Capital expenditure has been increased for EIL to provide the required supporting electrical infrastructure.</p> <p>Scope and timing of works are adjusted to customers' works plans as communicated to EIL. Expenditure and timing may differ from that published as customer developments progress.</p> <p>Planning for new connections uses averages based on historical trends, modified with any local knowledge, if appropriate. However, customer requirements are generally unpredictable and quite variable. Larger customers especially, which have the greatest effect on the network, tend not to disclose their intentions until connection is required (perhaps trying to avoid alerting competitors to commercial opportunities), so cannot be easily planned for in advance.</p> <p>Various options are considered to determine the least cost option for providing the new connection. Work required depends on the customer's location relative to existing network and the capacity of that network to supply the additional load. This can range from a simple LV connection at a fuse in a distribution pillar box at the customer's property boundary, to upgrade of LV cables or replacement of overhead lines with cables of greater rating, up to requirement for a new transformer site with associated 11kV extension if required. Even small customers can require a large investment to increase network capacity where existing capacity is already fully utilised.</p> <p>The district plan requires all new network to be underground in Invercargill, however, Bluff may utilise overhead construction which tends to be a lower cost option.</p> <p>Distributed generation as a network alternative tends to be intermittent so cannot be relied on without energy storage, which could make an installation uneconomic. Some schemes may be becoming cost competitive with supply from the network however the upfront cost is generally not attractive to most customers and generally a connection to the network is still desired as backup, supplementation and sometimes the ability to sell surplus energy. Customers may be encouraged to better manage diversity of load within their facilities where details are known and there is perceived benefit to the customer or network.</p> <p>Budgets for subdivisions and distributed generation are separated from other connections to support trending analysis; however, these budgets are set low as it is expected that spend will occur against them only once every few years.</p>	<p>\$2,883,395 '26/27-30/31</p>
<p>Earth Upgrades: Ineffective earthing may create, or fail to control, hazardous voltage that may occur on and around network equipment affecting safety for the public and for staff. Ineffective earthing may prevent protection systems from operating correctly which may affect safety and reliability of the network. Routine earth site inspection and testing identifies any sites that require upgrades.</p> <p>The analysis to determine what upgrade options are appropriate can be quite complex but essentially it looks to find the best trade-off between cost and risk reduction. Generally, in EIL the earthing upgrades required will be minimal with safety being achieved by simple connection to the large urban MEN (multiple earthed neutral) system. However, for sites where risk of potential exposure to EPR is high additional measures such as insulating barriers will be required to ensure public safety.</p> <p>Routine testing is completed five yearly with the entire network tested in one year.</p> <p>This project has been increased to cover remediation of non-compliant / un-maintainable sites discovered in the most recent earth inspection / testing round.</p>	<p>\$384,453 '26/27 – 30/31</p>

Project Description	CAPEX Cost & Timing
<p>LV Tie Point Disconnectors: Distribution substations are routinely de-energised to carry out necessary maintenance on the ring main units. At times, when justified to prevent disruption of supply to customers, the substation's load is transferred to neighbouring substations prior to de-energisation. This load transfer is currently carried out by manually connecting live conductors together at tie points using cable taps.</p> <p>While the risks of this procedure are largely mitigated by the use of administrative controls, insulating mats, and personal protective equipment (PPE), the residual safety risk may be deemed inappropriate for a modern electricity distribution business working under current health and safety legislation.</p> <p>This project provides for the installation of disconnector switches at all LV tie points on the network. In addition to the safety benefit, this project is expected to reduce the switching time associated with a de-energisation by over 75% and reduce wear / tear from manual handling of cables.</p> <p>The project will focus on two-way and three-way pillars, where a method has been devised to retrofit disconnectors into the existing pillar boxes. Retrofit installations will be aligned with the distribution substation maintenance servicing cycle and transformer replacements.</p> <p>Upon completion of the pillar retrofits, the focus will shift to switches that require pillar replacement. This will most likely involve replacing existing pillars with a larger injection moulded pillar box. Overall, nearly 1000 pillars will be upgraded in a project that extends beyond the end of the planning period.</p>	<p>\$1,421,510 '26/27 – 30/31</p>
<p>Supply Quality Upgrades: On the LV network, operation beyond capacity typically manifests as decreased voltage levels experienced by customers during periods of peak loading. This may occasionally require a new transformer site with associated 11 kV extension if required. However, in most cases replacing LV cables with larger cables will be a more economic option to maintain acceptable voltage for all customers. The minimum standard cable size which provides the existing and spare capacity for expected growth will be used.</p> <p>An alternative to network upgrade is demand side management, however cost incentives to reduce demand are proving ineffective due to the retailers repackaging of line charges into their billing. As EIL's 11 kV feeders have high load density supplied over a relatively short distance, LV is not seen as an issue on these feeders.</p> <p>Costs budgeted represent a long-term average with actual spend varying around this average from year to year.</p> <p>Once smart meter LV information is more readily available, EIL anticipates an increase in supply quality related work, in advance of customer complaints.</p> <p>The allowance for this work will be adjusted with more accurate projections of work volume.</p>	<p>\$19,222 p.a.</p>
<p>Network Automation Projects: This budget is to allow implementation of network automation initiatives on the Invercargill and Bluff networks to add additional remote controllable switching points and automation technologies. The resulting improvements in reliability are intended to offset the reduction in reliability that is to be expected as the cable network is allowed to age back to the optimal average asset life remaining of 50%; the extensive underground programme and other recent or near future capital intensive projects have made EIL into an unusually young network.</p>	<p>\$40,677 p.a.</p>

Table 57: Non-routine Development Projects (under consideration)

Project Description	CAPEX Cost & Timing
<p>Unspecified Projects: This budget is an estimate of costs for projects that are yet unknown but are considered likely to arise in the longer term. Certainty for these estimates is obviously low.</p> <p>These projects and this expenditure will eventuate based on customer driven developments and engineering evaluation of network capacity.</p>	<p>No provision</p>

Non-network Development

IT and management services support are provided through the services contract with PowerNet. EIL does not directly develop the GIS or AMIS (Maximo) systems, but in conjunction with PowerNet develop interfaces and processes around these systems.

- PowerNet includes consideration of non-network alternatives that could defer or replace the need for network upgrades. Non-network options include local generation installations as an alternative energy source as well as energy storage and these may be used in combination. These could provide a total supply solution for options such as microgrids or be used to reduce network capacity requirements as in demand peak shaving.
- These options are particularly relevant where demand growth is the primary driver for network upgrade projects. Growth impact may be reduced with non-network solutions whereas condition-based refurbishment or replacement is less able to be managed with non-network solutions.
- Non-network solutions effectiveness, however, is strongly influenced by growth rates, customer uptake, and the scale of the constraint, and these solutions generally work best in low-to-moderate growth environments where incremental capacity can meaningfully extend the life of existing assets. When growth is rapid, non-network alternatives can be quickly outpaced, creating a narrow window for benefits and increasing the risk of under-utilised or stranded assets.
- Recently, PowerNet considered a non-network alternative for the Otatara backup project, but the additional capacity afforded by the LV voltage limits increase (from 230V $\pm 6\%$ to $\pm 10\%$) has temporarily resolved this constraint. Further load growth is anticipated to erode this additional capacity over time.
- EIL will monitor growth and consider non-network solutions that may reduce cost for customers for other growth-driven projects as they arise.

7.2 Asset and Network Design

The design life cycle stage addresses the following aspects.

- Type of assets used on the networks.
- Network configuration.
- Interactions between various assets and asset systems on the network.
- Physical location of assets.

Design Phase Risks

The following risks are partially addressed in the design life cycle phase.

Table 58: Design Phase Risks

Category	Risk Title	Risk Cause	Risk Treatment Plan
Operational Performance - 1	Damage due to extreme Physical Event (i.e., Christchurch earthquake)	Damage caused by force majeure to our infrastructure or equipment (for example, floods, earthquakes)	Locating assets and networks to avoid high event probability areas. Design structures and buildings to cater for seismic events.
Network Performance	Failure of Asset Lifecycle Management	Mechanical or electrical failure, ineffective maintenance, ineffective fleet plans Budget constraints Lack of future network planning	Designs take maintenance and operations requirements into account. A lower equipment purchase price should not be cost of reliability and should not lead to increased maintenance requirements. Design takes asset retirement and disposal into account.
Network Performance	Intentional Damage	Terrorism, theft, vandalism	Asset and system design takes physical security into account.
Operational Performance	Unavailability of critical spares	Poor future work planning, high impact low probability events causing high spares usage. Supply chain disruptions	Designs are standardised to minimise stock levels and create interchangeability of assets.

Category	Risk Title	Risk Cause	Risk Treatment Plan
Operational Performance	Loss of key critical service provider	Economic environment, Lack of sufficient work to sustain contractors; unexpected inability of contractor to complete work, Major health event/pandemic	Standardised design does not lead to single supplier dependencies. A limited number of asset options are available. Designs can be implemented by any of several competent contractors.
Operational Performance	Major event triggering storm gallery activation	Damage caused by wind, snow, storm events	Design to reduce or eliminate faults due to inclement weather.
Health and Safety	Public meeting live assets	Unexpected public actions affecting our assets or asset integrity affects public safety	Safety in Design process takes public exposure to live equipment into account. Asset placement reduces public interaction with the assets. Any new assets are evaluated in terms of safety before they are approved for use on the network.
Environmental	Breaches of environmental legislation	Failure of assets, oil spill, bunding, hazardous goods breach	Design standards take environmental risk into account. Assets do not contain hazardous substances or hazardous substances are controlled.

Cost Efficiency

In the interests of cost efficiency, EIL aims to minimise capital expenditure and lifecycle cost when determining the most appropriate development option for the network. Being cost-efficient with network development requires a “just enough, just in time” approach for the determination of appropriate new capacity, and an appropriate level of standardisation. In future, demand management and flexibility services should be increasingly used to defer upgrades as an extension of this approach. Other works within the locale may be brought forward and combined to achieve economies of scale for design, safety, and traffic management costs.

Before capital-intensive upgrades are required, the following options, in a broadly descending order of preference, are considered when development triggers have been reached:

- Do nothing and simply accept that one or more parameters have exceeded a trigger point. Do nothing options would only be adopted if the benefit-cost ratios of all other reasonable options were unacceptably low and if assurance was provided to the Chief Executive that the do-nothing option did not represent an unacceptable increase in risk to EIL. An example of where a do-nothing option might be adopted is where the voltage at the far end of a remote rural feeder drops below the network standard minimum level for a short period at the height of the holiday season – the benefits of correcting such a constraint are simply too low to justify the expense.
- Operational activities, in particular switching on the distribution network to shift load from heavily loaded to lightly loaded feeders to avoid new investment or winding up a tap changer to mitigate a voltage problem. The downside to this approach is that it may increase line losses, reduce security of supply or compromise protection settings.
- Demand management using load control or using other methods to influence customers’ consumption patterns so that assets operate at levels below trigger points. Examples might be to shift demand to different time zones, negotiate interruptible tariffs with certain customers so that overloaded assets can be relieved or assist a customer to adopt a substitute energy source to avoid new capacity. EIL notes that the effectiveness of line tariffs in influencing customer behaviour is diminished by the retailer’s practice of repackaging fixed and variable charges.
- Install generation or energy storage units so that an adjacent asset’s performance is restored to a level below its trigger points. These options would be particularly useful where additional capacity could eventually be stranded or where primary energy is going to waste e.g., waste steam from a process.
- Modify an asset so that the asset’s trigger point will move to a level that is not exceeded e.g., by adding forced cooling. This approach is more suited to larger classes of assets such as power transformers. Installation of voltage regulating transformers may be economic where voltage drops below acceptable levels, but current

capacity is not fully utilised.

- Retrofitting high-technology devices that can exploit the features of existing assets including the generous design margins of old equipment. An example might include using advanced software to thermally re-rate heavily loaded lines, using remotely switched air-break switches to improve reliability or retrofit core temperature sensors on large transformers to allow them to operate closer to temperature limits.

Installing new or greater capacity assets is generally the next step to increase asset capacity to a level at which the relevant trigger point is not exceeded. An example would be to replace a 200 kVA distribution transformer with a 300 kVA unit so that the capacity criterion is not exceeded.

For meeting future demands for capacity, reliability, security, and supply quality there may be several options within the above range of categories and identifying potential solutions is dependent on the experience and ingenuity of the engineers undertaking the planning.

Standardisation

Standardisation is an important strategy used by EIL to achieve cost efficiencies. It may not always be obvious that standardisation achieves this outcome; standardised equipment sizes will often mean larger equipment is used than would otherwise be strictly necessary. However, standardising assets allows efficient management of stock and spares, operator familiarisation, standardisation of operation procedures, and simplified selection of equipment and materials. Standardised designs or design criteria also avoid “reinventing the wheel”, simplifies the design process, and can incorporate more learnings than could otherwise not be practically managed. The benefits of standardisation easily outweigh the oversizing of assets where significant repetition of a particular network solution occurs.

PowerNet’s Quality Systems (policies, standards, and procedures) provide for the documentation and communication of the standards that are applied to EIL’s network. EIL benefits from their close working relationship with the other line owners whose networks are managed by PowerNet, with the standardisation able to be maintained across networks for increased efficiencies. Examples include the keeping of critical spares, which can be more efficiently achieved when shared across the combined network’s asset base; or lessons learnt on one network that can be incorporated into standards which then benefit the other networks. Standardised design is used for line construction with a construction manual and standard drawings in use by planners, designers, and construction staff.

Standardised designs for projects may be used from time to time where projects with similarities occur within a short enough period. Though these opportunities do not arise often on EIL’s network, similar projects are often managed by PowerNet on other networks and where project scopes overlap design “building blocks” may be utilised in several designs. Through this approach a degree of standardisation is achieved, with each consecutive design utilising these building blocks from the latest previous design. Continuous improvement is realised with lessons learnt able to be incorporated at each iteration.

Virtually all of the EIL network assets are standardised to some degree either by being an approved network material or asset type or by selection and installation in line with network standards. Examples of standardisation are listed below.

Table 59: Equipment Standardisation

Component	Standard	Justification
Underground Cable	Distribution and LV network: 35, 95, 185 & 300 mm ² Al	Stocking of common sizes, lower cost
	11 kV Cable Cross-linked Polyethylene (XLPE)	Rating, ease of use.
Overhead Conductor	Sub transmission and distribution: All aluminium alloy conductor (AAAC) - Chlorine, Helium, Iodine, Neon or	Low corrosion, low resistance, cost, stocking of common sizes
	Aluminium conductor steel reinforced (ACSR) – Flounder, Wolf	Higher strength (longer spans, snow load)
	LV Aerial Bundled Cable (ABC): 35, 50 & 95 mm ² Al (four core).	Safety, lower cost.
Structures	Poles: Busck pre-stressed concrete	Consistent performance, long life, strength
	Cross-arms: Solid hardwood	Long life, strength.

Component	Standard	Justification
Line equipment	Standard ratings (e.g., ABS 400 A, field circuit breaker 400 A), manufacturer/type	Cover-all specification, minimise spares, familiarity, environmental (non SF6)
Power Transformers	Discrete ratings, tap steps, vector group, impedance, terminal arrangements etc.	Ratings match available switchgear ratings, interchangeability, network requirements.
33 kV & 11 kV Switchboards	Common manufacturers, common specification.	Interchangeability spares management.
Protection and Controls	Common manufacturer, communications interface, supply voltage etc.	Minimise spares, familiarity, proven history
Substation equipment	Standard ratings, equipment type, manufacturer etc.	Minimise spares, familiarity, proven history
Distribution Transformers	Standard ratings (residential areas - size based on domestic customer numbers), equipment type, manufacturer etc.	Minimise spares, familiarity, proven history, cover-all specification.
Ring Main Units	Standard ratings, equipment type, manufacturer etc.	Minimise spares, familiarity, proven history, cover-all specification.

Security

Security is the level of redundancy that is built into the network to provide improved continuity of supply when faults occur. It enables supply to be either maintained or restored independently of repairing or replacing a faulty component. EIL's security standard is therefore crucial for the maintenance of network reliability levels. Security involves a level of investment beyond what is strictly required to meet demand, but maintenance of the desired security level must account for demand growth eroding surplus capacity. Typical approaches to providing security include the following.

- Provision of Alternative Supplies.** This is achieved by providing one or more inter-feeder tie switches (interconnection points). Urban areas can naturally achieve a high level of meshing with many tie points between feeders whereas rural area feeders may need significant line extension to meet adjacent feeders. Feeders are generally designed to be able to offload the full feeder load during a fault scenario. Exceptions are the limited number of radially fed customers. The number of switches effectively dividing up a feeder also contributes to security, with the greater the number, the smaller the section which must be isolated after a fault for the duration of the repair. This requires those adjacent feeders to maintain spare capacity.
- Duplication of Assets.** In normal service both sets of assets share the load. When a duplicated asset malfunctions it can be isolated, and all loads can be transferred to the remaining asset. This approach generally provides the greatest security as it can completely prevent interruption to supply; but duplication of assets tends to be more expensive than merely allowing greater capacity in existing adjacent circuits.
- Generation.** This can be used to either provide an alternate supply, or to partially supplement supply and reduce capacity requirements for backup assets. From a security perspective, generation needs to have close to 100% availability to be of benefit. Diesel generation has good availability and is used occasionally to manage network constraints, although it is too expensive to run for extended periods. Other forms of generation such as run-of-the-river hydro, wind or solar, do not provide the needed availability due to lack of energy storage and so cannot be relied on to respond to varying load or provide sufficient generation during peak demand periods.
- Demand Management.** Use of demand management (interruptible load) can be used to avoid security triggers based on load level or avoid capacity of backup assets being exceeded.

The preferred means of providing security to urban zone substations will be by secondary sub transmission assets with any available back-feed on the 11 kV providing an extra level of security.

The following table summarises the security standards adopted by EIL. An exception to these standards occurs when a substation is for the predominant benefit of a single customer; in this case the customer's preference for security will be documented in their individual line services agreement and will set the minimum-security level.

Table 60: Target Security Levels

Description	Load Type	Security Level
AAA	Greater than 12 MW or 6,000 customers.	No loss of supply after the first contingent event.
AA	Between 5 and 12 MW or 2,000 to 6,000 customers.	All load restored within 25 minutes of the first contingent event.
A(i)	Between 1 and 5 MW	All load restored by isolation and back-feeding. Isolated section restored after time to repair.
A(ii)	Less than 1 MW	All load restored after time to repair.

The current security levels for zone substations are displayed in the next table.

Table 61: Security Levels for Zone Substations

Substation	Current Security Level	Required Security Level	Remarks
Spey Street	AAA	AAA	Dual 33kV transformer feeders from Invercargill GXP.
Leven Street	AAA	AAA	Short interruption required to switch to alternative supply from another GXP*
Southern	AA	AAA	Short interruption required to switch to alternative supply
Racecourse Road	AA	AA	Single transformer feeder from Invercargill GXP. Short 33kV cable. Alternative supply from 11kV back feed.
Bluff	AAA	AA	More economic to provide AAA security at the site, due to the lack of 11 kV backup capacity.

* The substation itself has full redundancy. However the two infeeds are from different GXPs so to avoid paralleling the GXPs on 33kV, a “break before make” system is in place.

Capacity Determination

When new or increased capacity has been determined as necessary the amount of new capacity must be quantified. Appropriate asset sizing is balanced to fit within EIL’s guiding principle, which is to minimise the long-term cost to provide service of sufficient quality under foreseeable demand.

Sizing network equipment carries an investment risk for assets being underutilized if not done correctly. While sizing a particular asset for the present time is relatively straightforward, load growth makes appropriately sizing an asset more difficult, especially for asset lifetimes over periods of high growth and growth unpredictability. Installing assets with too much spare capacity means an over-investment; however, if assets are undersized, the asset will need to be replaced early before their natural end of life. In many cases, standardization will limit the options available to assist capacity selection. In general, this will mean balancing over-investment, and under-investment will result in a small amount of over-investment (i.e., increased capacity). However, this is considered optimal due to the often-marginal cost of increased capacity versus the significant cost of re-work should the investment be under-sized.

Stranding of assets is a risk where new assets are required to supply one (or few) new customers representing the worst case in overinvestment if the expected growth does not eventuate. This stranding risk is particularly significant when network extension outside the existing network footprint is required. The assets are less likely to be reutilized if the expected load disappears. Stranding risk is generally managed through capacity guarantee contracts with customers to recover expected line charges if necessary.

Relocation of assets provides a way to manage costs efficiently while limiting exposure to the above risks in areas of growth. However, this strategy is only of benefit where the material cost dominates the installation cost of establishing an asset; the installation cost cannot be recovered. For example, once load grows to a power transformers capacity the transformer can be relocated and used elsewhere so that a larger unit may be installed in its place. In comparison a cable (where trenching and reinstatement dominates installation costs) would typically be abandoned and replaced.

Examples of criteria to determine capacity of equipment in line with the above considerations are as shown in the following table. Clearly understanding load growth into the future is crucial to making sound investment decisions.

Table 62: Capacity Selection Criteria

Network Asset	Capacity Criteria Selection	
Sub transmission network	Allow expected demand growth over life time of assets	
Power transformers	Allow expected demand growth over 20 years then relocate	
Switchgear	Allow expected demand growth over life time of assets	
Distribution and LV cables	Allow growth over expected life when known or otherwise 100% growth over existing load	
Overhead distribution and LV lines	Build to standard volt drop from nominal:	
	Urban	Rural
	11 kV: -3%	11 kV: -4%
	LV: -5%	LV: -4%
Distribution transformers	Size based on diversity and anticipated medium term load:	
	Domestic Customers	Transformer Size
	2	15 kVA
	6	30 kVA
	10	50 kVA
	20	100 kVA
	50	200 kVA
	80	300 kVA
	150	500 kVA
	Individual customers	Size to customer requirements

Best Option Identification

Of the many possible development options that may be identified for meeting demand and service levels, the possibility that best meets EIL’s investment criteria is determined using various analytical approaches. Each possible approach to meeting demand will contribute to strategic objectives differently. Increasingly detailed and comprehensive analytical methods are used for evaluating more expensive options.

The following table summarises the decision tools used to evaluate options depending on their cost.

Table 63: Cost-based Decision Tools

Cost & Nature of Option	Decision Tools	Approval Level
Up to \$75,000: commonly recurring, individual projects not tactically significant but collectively add up.	<ul style="list-style-type: none"> EIL standards. Industry rules of thumb. Manufacturer’s tables and recommendations. Simple spreadsheet model based on a few parameters. 	Project Manager & Network Engineer
\$75,000 to \$250,000: individual projects of tactical significance. Timing may be altered to allow resource focus on higher priority projects.	<ul style="list-style-type: none"> Spreadsheet model to calculate NPV that might consider one or two variation scenarios. Basic risk analysis including environmental and safety considerations. Consultation with stakeholders if necessary. 	GM Asset Management

Cost & Nature of Option	Decision Tools	Approval Level
\$250,000 to \$500,000: individual projects or programmes of tactical or strategic significance. Timing may or may not be flexible depending on priority.	<ul style="list-style-type: none"> • Extensive spreadsheet model to calculate NPV that may consider several scenarios. • Risk analysis including environmental and safety considerations with consideration to management cost. • Consultation with stakeholders if necessary. 	Chief Executive
Over \$500,000: occurs maybe once every few years, likely to be strategically significant. May divert resources from routine lower cost projects in the short term.	<ul style="list-style-type: none"> • Extensive spreadsheet model to calculate NPV, payback that will probably consider several variation scenarios. • Detailed risk analysis including environmental and safety considerations - represented as cost estimates within NPV and Payback calculations. • Resources (financial, workforce, materials, legal) across AWP need to be balanced across many projects and several years managed through planning meetings and spreadsheet models. • Ongoing stakeholder consultation may be required especially with large customers. • Business case presented to the Board, highlighting options considered and justification of recommended option. 	Board Approval

Prioritisation of Development Projects

Development projects are prioritized when competition for resources exists in managing conflicting stakeholder interests. Safety, viability, pricing, supply quality, and compliance are priorities for managing conflicts. EIL applies a multi-criteria assessment framework that assigns relative weightings to key risk, performance, and strategic factors, enabling consistent comparison of projects by assessing the severity, likelihood, customer impact, and long-term network implications of each driver. This approach ensures that resources are allocated to initiatives that deliver the greatest overall benefit to network safety, resilience, reliability, and stakeholder value, while maintaining alignment with EIL asset management objectives.

Electrification and Energy Efficiency

EIL strives to make decisions based on the best outcome for its customers; customers pay for losses on the network in their energy bills, so it is in the customer’s interest to deliver energy as efficiently as possible. However, from a customer’s cost-benefit point of view, the extra expense of a more efficient asset will generally outweigh the benefit of that asset. In the few cases where there is an economic justification to reduce losses in this way EIL will use these solutions, e.g., specifying low loss cores used in the magnetic circuits of transformers.

Power consumed by EIL and its organisational partners is used responsibly, with substation buildings and PowerNet’s office buildings heated using efficient heat pump technology, insulation, and draft control etc. where appropriate. EIL formed the Southland Warm Homes Trust (SWHT) in 2008 with the Southland Power Trust (TPCL’s shareholder). The SWHT works in partnership with government, the Energy Efficiency and Conservation Authority (EECA) and local funders to provide subsidies for insulation and heating assessments and retrofits for warmer, healthier homes across the Deep South region. PowerNet provides administration and financial reporting services on behalf of the SWHT.

The SWHT contracts Awarua Synergy to carry out assessments and the installation of insulation and heating products on behalf of the Trust. Under EECA’s Warm Up NZ Healthy Homes program which came into effect on 1 July 2013, insulation is free for eligible homeowners. Landlords with eligible tenants are also included but will be required to contribute. The Healthy Homes scheme targets those who stand to benefit most from having their homes insulated, those being low-income households with high health needs, including families with children and the elderly. EECA provides 50% of the funding conditional upon the remaining 50% funding coming from third party funders.

Distributed Generation

The value of distributed generation can be recognised in the following ways.

- Reduction of peak demand at the Transpower GXP.
- Reducing the effect of existing network constraints.
- Avoiding investment in additional network capacity.

- Making a very minor contribution to supply security where the customers are prepared to accept that local generation is not as secure as network investment.
- Making better use of local primary energy resources thereby avoiding line losses.
- Avoiding the environmental impact associated with large scale power generation.

It is also recognised that distributed generation can have the following undesirable effects:

- Increased fault levels, requiring protection and switchgear upgrades.
- Increased line losses if surplus energy is exported through a network constraint.
- Stranding of assets, or at least of part of an asset's capacity.
- Raising voltage above regulated levels.
- Can cause safety issues when the network de-energises a line to carry out work.

Despite the potential undesirable effects, the development of distributed generation that will benefit both the generator and EIL is actively encouraged. No distributed generators within EIL's network have an appreciable effect on development planning.

Terms and Conditions for Commercial Connections

- Connection of up to 10 kW of distributed generation to an existing connection to the network will not incur any additional line charges. Connection of distributed generation greater than 10 kW to an existing connection may incur additional costs to reflect network up-sizing.
- Distributed generation that requires a new connection to the network will be charged a standard connection fee as if it was a standard off-take customer.
- An application administration fee will be payable by the connecting party.
- Installation of suitable metering (refer to technical standards below) shall be at the expense of the distributed generator and its associated energy retailer.
- Any benefits of distributed generation that arise from reducing EIL's costs, such as transmission costs or deferred investment in the network, and provided the distributed generation is of sufficient size (greater than 10 kW) to provide real benefits, will be recognised and shared.
- Those wishing to connect distributed generation must have a contractual arrangement with a suitable party (retailer) in place to consume all injected energy – generators will not be allowed to "lose" the energy in the network.

Distributed Generation Safety Standards

- A party connecting distributed generation must comply with all safety requirements promulgated by EIL.
- EIL reserves the right to physically disconnect any distributed generation that does not comply with such requirements.

Distributed Generation Technical Standards

- Metering capable of recording both imported and exported energy must be installed if the owner of the distributed generation wishes to share in any benefits accruing to EIL. Such metering may need to be half-hourly.
- EIL may require a distributed generator of greater than 10 kW to demonstrate that operation of the distributed generation will not interfere with operational aspects of the network, particularly such aspects as protection and control.
- All connection assets must be designed and constructed to technical standards not dissimilar to EIL's own prevailing standards.

Use of Non-Network Solutions

EIL routinely considers a range of non-asset solutions and prefers solutions that avoid or defer new investment. Effectiveness of tariff incentives is lessened with Retailers repackaging line charges in ways that often remove the desired incentive. 'Use of System' agreements include lower tariffs for controlled, night-rate and other special channels. Load control is utilised for the following.

- Scheduled daily switching reduces network and GXP demand during peak times.
- Interruptible load is offered as instantaneous reserves in the ancillary services market with revenue returned to customers.
- Interruptible load may be redirected to support temporary constraints management or grid emergencies.

Load shedding may be used by some customers where they accept a reduction of their load instead of investing in additional network assets. This is generally done through a Special Protection Scheme (SPS).

Other low-cost solutions

Generators (owned by PowerNet) are used where appropriate for planned work on distribution transformers or LV network, to reduce the reliability impact of the work as a temporary solution during work execution. Other typical low-cost options include the following.

- Conductor upgrades.
- Voltage regulators.
- Pumps and fans on power transformers.
- Tie point shifts.

There are limits to the capabilities of low investment options to meet growth when the capacity margins are depleted or when demand is significant or occurring in large clusters.

Responses to the impact of Technology

Changes in markets, regulations, and customer behaviour create opportunities, but also complexities and risks for EIL. Responses to these potential impacts include the following.

- Implementing detailed demand data monitoring and analysis.
- Increasing cross-industry collaboration.
- Trialling new technology to have a better understanding of potential adoption and impact.
- Continuous improvement in communications with customers.

7.3 Asset Acquisition

During asset acquisition, designed assets are bought and installed. This phase often includes civil construction activities. The prevention and treatment of safety risks are paramount. This life cycle stage partially addresses the following risks.

Table 64: Acquisition Phase Risks

Category	Risk Title	Risk Cause	Risk Treatment Plan
Network Performance	Failure of Asset Lifecycle Management	Mechanical or electrical failure, ineffective maintenance, ineffective fleet plans, Budget constraints, Lack of future network planning	Ensure all new assets going onto the network are reliable – New Assets Process Manage the quality of work by contractors and own staff
Operational Performance	Damage due to extreme Physical Event (i.e., Christchurch earthquake)	Damage caused by force majeure to our infrastructure or equipment (e.g., floods, earthquakes)	Ensure all assets can withstand potential events they may be subject to. Construct all buildings and structures to be seismically compliant
	Major Contractual Breach	Breach of contractual obligations in place with key counterparties, resulting in legal action with potential serious financial implications and/or reputational damage	Use of standard, vetted contracts – NEC Contract and contractor management
	Unavailability of critical spares	Poor future work planning High impact low probability events causing high spares usage Supply chain disruptions	Ensure that any new assets are supported by a reputable supplier Procure strategic spares and parts when procuring the asset
	Loss of key critical service provider	Economic environment Lack of sufficient work to sustain Unexpected inability of contractor to complete work Major health event/pandemic	Improved identification of critical suppliers and contractors Identify alternative suppliers and contractors Internalise and grow internal workforce so that work can be executed internally
Health & Safety	Public coming into contact with live assets	Unexpected public actions affecting our assets or asset integrity affects public safety	Install barriers against inadvertent access to live assets
Environmental	Breaches of environmental legislation	Failure of assets, oil spill, bunding, hazardous goods breach	Construction methodologies employed cause no environmental harm

Installation of Assets

The drivers for the installation of an asset may change during the asset's operational life. In addition, the viability of maintaining or replacing an asset at end-of-life may also change. These drivers must be monitored beyond the installation process to ensure that the objective of providing an efficient and cost-effective service is achieved.

Standards are used to guide the construction and installation of regular assets such as a distribution transformer. However, complex assets (such as a zone substation) will require substantial design work before installation.

Equipment and materials are procured (per the relevant design or standard) and implemented according to EIL's standardization requirements.

Post-installation, the commissioning process follows. This process is either specified in the design or (for standardized installations) in a commissioning checklist. The purpose is to ensure the asset has been installed and will function as intended prior to putting it into service.

Asset Replacement and Renewal

Replacement and renewal programmes aim to get the full benefit of assets by replacing them near their economic end-of-life. This is balanced by the need to manage workforce resources in the short term and the delivery of desired service levels over the long term.

Inspection and testing programmes identify assets reaching end-of-life, while critical assets may be replaced on a fixed-time basis. For example, 11kV switchboards at zone substations are generally replaced at the end of their nominal year life. Less critical assets or assets provided with redundancy (as part of security arrangements) may be run to failure and replaced reactively. Assets such as cables may be run to failure several times and repaired before the fault frequency increases to the point that complete replacement is more economic. This approach requires monitoring failure rates.

Apart from whole-of-life cost analysis, several other replacement drivers include operational/public safety, risk management, declining service levels, accessibility for maintenance, obsolescence, and new technology. Some of these may be diminished through cost analysis. The network development driver might also impact asset replacement requirements.

Innovations That Defer Asset Replacement

Although asset age is taken into account in any replacement decision, asset condition is the main driver. There are several innovations used for condition assessment that potentially could defer asset replacement. These include the following.

- Thermal (infrared) and partial discharge (Corona) camera inspections of zone substation equipment.
- Mid-life refurbishment of power transformers.
- Dissolved Gas Analysis (DGA) of large distribution transformers.
- Thor hammer analysis of poles.
- Automation of switchgear to enable faster restoration in the event of faults.

The decision-making approach for replacements or renewals applicable to each network asset category is provided below.

Table 65: Replacement and Renewal Decisions per Asset Category

Asset Category	Subcategory	Replacement & Renewal Decision Approach
Subtransmission	O/H	Reactive replacements after failure due to external force. Poles replaced when structural integrity indicated as low by pole scan or visual inspection. Generally, poles, cross arms, pins, insulators, binders and bracing etc. replaced when inspection indicates deterioration that could cause failure prior to next inspection and maintenance is uneconomic. Conductor replaced when reliability declines to an unacceptable level or repairs become uneconomic.
	U/G	XLPE cables replaced when reliability declines to an unacceptable level or repairs become uneconomic. Oil cables may be damaged beyond economic repair depending on nature of failure.
	Distributed Subtransmission Voltage (ABSs)	Replacement if inspection/operation indicates deterioration sufficient to lose confidence in continued reliable operation and maintenance is considered uneconomic

Asset Category	Subcategory	Replacement & Renewal Decision Approach
Zone Substations	Subtransmission Voltage Switchgear	<p>Replaced at end of standard life (fixed time), may be delayed in conjunction with condition monitoring to achieve strategic objectives.</p> <p>Significant damage from premature failure could require replacement.</p>
	Power Transformers	<p>Major refurbishment for transformers is undertaken when units reach half of their expected life.</p> <p>Replaced after failure causing significant damage that is not economic to repair; most units will be allowed to run to failure to utilise entire lifespan unless failure risk is unacceptable.</p> <p>May be replaced if tank and fittings are deteriorating, spare parts are unavailable and not economic to maintain for aged units.</p> <p>May be scrapped if not economic to relocate (transport and installation costs) after aged transformers displaced e.g., for a larger unit.</p> <p>Paper, Furan and/or DGA analysis used to indicate insulation remaining life.</p>
	Distribution Voltage Switchgear	<p>Replaced at end of standard life (fixed time), may be delayed in conjunction with condition monitoring to achieve strategic objectives.</p> <p>Significant damage from premature failure could require replacement.</p>
	Other (Buildings, RTU, Relays, Batteries, Meters)	<p>Instrumentation/Protection at end of manufacturers stated life (fixed time) or when obsolete/unsupported or otherwise along with other replacements as economic e.g., protection replaced with switchboard or transformer.</p> <p>Batteries replaced prior to the manufacturers stated life expectancy (typically 10 years) or on failure of testing.</p> <p>Buildings and fences when not economic to maintain after significant accumulating deterioration or seismic resilience concerns.</p> <p>Bus work and conductors not economical to maintain.</p>
Distribution Network	O/H	<p>Reactive replacements after failure due to external force.</p> <p>Poles replaced when structural integrity indicated as low by pole scan or visual inspection.</p> <p>Generally, poles cross arms, pins, insulators, binders and bracing etc. replaced when inspection indicates deterioration that could cause failure prior to next inspection and maintenance is uneconomic.</p> <p>Conductor replaced when reliability declines to an unacceptable level or repairs become uneconomic.</p>
	U/G	<p>XLPE or paper lead cables replaced when reliability declines to an unacceptable level or repairs become uneconomic.</p>
	Distributed Distribution Voltage Switchgear	<p>Replaced at end of standard life (fixed time), may be delayed in conjunction with condition monitoring to achieve strategic objectives.</p> <p>Significant damage from premature failure could require replacement.</p>

Asset Category	Subcategory	Replacement & Renewal Decision Approach
Distribution Substations	Distribution Transformers	<p>Replaced if rusting is advanced or other deterioration/damage is significant and maintenance becomes uneconomic.</p> <p>Otherwise, units generally run to failure but transformers supplying critical loads may be replaced early based on age or as part of other replacements at site.</p> <p>Units removed from service <100 kVA and older than 20 years are scrapped; otherwise, units testing satisfactory recycled as stock.</p>
	Distribution Voltage Switchgear (RMUs)	<p>Replaced at end of standard life (fixed time), may be delayed in conjunction with condition monitoring to achieve strategic objectives.</p> <p>Significant damage from premature failure could require replacement.</p>
	Other	<p>Instrumentation/Protection at end of manufacturers stated life (fixed time) or when obsolete/unsupported or otherwise along with other replacements as economic e.g., protection replaced with switchboard or transformer.</p> <p>Batteries replaced prior to the manufacturers stated life expectancy (typically 10 years) or on failure of testing.</p> <p>Enclosures not economic to maintain after significant accumulating deterioration or seismic resilience concerns.</p>
LV Network	O/H	<p>Reactive replacements after failure due to external force.</p> <p>Poles replaced when structural integrity indicated as low by pole scan or visual inspection.</p> <p>Generally, poles cross arms, pins, insulators, binders and bracing etc. replaced when inspection indicates deterioration that could cause failure prior to next inspection and maintenance is uneconomic.</p> <p>Conductor replaced when reliability declines to an unacceptable level or repairs become uneconomic.</p>
	U/G	<p>Generally, run to failure. Replaced when condition declines to an unreliable level e.g., embrittlement of insulation.</p>
	Link and Pillar Boxes	<p>Replaced if damaged or deterioration is advanced and could lead to failure before next inspection (or if public safety concerns exist).</p>
Other	SCADA & Communications	<p>RTUs or radios at end of manufacturers stated life (fixed time) or when obsolete/unsupported or otherwise along with other replacements as economic.</p>
	Earths	<p>Replaced when inspections find non-standard arrangements, deteriorated components or test results are not acceptable.</p>
	Ripple Plant	<p>Becoming obsolete as smart meters are installed across the network. Run to failure but security provided by backup plant.</p>

Non-routine Replacement and Renewal Projects

Replacement and renewal projects that are one-off and underway or planned are described in the following tables. These projects often represent significant assets that have reached end of life or another significant milestone. Some projects may target several assets of similar age that will be replaced or renewed as part of short- or medium-term programme.

Table 66: Non-routine Replacement & Renewal Projects (next 12 months)

Project Description	25/26 CAPEX Cost
Nil	

Table 67: Non-routine Replacement & Renewal Projects (next four years)

Project Description	CAPEX Cost & Timing
<p>Power Transformer Refurbishment: Refurbishment is aimed at extending the expected life of transformers; the resulting deferral of replacements will achieve cost efficiencies in maintaining service for EIL's customers.</p> <p>Three of EIL's 23MVA zone substation transformers are beyond their midlife and un-refurbished. However, the ex-Doon Street transformer which is to be relocated to Southern substation will not be refurbished. Furan and paper sample analysis show that this unit's insulation is consistent with its age and therefore the cost of refurbishment is considered uneconomic given the likely level of remaining life that can be achieved.</p> <p>Refurbishment of the other two transformers has been deferred to best manage capital investment limits. The older of the Leven Street units was scheduled for refurbishment in 2026/27. The refurbishment will only be done if condition assessments show they are required.</p>	\$583,582
<p>Racecourse Road Switchboard Replacement: The 11 kV switchboard at Racecourse Road substation consisting of 12 circuit breaker cubicles will reach the end of its nominal life in 2020/21. Its replacement is scheduled for 2026 - 2028 with design costs allowed for in 2024/25. This is a deferment from 2020/21 to allow for replacement of RMUs at higher risk of failure.</p> <p>There is a consistent level of partial discharge suspected to be from a few cable boxes and CTs. Repair will be attempted in the intervening years till replacement. Risks associated with continued operation of the 11 kV switchboard near end of expected life are being mitigated by regular condition monitoring of the switchgear and the installation of on-line partial discharge monitors.</p>	\$3,911,199
<p>RMU Replacements: EIL's Ring Main Unit (RMU) replacement programme had been curtailed in recent years, as limited resources have been directed at the higher priority underground substations and link box replacement programmes.</p> <p>A specific brand of Ring Main Unit has had some catastrophic failures on the EIL network and in other EDBs. The increased provision in the first three years of spend is to accelerate the replacement of these units.</p> <p>Over 15% of EIL's fleet of RMUs is aged beyond industry good practice, and an operational risk analysis shows mid-level risk factors that are beyond EIL's normal tolerance for risk.</p> <p>While investment will be required to fully restore the RMU fleet to acceptable levels, some individual units present a disproportionate level of risk, mainly due to their location. The riskiest RMU sites will be targeted initially. Beyond 2021, the budget is increased to aggressively replace these RMU's.</p> <p>This programme has been reduced to manage capital limits.</p>	\$10,608659

Project Description	CAPEX Cost & Timing
<p>Fibre Installation: Control and monitoring of Leven St zone substation is currently via a single communications circuit tee-d off from the Invercargill GXP - Spey St zone substation communication circuits. The single communications circuit to Leven St zone substation crosses areas that are prone to being damaged by incidental civil works.</p> <p>This project is to install new optical fibre between the communications network gaps. This will complete the second communications circuit between the GXP and Leven St zone substation.</p> <p>This reduces the risk of communications and protection failure of the sub transmission supply to the CBD, and will allow faster protection, greater visibility, and enable future automation within the CBD distribution grid.</p> <p>External parties may have projects involving trenching along part of the proposed route in 2022-2023. PowerNet and those parties will discuss opportunities to share the trench, reducing trenching and reinstatement costs for both parties.</p>	\$200,840

The non-routine replacement and renewal projects that are under consideration for the remainder of the planning period are described in the following table.

Table 68: Non-routine Replacement & Renewal Projects (under consideration)

Project Description	CAPEX Cost & Timing
<p>Condition-Based Replacements and Renewals: This budget is an estimate of costs for projects that are yet unknown but from experience are considered likely to arise in the longer term (six-to-ten-year time frame). Certainty for these estimates is quite low. However, with EIL's current demand growth and asset age profile, the bulk of this expense is considered most likely to occur in the Asset Replacement & Renewal category. Other drivers include premature failures, or greater than expected deterioration of asset condition.</p>	No provision

Ongoing Replacement and Renewal Programmes

Ongoing work that tends to recur year after year and can be capitalised, are funded from the remaining replacement and renewal budgets. These budgets are listed and described below with the associated capital expenditure estimates.

Table 69: Ongoing Replacement & Renewal Programmes

Budget	Description	CAPEX Cost
Link Box Replacement	On-going replacement of above ground link boxes, beyond the priority replacement of the underground link-boxes described above, which have deteriorated with age or have been damaged and are unfit for service/unsafe.	\$115,076 p.a.
Zone Substation Minor Replacement	On-going replacement of minor components at zone substations such as LTAC panels and battery banks.	\$11,190 p.a.
Transformer Replacement	On-going replacements of distribution transformers which are generally identified during distribution inspections and targeted inspections based on age. Some removed units are refurbished for use as spares.	\$1,146,757
RMU Replacements	On-going replacement of Ring Main Units as they reach end of life and risk of failure increases.	\$3,110,579p.a.
Reactive 11 kV Cable Replacement	On-going reactive replacement of 11 kV cables as identified by condition after fault occurrence.	\$43,405 p.a.
Planned 11 kV Cable Replacement	An ongoing programme to proactively identify and replace 11 kV cables as they reach their economic end of life rather than continue to repair old cables beyond this point.	\$756,243 '26/27

Budget	Description	CAPEX Cost
General Distribution Replacement	On-going replacements of distribution assets other than cables. These are identified through routine inspection.	\$304,385 p.a.
LV Board Replacement	Replacement of hazardous old LV distribution boards with modern touch safe boards – on-going for 10 years.	\$40,430 p.a.
Pillar Box Replacement	On-going replacement of pillar boxes which have deteriorated with age or have been damaged and are unfit for service or unsafe.	\$94,031 p.a.
LV Cable Replacement	On-going replacement of LV cables as by age with coincident works on underlying 11 kV cable, or as they reach their economic end of life rather than continue to patch repair old cables beyond this point.	\$43,552p.a.
Distribution line replacement	On-going replacement of conductors and poles in city and Bluff due to high wind loading and marine corrosion.	\$207,230 p.a.

Asset Relocations

The following are drivers for asset relocations.

- Change in capacity requirements – move an asset that is under capacity or underutilised to a more suitable position and install a new asset in its place.
- Relocate assets due to redevelopment of the area where they are e.g., Stead St stop bank, paid for by the developer.
- Customer requests – paid for by customer.
- Changes in the risk profile.

Quality of Supply Improvements

By reducing the number of unplanned interruptions and their frequency, the impact of SAIDI and SAIFI is limited. The following quality of supply improvements are implemented.

- More control points – segmentation of the network.
- Automation e.g., reclosers.
- Remote control.
- Fault Indicators.

7.4 Commissioning of Assets

The commissioning life cycle phase addresses the following aspects, and risks are presented in the next table.

- Ensuring that the assets or asset systems functionally deliver to the design specifications.
- System integration – ensuring that the new assets integrate with the existing assets and networks.
- Communication between the new assets and the control systems.
- Documenting the asset characteristics such as capacity, settings, as-built drawings, maintenance requirements, location, test results etc.
- Updating the AMIS and SCADA system to reflect the new asset.
- Training of staff on the maintenance and operation of the equipment.

Table 70: Commissioning Phase Risks

Category	Risk Title	Risk Cause	Treatment Plan
Network Performance	Failure of Asset Lifecycle Management	Mechanical or electrical failure, ineffective maintenance, ineffective fleet plans Budget constraints Lack of future network planning	System integration is tested Asset characteristics and maintenance requirements are captured in the information systems
	Operational systems failure due to breakdown in telecommunications	SCADA communications has one centralised communications point that all information is passed through.	Testing the communication between the new assets and the control systems

7.5 Retiring and Disposal of Assets

Retiring of assets generally involves de-energising the asset and disconnecting it from the network before removal from site or abandoning in-situ (typical for underground cables). The following risks are addressed in this life cycle stage.

Table 71: Retiring Phase Risks

Category	Risk Title	Risk Cause	Treatment Plan
Network Performance	Failure of Asset Lifecycle Management	Mechanical or electrical failure, ineffective maintenance ineffective fleet plans Budget constraints Lack of future network planning	Assets are removed from the network when they start to affect reliability
Network Performance	Loss of right to access or occupy land	Risk of assets losing / not having the right to occupy particular locations (e.g., Aerial trespass, subdivision)	Historical land use rights are formalised should the land be required for the installation of new assets.
Operational Performance	Unavailability of critical spares	Poor future work planning High impact low probability events causing high spares usage Supply chain disruptions	Where practical, removed assets or asset components are kept being utilised in the repair of existing assets.
Environmental	Breaches of environmental legislation	Failure of assets, oil spill, bunding, hazardous goods breach	Assets containing hazardous materials are identified and disposed of using national and international guidelines

Removed assets will be eliminated from the regulatory asset base and need to be disposed of in an acceptable manner particularly if they contains SF6, oil, lead, or asbestos. Key criteria for retiring an asset includes the following.

- It is no longer required, usually because a customer has reduced or ceased demand.
- It creates an unacceptable risk exposure, either because its inherent risks have increased over time or because emerging trends of safe exposure levels are declining. Assets retired for safety reasons will not be re-deployed or sold for re-use.
- There are no suitable opportunities for re-deployment after an asset has been replaced to increase capacity or where more economic options exist to create similar outcomes e.g., new technology offers a low-cost maintenance free replacement.
- It is uneconomic to maintain the asset and more cost effective to replace it.
- The asset has reached end-of-life.

7.6 Capital Expenditure Forecast

The CAPEX forecast in the AMP is based on historical costs, supplier quotes, and benchmarking across similar asset classes. Estimates are categorized as firm, indicative, or preliminary depending on project stage, with risks and uncertainties addressed through contingencies and scenario analysis. Key assumptions and sensitivities are documented to ensure transparency and support informed decision-making.

Asset class replacement profiles and strategies are maintained, including expected service life, replacement triggers, inspections, and approaches such as proactive renewal or run to failure. For run-to-failure assets, cost projections are conducted using historical performance, and maintenance data, allowing us to estimate financial impacts, prioritize critical assets, and ensure CAPEX forecasts reflect both planned and unplanned replacements.

The capital expenditure forecast is presented in the following table and provided in the Information Disclosure Schedule 11a.

Table 72: Capital Expenditure Forecast (\$000 - constant 2026 dollars)

Category	DPP4					DPP5					DPP6
CAPEX: Consumer Connection	2025/2026	2026/2027	2027/2028	2028/2029	2029/2030	2030/2031	2031/2032	2032/2033	2033/2034	2034/2035	2035/2036
Customer Connections (≤ 20 kVA)	77	78	78	78	78	78	78	78	78	78	78
Customer Connections (21 to 99 kVA)	68	70	70	70	70	70	70	70	70	70	70
Customer Connections (≥ 100 kVA)	154	155	155	155	155	155	155	155	155	155	155
Distributed Generation Connection	3	4	4	4	4	4	4	4	4	4	4
New Subdivisions	0	0	0	426	529	394	394	394	394	394	426
Bluff LV Service Lines	0	0	0	0	0	0	283	0	0	0	0
	850	307	307	733	836	701	983	701	701	701	733

CAPEX: System Growth	2025/2026	2026/2027	2027/2028	2028/2029	2029/2030	2030/2031	2031/2032	2032/2033	2033/2034	2034/2035	2035/2036
Doon Street Reconfiguration	0	0	0	0	0	704	0	0	0	0	0
New SOU CB11 & 11kV feeder to Rockdale Subdivision	0	0	0	0	0	409	409	409	136	0	0
	0	0	0	0	0	1,113	409	409	136	0	0

CAPEX: Asset Replacement and Renewal	2025/2026	2026/2027	2027/2028	2028/2029	2029/2030	2030/2031	2031/2032	2032/2033	2033/2034	2034/2035	2035/2036
Link Box Replacement	111	115	115	115	115	115	115	115	115	115	115
Power Transformer Refurbishment	0	0	0	584	0	0	0	0	0	0	0
Racecourse Road Switchboard Replacement	0	2,088	1,824	0	0	0	0	0	0	0	0
Zone Substation Minor Replacement	11	11	11	11	11	11	11	11	11	11	11

SECTION 7 Capital Expenditure

Transformer Replacement	1,103	1,147	1,147	1,083	1,083	1,083	1,083	1,083	1,083	1,083	1,083
RMU Replacements	2,923	3,111	2,902	2,615	1,981	1,981	1,981	1,981	2,902	2,902	2,902
Reactive 11 kV Cable Replacement	41	43	43	43	43	43	43	43	43	43	43
Planned 11 kV Cable Replacement	724	756	756	756	756	756	756	1,319	1,829	1,829	2,088
General Technical Replacement	0	0	0	0	0	0	0	0	52	52	52
General Dist Replacement	298	304	304	304	304	304	304	304	304	304	304
LV Board Replacement	39	40	40	40	40	40	40	40	40	40	40
Pillar Box Replacement	92	94	94	94	94	94	94	94	94	94	94
LV Cable Replacement	43	44	191	191	191	191	191	191	191	191	191
Unspecified Asset Replacement & Renewal Projects	0	0	0	432	432	432	432	432	432	432	432
Distribution Line Replacement	199	207	77	77	77	77	77	77	77	77	77
Leven St 11kV Switch-board Replacement	0	0	0	456	2,319	858	0	0	0	0	0
Power Transformer Replacement - Southern Substation T2	0	0	0	0	0	0	0	1,661	0	0	0
	5,582	7,960	7,506	6,802	7,448	5,987	5,129	7,405	7,175	7,175	7,434

CAPEX: Asset Relocations	2025/2026	2026/2027	2027/2028	2028/2029	2029/2030	2030/2031	2031/2032	2032/2033	2033/2034	2034/2035	2035/2036
Asset Relocation Projects	7	8	8	8	8	8	8	8	8	8	8
	7	8	8	8	8	8	8	8	8	8	8

CAPEX: Quality of Supply	2025/2026	2026/2027	2027/2028	2028/2029	2029/2030	2030/2031	2031/2032	2032/2033	2033/2034	2034/2035	2035/2036
Supply Quality Upgrades	18	19	19	19	19	19	19	19	19	19	19
Network Automation Projects	39	41	41	41	41	41	41	41	41	41	
Fault Indicator project	118	54	54	0	0	0	0	0	0	0	0
	175	114	114	60	60	60	60	60	60	60	19

CAPEX: Other Reliability, Safety and Environment	2025/ 2026	2026/ 2027	2027/ 2028	2028/ 2029	2029/ 2030	2030/ 2031	2031/ 2032	2032/ 2033	2033/ 2034	2034/ 2035	2035/ 2036
Earth Upgrades	206	77	77	77	77	77	77	77	77	77	77
Pillar Box Lid Upgrade	149	159	159	159	159	159	159	159	159	159	159
Oil-Filled Cable Work	0	0	673	0	0	3,062	4,169	0	0	0	0
LV Tie Point Disconnectors	283	284	284	284	284	284	284	284	284	284	284
Fibre Installation	48	50	50	50	50	50	50	50	50	50	
	558	570	1,244	570	570	3,632	4,740	570	570	570	520
Total Network CAPEX	7,301	8,960	9,178	8,173	8,922	11,501	11,329	9,152	8,649	8,513	8,714

Values Fully Marked Up, No Inflation, Base Year dollars.



8

Operating Expenditure

SECTION CONTENTS

8	Operating Expenditure.....	146
8.1	The Operation and Maintenance Lifecycle Phase.....	146
8.2	Asset Maintenance.....	148
8.3	Asset Operation.....	155
8.4	Operational Expenditure Forecast.....	157

Otakaro Park, Invercargill

8 OPERATING EXPENDITURE

Our OPEX programme supports risk management, maintenance and inspection processes, and operations aspects of O&M such as control room functions and service restoration.

Operating Expenditure (OPEX) is required to operate and maintain EIL's networks. This section describes our planned operating expenditure for the next ten years and applies the operate & maintain (O&M) lifecycle stage of our asset management model.

When identifying operating expenditure initiatives we pursue the following objectives.

- Comply with customer obligations and service standards.
- Maintain the safety of the distribution system.
- Assets are operated and maintained in a manner that minimises system life cycle cost with due consideration of risk.
- Electricity delivery networks and associated electrical systems are maintained in way that meets the requirements of customers, internal stakeholders and relevant legal authorities, at minimum life cycle cost.

8.1 The Operation and Maintenance Lifecycle Phase

The Operations and Maintenance (O&M) lifecycle phase starts once the assets have been commissioned and are handed over to the Operations Unit. This is the stage where the majority of lifecycle expenditure occurs. The physical assets are expected to perform their function at specified performance and reliability levels.

Continuous improvement of O&M activities is a key component of the asset management process as O&M practices can significantly impact asset lifecycle costs, management of risk and service delivery performance. The way that an asset is operated and maintained directly determines the performance, reliability and life expectancy of the asset.

O&M Phase Risks

Expenditure on maintenance and inspections is prioritised using a structured risk and condition-based approach. Each asset and activity is assessed for the likelihood and consequence of failure, considering impacts on operational performance, network reliability, safety, and regulatory compliance. High-risk assets are scheduled for proactive maintenance and inspection, while lower risk assets are monitored or addressed as required. This prioritisation is integrated into Maximo to optimise resource allocation, ensure efficient execution, and provide traceability of expenditure decisions. Risk assessments and priorities are reviewed regularly to reflect changes in asset condition, operational experience, and emerging risks.

The following risks are addressed during the O&M phase.

Table 73: Operation & Maintenance Phase Risks

Category	Risk Title	Risk Cause	Treatment Plan
Operational Performance	Damage due to extreme Physical Event (i.e., Christchurch earthquake)	Damage caused by force majeure to our infrastructure or equipment (e.g., floods, earthquakes)	Structures are inspected and maintained to retain structural functionality
Network Performance	Failure of Asset Lifecycle Management	Mechanical or electrical failure, ineffective maintenance ineffective fleet plans Budget constraints Lack of future network planning	Asset fleet plans outlining the maintenance actions for each type of asset is being incorporated into the AMIS (Maximo) Maintenance execution is being managed to ensure all assets are maintained Operating instructions and manuals are accessible to ensure assets are operated correctly
	Operational systems failure due to breakdown in telecommunications	SCADA communication has one centralised communications point that all information is passed through.	Regular testing of the telecommunications systems
	Intentional Damage	Terrorism, theft, vandalism Reputation	Programme to replace locks and improve security
Operational Performance	Unavailability of critical spares	Poor future work planning High impact low probability events causing high spares usage Supply chain disruptions	Spares will be recorded in Maximo Education of staff on spares process and locations
	Loss of key critical service provider	Economic environment Lack of sufficient work to sustain viable operations Unexpected inability of contractor to complete work Major health event/pandemic	Improved identification of critical suppliers Identify alternative suppliers Grow the capabilities of the internal workforce
	Major event triggering CIMS activation	Damage caused by wind, snow, storm events	Monitor developing weather Ensure people, vehicles, equipment, and spares are on call and/or available during storm events
Health & Safety	Public coming into contact with live assets	Unexpected public actions affecting our assets or asset integrity affects public safety	Access prevention barriers are treated as assets and maintained to be in good condition
Regulatory Change & Compliance	Major legislative breaches	Failure to meet legal obligations, for example: <ul style="list-style-type: none"> • Obligation to supply electricity • Price quality regulation breach • Low fixed charge regulations • Employment legislation • Metering recertification 	Utilise the Planned Interruption SAIDI and SAIFI allocations optimally by planning work more effectively

Vegetation Management

Annual tree trimming in the vicinity of overhead network is required to prevent contact with lines maintaining network reliability. The first trim of trees must be undertaken at EIL's expense as required under the Electricity (Hazards from Trees) Regulations 2003. While some customers have received their first free trim, some are disputing the process and additional costs are occurring to resolve the situation. As EIL's network is mostly underground, tree issues are minimal and therefore costs are relatively low. From 2026/27 onwards the provision for vegetation management is \$2,388 p.a.


8.2 Asset Maintenance

The maintenance aspect of the O&M lifecycle phase is aimed at ensuring that assets will achieve their expected useful lives. Asset maintenance is not intended to upgrade an asset or extend its life to beyond usual expectations.

Maintenance is primarily about replacing consumable components. Many of these components will "wear out" during an asset's design life and achieving the expected service life depends on such replacements. Examples of the way in which consumable components "wear out" include the oxidation or acidification of insulating oil, pitting or erosion of electrical contacts, or loss or contamination of lubricants.

Continued operation of such components will eventually lead to failure as indicated in the following failure probability diagram. Exactly what leads to failure may be a complex interaction of parameters such as quality of manufacture, quality of installation, age, operating hours, number of operations, loading cycle, ambient temperature, previous maintenance history and presence of contaminants.

Figure 41: Component Failure



The probability of failure curve can be viewed as applicable to the overall asset life in which case neglecting maintenance could result in a considerable contraction along the "parameters influencing failure" axis. Appropriate maintenance activities would stretch out the curve toward the expected design life; effectively resetting or pushing out the increasing probability of failure. There is often a significant asymmetry associated with consumables for example replacing a lubricant may not significantly extend the life of an asset but not replacing a lubricant could significantly shorten the asset's life.


EIL's maintenance decisions are made using cost-benefit criteria with the principal benefit being less supply interruption. Increasing maintenance costs (labour and consumables) over the asset's lifecycle, taken together with the cost of discarding unused component life, must be traded off against the desire to avoid failure. The optimal time for maintenance depends on an asset's criticality (impact of failure on customers) and ultimately on how much EIL's customers are willing to pay to reduce probability of failure.

Assets such as a 33/11 kV substation transformer that supplies large customers or large quantities of customers may only be operated to point B in the preceding diagram and condition will be extensively monitored to minimise the likelihood of supply interruption. Meanwhile assets supplying merely a small customer, such as a 10 kVA transformer, will most often be run to failure represented as point C.

Maintenance Actions

Types of maintenance activities are presented in below.

Figure 42: Structure of Maintenance Actions



Planned versus Unplanned Maintenance

Condition assessment is an important part of determining maintenance requirements because many components do not deteriorate at a predictable rate. Condition assessment allows deferral of maintenance cost for assets that are in good condition and permits maintenance to be focused on more deteriorated assets. Condition assessment involves inspections and testing to gather information about the condition of assets and their components and can incorporate follow-up analysis (condition monitoring) to infer the condition of the asset through establishing trends in observable criteria.

By contrast some components are maintained at fixed intervals or based on operation counts. An example is replacing contacts in a circuit breaker that are pitted or eroded with each operation but are unable to be inspected without dismantling the circuit breaker (by which time the contacts can be replaced with a relatively small incremental cost).

As the value and/or criticality of an asset increase, the company relies less on easily observable proxies for actual condition (such as calendar age, running hours or number of trips) and more on comprehensive analysis of component condition (through such means as dissolved gas analysis (DGA) of transformer oil).

Most technical equipment, such as transformers, switchgear and secondary assets, is maintained in line with manufacturer’s recommendations as set out in their equipment manuals. Experience with the same types of equipment may provide reason to add additional activities to this routine maintenance. Visual inspections and testing also determine reactive maintenance requirements to maintain the serviceable life of equipment that are not routine, but across a large asset base provide an ongoing need for additional maintenance resource.

Overhead line inspections are an economic means to prevent a large proportion of potential faults, so the basic approach is to inspect these assets and perform preventative maintenance over the most cost-effective period that achieves the desired service levels. A certain frequency of failure is accepted on overhead lines where this remaining proportion of failures becomes uneconomic to avoid. This recognises customers’ acceptance of a low number of outages and the increasing cost for diminishing returns in attempting to reduce fault frequency.

Cables are underground, which means they are unable to be visually inspected, and testing is generally not cost-effective - it is difficult to obtain accurate results and to use them to predict time to failure. Cables are therefore often run to failure. However, as the relatively young cable network ages and fault frequency begins to increase a more preventive strategy will be employed based on testing to determine condition for critical cables. Currently cables are tested as part of the Ring Main Unit maintenance cycle.

In terms of cost efficiency, failures are more acceptable for lines and cables than for ring main units and zone substation assets. Significant service life can be restored to lines and cables by simply repairing the fault. Asset criticality is a consideration in determining an acceptable level of outages, however increased security (redundancy) is often a more

effective strategy than attempting to determine time to failure and performing preventative maintenance.

Historical reactive maintenance, fault rates, asset age, and condition have been incorporated into the operating expenditure projections. For assets with less observable condition, such as underground cables, historical failure trends and targeted testing are used to inform maintenance planning. This approach ensures OPEX forecasts reflect both the actual performance of assets to date and anticipated future maintenance needs, balancing cost efficiency with service reliability.

Maintenance Approaches

The following table summarises the maintenance approaches applicable to each network asset category, and indicates the frequency with which these maintenance activities are undertaken. Our fleet plans detail the maintenance approaches more fully.

Table 74: Maintenance Approach by Asset Category

Asset Category	Sub Category	Maintenance Approach	Frequency
Sub-transmission	Overhead	Condition assessment through periodic visual inspection. Tightening, repair, or replacement of loose, damaged, deteriorated or missing components.	3-5 yearly
	Underground	Generally, run to failure and repair. Inspection of visible terminations as part of zone substation checks, opportunistic inspection if covers removed for other work, sheath insulation IR test. Testing generally in conjunction with fault repair but may be initiated if anything untoward is noted during other inspections or work; may use IR, PI, TR, PD, VLF. Partial Discharge is tested for during Ring Main Unit maintenance.	Annual
	Distributed Subtransmission Voltage Switchgear (ABSs)	Condition Monitoring through periodic visual inspection. Tightening, repair or replacement of loose, damaged, deteriorated or missing components. Lubrication of moving parts.	5 yearly

Asset Category	Sub Category	Maintenance Approach	Frequency
Zone Substations	Subtransmission Voltage Switchgear	<p>Condition assessment through periodic visual inspection checking for: operation count, gas pressure, abnormal or failed indications and general condition.</p> <p>Testing: Contact Resistance, Partial Discharge, Insulation Resistance, CB operation time, cleaning of contacts, Thermal Resistivity viewed soon after unloading, VT/CT IR and characteristics.</p> <p>Corrective maintenance as required after any concerning inspection or test results.</p>	<p>Monthly</p> <p>5 Yearly</p>
	Power Transformers	<p>Condition monitoring through periodic inspections.</p> <p>Winding & insulation resistances, Function checks on auxiliaries (Buchholz, pressure relief, thermometers).</p> <p>Predictive maintenance - oil analysis (dissolved gases, furan) to estimate age and identify internal issues arising or trends; frequency increased if issues and trends warrant. Oil processed as necessary.</p> <p>Tap changer servicing: mechanism and contacts inspected – replacements as necessary, DC resistance across winding each tap, diverter resistors resistances.</p> <p>Clean up and repair of corrosion, leaks etc. and replacement of deteriorated or damaged components. Replacement of breathers when saturated.</p> <p>Paper sample may be taken to estimate age for aged transformers in critical locations at an engineer's instruction or otherwise during major refurbishment at half-life.</p> <p>Swept frequency test at start-of-life and after significant events such as relocation, repaired fault, refurbishment done to check for internal movement of components.</p>	<p>Monthly</p> <p>Annual</p> <p>Operation count</p> <p>Non-periodic</p>
	Distribution Voltage Switchgear	<p>Condition assessment through periodic visual inspection checking for: operation count, gas pressure, abnormal or failed indications and general condition.</p> <p>Testing: Contact Resistance, Partial Discharge, Insulation Resistance, CB operation time, cleaning of contacts, Thermal Resistivity viewed soon after unloading, VT/CT IR and characteristics.</p> <p>Corrective maintenance as required after any concerning inspection or test results.</p>	<p>Monthly</p> <p>5 Yearly</p> <p>Non-Periodic</p>
	Other (Buildings, RTU, Relays, Batteries, Meters)	<p>Monthly sub checks include inspection of auxiliary and other general assets for anything untoward; structures, buildings, grounds and fences for structural integrity and safety and general upkeep; rusting, cracked bricks, masonry or poles and weeds etc. Maintenance repairs and general tidying as necessary.</p> <p>Protection relays are tested typically with current injection to verify operation as per settings.</p> <p>Any alarms or indications from electronic equipment or relays reset and control centre notified for remediation.</p> <p>Relays recertified by external technicians as regulations require.</p> <p>Otherwise, any other equipment visually inspected for anything untoward.</p>	<p>Monthly</p> <p>5 yearly</p> <p>Non-Periodic</p>

Asset Category	Sub Category	Maintenance Approach	Frequency
Distribution Network	O/H	Condition assessment through periodic visual inspection. Tightening, repair or replacement of loose, damaged, deteriorated or missing components.	3-5 yearly
	U/G	Generally, run to failure and repair. Inspection of visible terminations as part of zone substation checks and otherwise opportunistic inspection if covers removed for other work. Testing generally in conjunction with fault repair but may be initiated if anything untoward is noted during other inspections or work; may use IR, PI, TR, PD, VLF.	Reactive or opportunistic 5 yearly if visible
	Distributed Distribution Voltage Switchgear	Condition Monitoring through periodic visual inspection. Tightening, repair, or replacement of loose, damaged, deteriorated, or missing components. Function tests to verify operation as per settings; for any switchgear controlled by relays.	5 yearly
Distribution Substations	Distribution Transformers	Condition monitoring through periodic inspections. Infrared thermal camera inspection units 500 kVA and larger. Clean up and repair of corrosion, leaks etc. Some units have breathers; replaced when saturated. Winding resistances, Insulation resistance for older units if shut down allows. DGA for critical end of life units.	6 monthly (or 5-yearly if <150 kVA) Opportunistic Non-Periodic
	Distribution Voltage Switchgear (RMUs)	Condition monitoring visual inspection to assess deterioration or corrosion. Some minor repairs may be made but generally inspection determines when replacement will be required. Threshold PD tests to identify significant partial discharge. Periodic servicing undertaken including wipe down of epoxy insulation and oil replacement in critical switchgear. Some removed oil tested for dielectric breakdown as occasional spot check of general condition.	6 monthly 5-10 yearly
	Other	Inspection of enclosures for structural integrity and safety compromised by rusting or cracked brick or masonry. Overhead structures included in distribution network inspections.	6 monthly
LV Network	O/H	Condition Monitoring through periodic visual inspection. Tightening, repair, or replacement of loose, damaged, deteriorated, or missing components.	5 yearly
	U/G	Run to failure and repair.	Reactive
	Link and Pillar Boxes	External inspection for damage, tilting sinking etc. Internal components run to failure and repair. Some opportunistic inspections when opened for other work.	5 yearly
Other	SCADA & Communications	Generally self-monitored with alarms raised for failures or downtime. 24/7 control room initiate response.	Reactive
	Earths	Five yearly inspections to check locational risk, check for standard installation and any corrosion, deterioration or loosening of components. Testing is done to confirm connection resistances and electrode to ground resistance is sufficiently low.	5 yearly
	Ripple Plant	Inspection along with other assets at GXP for signs of deterioration or damage of components; oil leaks, corrosion etc. Reactive remedial actions will follow for any issues found.	Monthly

Maintenance and Inspection Programmes

Network assets are inspected routinely with the frequency dependent on the criticality of the assets and the outcome, focussing on failure avoidance. Inspections are not practical for all assets, for example cables buried underground, and may be limited by the availability of outages or the added effort (labour cost) required to remove covers. Routine inspections are mostly limited to what can be viewed from a walkover of the assets.

Recognising that some deterioration is acceptable, inspections are intended to identify components that could lead to failure or deteriorate beyond economic repair within the period until the next inspection. Observed deterioration may trigger corrective maintenance, if economic, especially where significant further deterioration can be avoided, for example touching up paint defects before rust can take hold. Other forms of deterioration are unable to be corrected (or improved), for example pole rotting, and noting these issues may become a trigger for replacement or renewal depending on the extent of deterioration i.e., loss of structural integrity.

Visual or more intrusive technical inspection of an asset are often used to determine the condition of the asset. Testing supplements network inspections, and although it typically requires additional time and skilled staff, testing has strong advantages over visual inspection if cost effective. It is generally possible to gain greater detail around asset condition and often allows collection of condition data without the need to remove covers for inspection. Data gathered can be qualitative rather than quantitative, allowing more precise trending of an asset's condition over time. Care needs to be taken during testing, as testing itself may cause damage, for example DC testing of XLPE cables or even Very Low Frequency (VLF) cable testing causes damage if the cable is not in sufficiently good condition to pass the test.

We set out budget descriptions for routine corrective maintenance and inspection activities in the following table. These budgets tend to be ongoing at similar levels year after year but may be adjusted from time-to-time to allow for improvements in maintenance practice.

Table 75: Maintenance Activities and Opex Costs

Budget	Description	OPEX Cost
Distribution Routine Inspections	All work where the primary driver is the five yearly network inspections (20% inspected annually), or other routine tests on distribution assets. Includes any minor maintenance works carried out during these inspections.	\$115,293 p.a.
Technical Routine Inspections	All work where the primary driver is routine inspection and testing of technical assets, for example oil DGA, earth mat testing, and protection testing. Includes any minor maintenance carried out during these inspections.	\$110,409 p.a.
Distribution Routine Maintenance	All work where the driver is reactive work undertaken to correct issues found during the routine inspection. Also, a general budget for all minor distribution work.	\$71,935 p.a.
Technical Routine Maintenance	All work where the primary driver is inspection and testing of technical assets of sufficient depth to require de-energisation of the asset. Includes any servicing activities (such as oil processing, CB oil replacement, or recalibration of relays) carried out while the equipment is de-energised for these inspections.	\$504,176 p.a. thereafter
Distribution Corrective Maintenance	Permanent repairs carried out on faulted Distribution assets that had temporarily been made safe/functional during the initial incident response.	\$104,843 p.a.
Technical Corrective Maintenance	Permanent repairs carried out on faulted Technical assets that had been temporarily been made safe/functional during the initial incident response.	\$492,771 p.a.
Zone Substation Routine Maintenance	All work where the primary driver is routine scheduled maintenance (other than preventative maintenance) on zone substations. For example, SEPA unit cleaning, mowing, and minor weed control.	\$42,491 p.a.
Distribution Substation Routine Maintenance	All work where the primary driver is routine scheduled maintenance (other than preventative maintenance) on distribution substations. For example, cleaning, minor weed control, enclosure repainting.	\$55,943 p.a.

Budget	Description	OPEX Cost
Partial Discharge Survey	Partial discharge condition monitoring of equipment to identify abnormal discharge levels before failure occurs.	\$46,040 p.a.
Infra-Red & Corona Survey	Infra-Red and Corona Discharge condition monitoring survey of bus-work, connections, contacts etc. An Infra-Red survey checks for abnormal heating as an indication of poor electrical contact between current carrying components, which may lead to voltage quality issues and/or failure of equipment; while Corona Discharge testing looks for ionisation of air around insulators, as evidence of insulation defects or contamination.	\$11,639 p.a.
Supply Quality Checks	Investigations into supply quality which are generally customer initiated.	\$3,992 p.a.
Spare Checks and Minor Maintenance	A budget for checks to confirm what equipment is kept in spares and perform minor maintenance required to ensure spares are ready for service.	\$1,340 p.a.
Customer Connections	Operational portion of expenditure for the customer connections process is captured in this budget.	\$21,586 p.a.
MV Cable Testing	Testing cables to obtain a health assessment of the cable to assist with cable replacement decisions and prioritisation	\$284,436p.a.

Asset Component Replacement and Renewal

Component renewals or refurbishments are significant maintenance activities that generally focus on the non-consumable components of assets to achieve an extension to the originally expected life. This is typically less routine work and often represents a significant milestone in the life of an asset. Renewal may ultimately be part of a full asset replacement programme where the component replacements are “staggered” over time. A typical example is an overhead line, where the components (poles, cross-arms, and conductors) wear out and are replaced at different rates, but the result is complete replacement of the original line – perhaps several times over for, as long as the line asset is required.

Ultimately an asset will reach end of life when it either fails or deteriorates to the point it becomes uneconomic to repair or maintain. This will occur when failure causes significant damage to the overall asset (highly likely at distribution or subtransmission voltages) or when a part of the asset that cannot be economically replaced has significantly aged or deteriorated, for example paper insulation in a transformer.

Data maturity significantly influences operational expenditure by affecting the quality, completeness, and accessibility of asset information. High quality, complete data supports targeted maintenance, informed replacement decisions, and optimized life cycle planning, reducing reactive maintenance costs. In contrast, incomplete or low-quality data can increase OPEX through over maintenance, conservative assumptions, or unplanned corrective actions. Enhancing data maturity ensures asset renewal and replacement decisions are evidence based, cost effective, and aligned with long-term asset management strategies.

The replacement and renewal budgets for ongoing operational work that tends to recur year after year are listed and described below.

Table 76: Component Replacement and Renewal Programmes

Budget	Description	OPEX Cost
Distribution Replacement & Renewal	All OPEX work where the primary driver is the repair of distribution assets that have been found during inspection to fall short of the required standard; also includes scheduled replacements of parts/fluids under a preventative maintenance programme, and expenses incurred due to obsolescence. Excludes CAPEX (work that will have a material effect on the functionality or the life of capital assets). Covers items like crossarms, insulators, strains, re-sagging lines, stay guards, straightening poles, pole caps, ABS handle replacements etc.	\$78,745 p.a.

Budget	Description	OPEX Cost
Zone Substation Replacement & Renewal	All OPEX work where the primary driver is the repair of zone substation assets that have been found during inspection to fall short of the required standard; also includes scheduled replacements of parts/fluids under a preventative maintenance programme, and expenses incurred due to obsolescence. Excludes CAPEX (work that will have a material effect on the functionality or the life of capital assets). Covers items like earth sticks, safety equipment, buildings, battery systems etc.	\$22,478 p.a.
Distribution Substation Replacement & Renewal	All OPEX work where the primary driver is the repair of distribution substation assets that have been found during inspection to fall short of the required standard; also includes scheduled replacements of parts/fluids under a preventative maintenance programme, and expenses incurred due to obsolescence. Excludes work that will have a material effect on the functionality or the life of capital assets, i.e., CAPEX. Covers items like enclosure repairs, paint touch-ups, spouting & roof repairs, etc.	\$89,154 p.a.

8.3 Asset Operation

The operations aspect of the O&M lifecycle phase refers to the day-to-day activities required to provide service delivery to EIL's customers. Operation of the network is effectively the service that EIL's customers pay for, so it is the customer's expectation that forms the driver for the continuous operation of assets in determining the optimal balance between reliability and cost.

Well-planned and executed operations allow EIL to deliver energy supply services efficiently, effectively, and economically. In the asset management context, this requires the business to set service delivery priorities through budgeting and infrastructure planning and investment processes.

Operation of EIL's assets predominantly involves creating the path for electricity to flow from the GXP to customer's premises year after year with occasional intervention when a trigger point is exceeded. However, the workload arising from tens of thousands of trigger points is substantial enough to merit a dedicated control room. Altering the operating parameters of an asset such as closing a switch or altering a voltage setting involves no physical modification to the asset, but merely a change to the asset's state or configuration.

Contingencies to Manage Operational Risks

The following tactics have been or are being implemented to manage operational risks (especially for HILP events).

- Align asset design with current best practice.
- Regular inspections to detect vulnerabilities and potential failures.
- Remove assets from risk zone.
- Build appropriate resilience into network assets.
- Provide redundancy of supply to large customer groups.
- Involvement with the local Civil Defence.
- Prepare practical response plans.
- Operate a 24hr control centre.

In addition to the tactics listed above, EIL has the following specific contingencies in place through its management company PowerNet.

Business Continuity Plan

EIL requires PowerNet to be able to continue in the event of any serious business interruption. Events causing interruption can range from malicious acts through damaging events, to a major natural disaster such as an earthquake. PowerNet has developed a Business Continuity Plan using the nationally deployed Coordinated Incident Management System (CIMS) which has the following principal objectives:

- Eliminate or reduce damage to facilities, and loss of assets and records.
- Plan alternate facilities.
- Minimise financial loss.
- Provide for a timely resumption of operations in the event of a disaster.

- Reduce or limit exposure to potential liability claims filed against the company, its directors, and staff.
- Coordinate with other services if a regional or national significant event occurs.

In developing the business continuity plan each business unit identified their key business functions and prioritised them according to their criticality and the timeframes before their absence would begin to have a major impact on business functions. Where practicable, continuity plans have been developed in line with each critical business function and preparation has been undertaken where appropriate to allow continuity plans to be implemented should they be required.

Pandemic Action Plan

EIL requires PowerNet to be able to continue in the event of a breakout of any highly infectious illness that could cause significant numbers of staff to be unable to function in their job. The plan aims to manage the impact of an influenza-type pandemic on PowerNet's staff, business, and services through two main strategies:

- Containment of the disease by reducing spread within PowerNet, achieved by reducing risk of infected persons entering PowerNet's premises, social distancing, cleaning of the work environment, managing fear, management of cases at work and travel advice.
- Maintenance of essential services if containment is not possible, achieved through identification of the essential activities and functions of the business, the staff required to carry out these tasks and special measures required to continue these tasks under a pandemic scenario.

Critical Network Spares

Critical network equipment has been identified and spares are kept to ensure that reinstatement of supply or supply security is achievable in an appropriate timeframe following unexpected equipment failure. Efficiencies have been achieved due to close relationship between the networks which PowerNet manage, for example a transformer was borrowed from TPCL to reinstate a firm supply following failure of a transformer at a critical Invercargill CBD zone substation.

Network Operating Plans

As contingency for major outages on the EIL network PowerNet holds network operating plans for safe and efficient restoration of services where possible. For example, a schematic based switching plan and accompanying operating order detailing steps required to restore supply after loss of a zone substation.

Insurance

EIL holds the following insurances.

- Material damage and business interruption over substations and buildings
- Contracts works and marine cargo
- Directors' and officers' liability
- Utilities Industry Liability Programme (UILP) that covers Public, Forest & Rural Fires, Products liability, and Professional Indemnity
- Statutory liability
- Contractors working on the network hold their own liability insurance.

Service Interruptions and Emergencies

This provides for staff, plant, and resources to be ready for faults and emergencies. Fault staff respond to make the area safe, isolate the faulty equipment or network section and undertake repairs to restore supply to all customers. Any follow-up actions necessary to make further repairs are charged to the appropriate Corrective Maintenance budget. The Service Interruptions & Emergencies budget is set at \$ 603,680 per annum.

8.4 Operational Expenditure Forecast

The following table presents our forecasts of EIL's operational expenditure for the next 10 years. This information is also provided in the Information Disclosure Schedule 11b.

Table 77: Operating Expenditure Forecast (\$000 - constant 2026/27 terms)

Category	DPP4					DPP5					DPP6
	2025/ 2026	2026/ 2027	2027/ 2028	2028/ 2029	2029/ 2030	2030/ 2031	2031/ 2032	2032/ 2033	2033/ 2034	2034/ 2035	2035/ 2036
OPEX: Asset Replacement and Renewal											
Distribution Replacement & Renewal	76	79	79	79	79	79	79	79	79	79	79
Zone Substation Replacement & Renewal	22	22	22	22	22	22	22	22	22	22	22
Distribution Substation Replacement & Renewal	86	89	89	89	89	89	89	89	89	89	89
	183	190	190	190	190	190	190	190	190	190	190

Category	2025/ 2026	2026/ 2027	2027/ 2028	2028/ 2029	2029/ 2030	2030/ 2031	2031/ 2032	2032/ 2033	2033/ 2034	2034/ 2035	2035/ 2036
	OPEX: Vegetation Management										
Vegetation Management	2	2	2	2	2	2	2	2	2	2	2
	2	2	2	2	2	2	2	2	2	2	2

Category	2025/ 2026	2026/ 2027	2027/ 2028	2028/ 2029	2029/ 2030	2030/ 2031	2031/ 2032	2032/ 2033	2033/ 2034	2034/ 2035	2035/ 2036
	OPEX: Routine and Corrective Maintenance and Inspection										
Distribution Routine Inspections	142	115	115	115	115	115	115	115	115	115	115
Technical Routine Inspections	121	110	110	110	110	110	110	110	110	110	110
Distribution Routine Maintenance	96	72	72	72	72	72	72	72	72	72	72
Technical Routine Maintenance	492	204	204	204	204	204	204	204	204	204	204
Distribution Corrective Maintenance	107	105	105	105	105	105	105	105	105	105	105
Technical Corrective Maintenance	202	493	493	493	493	493	493	493	493	493	493
Zone Substation Routine Maintenance	41	42	42	42	42	42	42	42	42	42	42
Distribution Substation Routine Maintenance	54	56	56	56	56	56	56	56	56	56	56
Partial Discharge Survey	44	46	46	46	46	46	46	46	46	46	46
Infra-red & Corona Surveys	11	12	12	12	12	12	12	12	12	12	12
Supply Quality Checks	4	4	4	4	4	4	4	4	4	4	4
Spares Checks and Minor Maintenance	1	1	1	1	1	1	1	1	1	1	1

SECTION 8 Operating Expenditure



Customer Connections	21	22	22	22	22	22	22	22	22	22	22
MV Cable Testing	279	284	284	284	284	284	284	284	284	284	284
	1,616	1,567	1,567	1,567	1,567	1,567	1,567	1,567	1,567	1,567	1,567

OPEX: Service Interruptions and Emergencies	2025/ 2026	2026/ 2027	2027/ 2028	2028/ 2029	2029/ 2030	2030/ 2031	2031/ 2032	2032/ 2033	2033/ 2034	2034/ 2035	2035/ 2036
Incident Response - Distribution - Unplanned	528	538	538	538	538	538	538	538	538	538	538
Incident Response - Technical - Unplanned	53	54	54	54	54	54	54	54	54	54	54
Incident Response - Technical - Fixed Fee	23	56	56	56	56	56	56	56	56	56	56
	604	648	648	648	648	648	648	648	648	648	648

Operational Expenditure Total	2,406	2,407	2,407	2,407	2,407	2,407	2,407	2,407	2,407	2,407	2,407
System Operations and Network Support	1,994	1,994	1,994	1,994	1,994	1,994	1,994	1,994	1,994	1,994	1,994
Business Support	2,517	2,517	2,517	2,517	2,517	2,517	2,517	2,517	2,517	2,517	2,517
AMP Total Operational Expenditure	6,917	6,918	6,918	6,918	6,918	6,918	6,918	6,918	6,918	6,918	6,918

Grand Total Capital and Operational Expenditure	13,669	15,878	16,097	15,091	15,841	18,420	18,247	16,070	15,568	15,432	15,633
--	---------------	---------------	---------------	---------------	---------------	---------------	---------------	---------------	---------------	---------------	---------------

Values Fully Marked Up, No Inflation, Base Year dollars.

9

Execution Capacity

SECTION CONTENTS

Oreti River. Photo: Videocopter


9	Execution Capacity	160
9.1	People, Culture and Leadership	161
9.2	Funding the Business	162
9.3	Information Management.....	163

9 EXECUTION CAPACITY

The core of EIL’s asset management activities lies within the detailed processes and systems that reflect our thinking, manifest in our policies, strategies and processes, and ultimately shape the nature and configuration of EIL’s fixed assets.

EIL has contracted PowerNet to be the asset management company for EIL. PowerNet uses its integrated Business Management System (BMS) to manage the network. The BMS can be depicted as per the following figure. This figure illustrates the asset lifecycle approach that we use in managing the assets of EIL. Each of the lifecycle stages as well as the underpinning foundational elements are discussed in this AMP.

Figure 43: Asset lifecycle



It is important to note that all asset lifecycle activities are executed within the framework of our Safety Management System. The highest priority in all decision-making is to ensure the safety of the public and our staff. This is built into every lifecycle activity.

Asset management and safety are both managed within our Quality Management System (QMS). The QMS ensures that approved processes are followed, and that necessary documentation is available to staff and is current. This leads to work being executed in a consistent manner across the whole company and for all managed networks.


The foundation for managing the assets and determining the required resources and funding is our Fleet Plans. Our Fleet Plans:

- Outline how we manage each asset over its full life; and
- How we extract the maximum value from each asset by
 - Trading-off Capex with Opex, looking at the full life costs
 - Optimising maintenance tactics for each asset class and type
 - Determining risk associated with each asset class/type (e.g. safety, transformer oil spills, etc)
 - Taking into account disposal cost and implications (e.g. disposing of SF6)

The Fleet Plans contain staffing and equipment requirements for each piece of work. Rates such as hourly rates and travel rates are applied to the information in the Fleet Plans to give us a cost for each piece of work. This gives us the Unit Rates that are charged to the networks by PowerNet.

The Annual Works Plan consolidates all the work that needs to be done on the network and the cost thereof into a single document that is used for the development of the AMP and the PowerNet and network Business Plans. The resulting information on forecast Capex and Opex is arranged into the Commerce Commission format for disclosure (as presented in the AMP in sections 7 and 8 and Annexure 3). This value chain is depicted in the following diagram.

Figure 44: Asset lifecycle



9.1 People, Culture and Leadership

EIL’s work has to be planned, managed and executed by people. Organisational leadership and culture are key determinants in the efficacy of work execution by people.

The EIL leadership consists of the EIL Board. The EIL Board sets and monitors the network performance objectives, evaluates, and addresses network and EIL-related risks and makes the funding available to PowerNet to execute the required work. PowerNet sets the policies that govern work execution and employees, evaluates and addresses staff and PowerNet related risks to ensure that the requirements of the EIL Board as set out in the network management agreement are met.

Work Execution Requirements

PowerNet determines the work execution requirements by determining the man hours and other resources required to execute each item of work or project. The planned Works Programme is analysed to determine the overall resource requirements for the work execution. Adjustments are then made based on resource availability. These adjustments may be delaying work until resources become available, using contractors or, if there is a long-term resource requirement, appointing additional staff or procuring the required plant or equipment. The year-to-year work volumes in the AWP are smoothed out to prevent peaks and troughs in resources required (to the extent possible acknowledging appropriate risk controls) to provide a relatively constant work stream.

Utilising PowerNet’s works management and field services staff has great benefit in ensuring a longer-term approach may be taken to resourcing. Staff numbers can be increased with added confidence that they will be fully utilised in future years given the long-term plans developed, as these resources can be utilised on all the PowerNet managed networks. The smoothing out of resource requirements can be done over a larger base load of work.

Working closely with PowerNet’s contractors is also an important part of the AWP development process. The detailed works plan is communicated to the contractors, and they commit to making sufficient resources available for the years ahead. Contractors can confidently commit to hiring extra staff where appropriate, recognising EIL’s on-going development and maintenance requirements.

People-related constraints

It remains problematic to obtain and retain the required numbers of appropriately skilled resources. This applies to all levels of staff, but particularly to technical and field staff. The lower South Island is not a first choice for people to work and stay, especially younger people. PowerNet generally has around 13 vacancies for field and technical staff. Many of these vacancies are filled using overseas recruitment.

The specific experience and skills on the EIL underground network remain scarce.

9.2 Funding the Business

Revenue

EIL’s revenue comes primarily from retailers who pay for the conveyance of energy over EIL’s network but also from customers providing contributions for the uneconomic part of works. The revenue available to EIL is set out in a “price path”, in compliance with determinations by the Commerce Commission. The following approaches for funding of new assets are utilised.

- Funding from revenue within the year concerned.
- Funding from after-tax earnings retained from previous years.
- Raising new equity (very unlikely given the current shareholding arrangement).
- Raising debt (which has a cost, and is also subject to interest cover ratios).
- Allowing Transpower to build and own assets which allows EIL to avoid new capital on its balance sheet, but perhaps more importantly also allows EIL to treat any increased Transpower charges as a pass-through cost.

Expenditure

Expenditure is incurred to maintain the asset value of and to expand or augment the network to meet customer demands

Influences on the Value of Assets

An annual independent telephone survey is undertaken each year and consistently indicates EIL’s customer’s price-quality trade-off preferences are as follows.

- A large majority are not willing to pay \$10 per month more in order to reduce interruptions
- A small minority are willing to pay \$10 per month more in order to reduce interruptions
- A small minority feel they don’t know or are unsure of price-quality trade-offs

In response, EIL’s asset value should either remain about the same or be allowed to decline in a controlled manner (and knowing how to do this is obviously a complex issue). However, this presents EIL with the dilemma of responding to customers’ wishes for lower cost supply in the face of a “no material decline in SAIDI” requirement and revenue incentives in Commerce Commission regulation to improve reliability. Factors that will influence EIL’s asset value are shown below:

Table 78: Factors influencing EIL’s asset value

Factors that increase EIL’s asset value	Factors that decrease EIL’s asset value
Addition of new assets to the network	Removal of assets from the network
Renewal of existing assets	On-going depreciation of assets
Increase of standard component values implicit in valuation methodology	Reduction of standard component values implicit in valuation methodology

At a practical level, EIL’s asset valuation will vary even in the absence of component revaluations. This is principally because the accounting treatment of depreciation models the decline in service potential as a straight line (when in most cases it is more closely reflected by an inverted bath-tub curve) whilst the restoration of service potential is very “lumpy”. However, the aggregation of many depreciating assets and many restoration projects tends to smooth short-term variations in asset value.

Depreciating the Assets


Assets are depreciated using straight line depreciation over the asset expected life. This doesn’t strictly model the decline in service potential of an asset. Straight-line depreciation does, however, provide a smooth and reasonably painless means of gathering funds to renew assets reaching the end of their life.

9.3 Information Management

Information Management Model

The data hierarchy model depicted below shows the typical information and knowledge residing within EIL’s business (including employees from PowerNet).

Figure 45: EIL’s Data Hierarchy Model



The bottom two layers of the hierarchy, ‘Data’ and ‘Information’ strongly relate to EIL’s asset and operational data, and the summaries thereof impact EIL’s decision making. The middle layer, ‘Knowledge’, tends to be general in nature and may include technical standards, policies, processes, operating instructions, and spreadsheet models. This probably represents the upper limit of what can be reasonably codified of accumulated knowledge.

The top two layers ‘Understanding’ and ‘Wisdom’ are extensive, often quite fuzzy and enduring in nature. The decision-making process involves these top two levels of the hierarchy and key organisational strategies and processes reside at these levels.

Accurate decision making requires the convergence of both information and (a lot of) knowledge to yield a correct answer. Deficiencies in either area (incorrect data, or a failure to correctly understand issues) will lead to wrong outcomes. The layers right from “Data” to “Wisdom” are difficult to codify and suitable application depends on skilled and experienced people. Developments in the field of Artificial Intelligence (AI) are closely monitored to see if AI will become of use in this regard.

The following outlines the types of investments targeted within the planning period to support improved network visibility.

LV network monitoring. This is an essential programme that will inform future investment plans, provide inputs for automation schemes, and help ensure network stability in the face of increased use of distribution edge devices. Over time, we intend to expand visibility further down into the networks – typically to include feeder endpoints and T-offs. The programme will also look at the integration of other available monitoring devices on the network – for example customers’ inverters (for PV), smart meters etc.

Enhanced network condition and utilisation monitoring – incorporating new and different network condition detection methods through expanded sensor types, external sources of network specific data, and improved back-office capability.


Interfacing with DER resources on the LV network – developing methods to provide network relevant data to DER resources (and their management interface) and obtain data from these sources. This will include developing methods of exchanging information with local generation, storage, and discretionary loads, such as EVs.

Expanded communications and information systems. We will also identify potential opportunities to share infrastructure with other providers, for example, should the required network insights be available from retailers’ smart meters, it may obviate the need for our own investment.

EIL’s Asset Management Information Systems

The following diagram provides a high-level summary of EIL’s asset management processes and systems. It incorporates the role and interaction of each component of the data hierarchy model.

Figure 46: Key Asset Management Systems & Processes



There is a variety of information management tools which capture asset data and can be used to create summary information from the data. Based on this foundation, EIL has sufficient knowledge about almost all the assets; their locations, what they are made of, how old they are and their performance. This knowledge will be used for either making decisions within EIL’s own business or assisting external entities with resolutions. A summary of the key data repositories is listed below.

Table 79: Key Information Systems

Information System	Data Type	Data Source
Asset Management System (AMIS – Maximo)	Description, Specifications, Age, Condition	Network Equipment Movement (NEM) Forms, Field Survey, Supplier Data, Commissioning Records, Test Records
Geographic Information System (GIS)	Location, Age, Connectivity	As-built information, Roding Authorities, Land Surveys
SCADA	Switch Status, Loading	Polled devices
PowerNet Connect	Customer Details	MARIA registry, GIS
PowerNet Connect	Customer calls regarding faults	Customer calls to System Control
Outage Reporting System	Regulatory recording of outages SAIDI & SAIFI	System Outage Logs
Defect Database	Equipment failures	System Control, Reports from field staff, Project Managers

In general, the completeness of data within the information systems is reasonable (acceptable) and a summary with noted limitations is provided in the next table.

Table 80: Data Completeness within Information Systems

System	Parameter	Completeness	Notes
GIS	Description	Good	Some delays between job completion and GIS update, some cable size/types unknown
GIS	Location	Excellent	Some delays between job completion and GIS update
GIS	Age	Reasonable	Equipment ages include some estimate by type (era of manufacture)
Condition Assessment Database	Condition	Acceptable	Regular inspections but some subjectivity and condition data not updated with repair
AMIS	Specification	Acceptable	Some delays between job completion and Maximo update
AMIS	Details	Acceptable	Some delays between job completion and Maximo update
AMIS	Age	Acceptable	Missing age on old components, mix of installation and manufacturing dates used as age estimate
AMIS	Condition	Reasonable	Some condition monitoring data (DGA)
SCADA	Zone Substations	Excellent	All monitored
SCADA	Field Devices	Good	Monitoring and automation increasing

Data Control, Improvement and Limitations

EIL’s original data capture emphasised asset location and configuration. The data was used to populate the GIS, but it did not include high-level asset condition data. As part of this original data capture, the company developed a field manual of drawings and photos to minimise subjectivity.

Records and drawings have been used to ascertain asset age, but certain asset classes such as cables, had limited supporting information. Old cables do not have a manufacturing date associated and updating the GIS system with missing data entry points is problematic. Options have been considered to get ages measured for the un-dated cables, but no economic methodology has been found. Where economical, condition data is collected, as it is useful in determining replacement timeframes.

Almost all GIS data entered for assets is standardised and selected from lists to ensure quality of data entry; and for all other data (for example electrical connectivity), thorough processes, peer reviews, and well-trained staff are used to ensure data entry quality is very good. Key process improvements will include timelier as-builts with PowerNet staff taking GPS coordinates for poles and other assets and use of electronic forms for data input.

Data for the AMIS is collected by the Network Equipment Movement (NEM) form that records every movement of serial numbered assets. Some updating of data is obtained when sites are checked with a barcode label put on equipment to confirm data capture and highlight missed assets. About 20 percent of the network (by length) is condition assessed each year to update asset condition data (noting that asset condition is continually varying), and any discovered variances are corrected.

Improvements to the AMIS are continually being undertaken to allow additional asset details which were historically captured in spreadsheets to be captured in the AMIS; especially the addition of condition-based indicators to assist in making better asset management decisions. Data validation and completeness controls are also being added over time to prevent new assets being created without all required data being captured.

Assets are assigned a unique reference common to both the GIS and AMIS. Where asset data is common to both systems it will be input into one system (deemed the master for that data) and automatically copied to the other to ensure consistency. Other systems also have some degree of interface for copying across common data such as

customer data residing in both the ICP database and in GIS and referenced by the common ICP number. However, for the most part, these tools do not interact directly, with staff pulling together information from the necessary tools for their use as part of their asset management activities.

The SCADA system and monitoring completeness and accuracy is excellent at zone substations as it is critical for both safety and reliability of the network and is used for the day-to-day operation of the network. More field devices are being added to SCADA for remote monitoring and operation.

Other data repositories have very good data quality with these database systems controlling data entry through drop down lists and validation controls. Modifications may be made from time to time to better align with maintenance processes as they evolve.

Software Systems (Asset related)

In order to satisfy its obligations under the network management agreement PowerNet maintains and utilises several software-based tools to manage data and knowledge. These are described below.

- **Asset Management Information System (AMIS)** This system stores EIL's asset descriptions, specifications, ages, and condition information for serial numbered components. It also provides execution and asset management tools with most day-to-day operations being managed through the AMIS. The life-cycle of maintenance regimes, field inspections, customer-related tasks and/or estimates, etc. is managed via Work Orders issued from the AMIS and is integrated to the financial management system. Work Orders are also packaged to track the execution of capital projects involving design, procurement and installation of major network assets. Work Orders generated from the AMIS create the focus for all work packaging and execution for EIL. The individual assets that make up large composite items such as substations are managed through the AMIS in conjunction with other more traditional techniques such as drawings and individual test reports. EIL utilises IBM Maximo Application Suite, which offers a best-of-breed portfolio of enterprise asset management solutions for its AMIS. EIL utilises the Maximo software package for its AMIS.
- **Geographic Information System (GIS)** An Intergraph based GIS is utilised to store and map data on individual components of distributed networks. The GIS focuses primarily on geographically distributed assets such as cables, conductors, poles, transformers, switches, fuses, and similar items and provides asset description, location and age information for each asset. Locational data is used to provide mapping type displays of existing equipment for planning network upgrades, extensions, and maintenance scheduling. It allows these plans to account for distance and travel time and any other factors influenced by the geographic distribution of the assets. Electrical connectivity, capacity and ratings also form a crucial data set stored in the GIS which assists the analysis of the networks ability to supply increasing customer load or determine contingency plans.
- **Load Flow and Fault Analysis Software** Export of data from the GIS into this system allows modelling of the network. This helps predict network capability in the existing arrangement and in future "what if" scenarios considered as planning options as well as determining fault levels to assess safety and effectiveness of protection and earthing systems. Two software packages Power Factory and PSS Adept (to be decommissioned) are used to perform this analysis for EIL.
- **Supervisory Control and Data Acquisition (SCADA) System** The SCADA system provides real time operational data such as loadings, voltages, temperatures and switch positions. It also provides the interface through which PowerNet's System Control staff can view the data through a variety of display formats and remotely operate SCADA connected switchgear and other assets. Historical data is stored and provides a reference for planning. For example, network loading can be downloaded over several years allowing growth trends to be determined and extended to forecast future loading levels.
- **Business Central (previously Finance One) (BC) Financial System** Monthly reports from F1 provide recording of revenues and expenses for the EIL line business unit. Project costs are managed in PowerNet with project managers managing costs through the AMIS system. Interfaces between BC and the AMIS track estimates and costs against assets.
- **Outage, Fault and Defect Database** These are populated by the System Control staff as information is reported by field staff or via the faults call centre to ensure efficient tracking of operational issues affecting network service levels.
 - The faults database logs all customer-initiated calls reporting power cuts or part power to store reported information and contact details. Calls are therefore able to be tracked to ensure effective response and restoration.
 - The outage database logs outage data used to provide regulatory information and statistics on network performance. As such data capture is in line with regulatory focuses, it excludes LV network outages. Reports from this system are used to highlight poorly performing feeders which can then be analysed to determine

maintenance requirements or if reliability may be enhanced by other methods. Monthly reports are provided to the EIL Board for monitoring, together with details of planned outages.

- Asset defects are captured in another database for technical asset issues which do not have an immediate impact on service levels but potentially could, if not responded to. Defects are tracked in this database and scheduled for remediation.
- **Condition Assessment Database** This database tracks the results of routine overhead line inspection rounds and is used as a basis for assigning line repair/renewal work. Severely deteriorated structures are marked as red-tagged and are prioritised for repair, and similarly with low conductor spans. The current database is being replaced as part of an overhaul of line inspections on all PowerNet-managed networks; the replacement database will permit the recording of repairs and will allow more precision in reliability analysis.
- **ICP/Customer Database** An additional database (essentially commercial in nature) containing such data as customer details, consumption and billing history. This interfaces with the National Registry to provide and obtain updates on customer connections and movements. Data is received from retailers and links this to the customer database.

Processes and Documentation

EIL's key asset management processes and systems are based around the asset lifecycle activities and complies with the ISO55001 Asset Management System and the AS/NZS9001 Quality Management System standards. EIL, through PowerNet, is audited and is certified to both systems. The processes are not intended to be bureaucratic or burdensome but are intended to guide EIL's decisions (apart from safety-related procedures which do contain mandatory instructions). Accordingly, these processes are open to modification or amendment if a better way becomes obvious.

The asset management processes are documented and grouped in the following categories with a complete list provided in Appendix 1.

- Operating Processes and Systems.
- Maintenance Processes and Systems.
- Renewal Processes and Systems.
- Up-sizing or Extension Processes and Systems.
- Retirement Processes and Systems.
- Performance Measuring Processes.
- Other Business Processes.

Some processes are prescribed in external documents (such as the information disclosure determination which this AMP is required to comply with) and as such they are not copied onto internal documentation. Processes are often embedded within asset management tools including external requirements such as the need to produce network reliability statistics for disclosure being embedded within the outage management database.

ProMapp is used to document our processes. The ProMapp process mapping software makes it easy for all employees to view our processes step-by-step so that they can better understand them and ensure consistency in the way work is being executed, continuous improvement, quality assurance, and risk management.

Document and Process Reviews


Each document or process is controlled by an owner at management level who is given responsibility for its review and update. The documents and processes are reviewed periodically to ensure they are kept up to date. Lean Management practices have recently been introduced to refine business and asset management processes with the changes identified ultimately reflected in documented procedures.

Once updates have been finalised, they are approved by the controlling manager and all staff are notified by email and where necessary by placement on notice board and direct training and communication to individuals affected. External audits of specific systems and processes are also conducted. Current external audits include the following.

- Public Safety Management System (PSMS) (AS/NZS 7901 compliance).
- Occupational Health and Safety Management (AS/NZS 4801 compliance).
- Worksite safety audits (completed by Network Compliance Ltd).
- Asset Management Maturity Assessment Tool (AMMAT) review.

10

Evaluation of Performance



Anderson Park Southland. Photo: Jeremy Pierce

SECTION CONTENTS

10	Evaluation of Performance	170
10.1	Progress against Plan.....	170
10.2	Service Level Performance.....	171
10.3	AMMAT Performance	173
10.4	Gap Analysis and Planned Improvements.....	174
10.5	Benchmarking.....	174

10 EVALUATION OF PERFORMANCE

This section reviews EIL's performance on expenditure measures, service level performance, and network efficiency. It also examines asset management maturity using the AMMAT tool and identifies initiative for continued improvement. Finally, EIL's performance relative to other EDBs is considered, using data from regulatory information disclosures.

10.1 Progress against Plan

The performance between estimated expenditure and actual expenditure for CAPEX and OPEX is described below.

Capital Expenditure

Capital works was 4% over budget due to:

- **Consumer connections** – 41% underspend in the new subdivision category is due to the absence of development in the Te Puwai subdivision.
- **Asset replacement and renewal** – Total actual spending aligned with the total allocated budget.
- **Asset relocations** - 832% overspend was due to the relocation of Linkbox 6 in the CBD to accommodate hotel development.
- **Quality of Supply** – 62% overspend was driven by the fault indicator project and the completion of fibre installation to RMUs, which had been delayed last year due to supply issues.
- **Reliability, Safety and Environment** – The 47% overspend was driven by higher than anticipated traffic management costs and increased expenditure on earth upgrades, which were required after delays in CBD network earthing works over the past two years.

The following table provides further information on the variation between forecast and actual capital expenditure.

Table 81: Variance between Capital Expenditure Forecast and Actual Expenditure

Capital Expenditure	Forecast 2024/25 (\$k)	Actual 2025/26 (\$k)	Variance
Consumer Connection	1,343	786	41
System Growth	-	-	-
Asset Replacement and Renewal	4,205	4,196	0%
Asset Relocations	7	66	832%
Quality of Supply	169	275	62%
Legislative and Regulatory	-	-	-
Other Reliability, Safety and Environment	1,397	2,050	47%
Capital Expenditure on Network Assets	7,122,932	7,374,802	4%

Operational Expenditure

Operational expenditure was 25% under budget.

- Service interruptions and emergencies – 8% underspend which is a minor variation in a reactive budget for fault response.
- Vegetation management – 16% underspend because of less work identified.
- Routine and corrective maintenance and inspection – The 30% underspend was due to limited work identified from the inspection programme, resulting in lower than planned expenditure.
- Asset replacement and renewal – The 37% underspend was due to additional RMU oil change work completed last year, resulting in reduced expenditure this year.

The following table provides further detail on the variation between forecast and actual operational expenditure.

Table 82: Variance between Operational Expenditure Forecast and Actual Expenditure

Operational Expenditure	Forecast 2024/25 (\$k)	Actual 2024/25 (\$k)	Variance
Asset Replacement and Renewal	188	119	37%
Vegetation Management	2.5	1.9	16%
Routine and Corrective Maintenance and Inspection	1,791	1,252	30)%
Service Interruptions and Emergencies	614	567	8%
Operational Expenditure on Network Assets	2,597	1,941	(25)%

10.2 Service Level Performance

Customer Consultation

Key customers are surveyed annually by external consultants. PowerNet, as the de facto service provider, is used as a proxy for EIL. Interviewees generally felt PowerNet had a very positive image in the community however there was a perception with some that PowerNet has quite a low profile. It was generally perceived that PowerNet has its customer's best interests at heart however some felt they were unable to comment on this due to lack of visibility.

Customers consistently ranked continuity of supply as the most important aspect of their provided network service and indicated that PowerNet performed very well in this regard. Other customer priorities included prompt restoration of supply, sufficient notice of planned interruptions, cost of supply, and supply quality. Again, customers indicated that they were generally satisfied with these aspects and the overall service from PowerNet. Some businesses expressed a desire for more proactive and regularly initiated contact from PowerNet staff to make them more aware of quality, efficiency, or pricing options, but the majority saw no specific need for such contact.

Reliability

As was discussed in chapter 5, we use the internationally accepted reliability measures of SAIDI and SAIFI to assess reliability. These measures are also used by the Commerce Commission in its DPP regulation. SAIDI is calculated using the duration of each interruption stage and the number of consumers affected. SAIFI measures the average number of interruptions a customer experiences over a year, measured in units of interruptions per customer.

The following table shows that EIL performed well on SAIDI and SAIFI outcomes for 2023/24, in comparison with regulatory targets and limits. Unplanned SAIDI outperformed both the target and the limit. Planned SAIDI was below the limit though above the target. Both planned and unplanned SAIFI were under the limit.

We note that these figures have been normalised according to the Commerce Commission's methodology. We also note that planned SAIDI and SAIFI limits are cumulative over a 5-year period, and that the figures in the table are annual pro-rata.

Table 83: Performance against Primary Service Targets

Measure	Class	2024/25 DPP3 Target	2024/25 DPP3 Limit	2024/25 Actual
SAIDI	Planned	16.16	27.15	25.75
	Unplanned	18.05	25.19	21
SAIFI	Planned	-	0.660	0.092
	Unplanned	-	0.114	0.347

Customer Satisfaction

The customer engagement survey conducted by phone provides feedback to understand customer satisfaction regarding a range of aspects around their supply services. Statistics are also recorded for any customer complaints received. Performance against the service levels regarding planned outages was better than the targets set for 2024/25. The table below presents a summary of performance against customer satisfaction targets.

Table 84: Performance against Secondary Service Targets

Attribute	Measure	Target 2024/25	Actual 2024/25
Customer Satisfaction on Faults	No impact or minor impact of last unplanned outage {CES}	>50%	55%
	Information supplied was satisfactory {CES}	>80%	63%
	PowerNet first choice to contact for faults {CES}	>35%	53%
Voltage Complaints	Number of customers who have made supply quality complaints {IK}	<6	3
	Number of customers having justified supply quality complaints {IK}	<3	0
Planned Outages	Provide sufficient information {CES}	>80%	96%
	Satisfaction regarding amount of notice {CES}	>80%	96%
	Acceptance of one planned outage every two years lasting four hours on average {CES}	>80%	84%

{ } indicates information source; CES = Customer engagement survey using independent consultant to undertake phone survey, IK = Internal KPIs.

Network Efficiency

The load factor reflects the ratio of EIL's average demand to peak demand and averages around 50%. While it is desirable to have a capacity utilisation factor as high as possible, standardisation of transformer sizing, allowance for growth and the unpredictable consumption patterns of customers mean there is a practical and economic limit to how much this factor can be improved.

Reported losses tend to vary from year to year more than can be explained by changes in operation and network assets. This variation can mostly be attributed to the retailer accrual process.

EIL's capacity utilisation compares very well with other distribution businesses.

Table 85: Performance against Efficiency Targets

Measure	2024/25 Target	2024/25 Actual
Load factor	> 50%	47%
Loss ratio	< 5.5%	4.7%
Capacity utilisation	> 40%	41.25%

Financial Efficiency

Overall, the network and non-network OPEX financial efficiency results are marginally better than planned.

Table 86: Performance against Financial Targets

Measure	2024/25 Target	2024/25 Actual
Network OPEX/ICP	\$142	\$110
Network OPEX/km	\$3,755	\$2,918
Network OPEX/MVA	\$16,000	\$12,266
Non-Network OPEX/ICP	\$221	\$225
Non-Network OPEX/km	\$6,000	\$6,783
Non-Network OPEX/MVA	\$25,500	\$28,516

10.3 AMMAT Performance


PowerNet understands the foundations of good asset management practice and endeavours to comply with international best practice as embodied in the ISO5500X suite of standards (a management system for Asset Management). In addition, the original PAS 55 principles are adopted (as this is the measurement standard still utilised by Commerce Commission). These foundations are applied in EIL.

The AMMAT (Asset Management Maturity Assessment Tool) is based on a selection of questions based on PAS-55. It is intended to prompt consideration of performance against a number of facets of good asset management practice. Each question can be scored from '0' to '4' and each question has a series of answers to describe what is required to achieve each scoring level. Appendix 3 Schedule 13 shows the full AMMAT questions, the scores determined and the maturity description for each question.

PowerNet commissioned Utility Consultants to do an AMMAT assessment for this AMP. The focus was on the changes that had occurred since the 2023 assessment. In scoring EIL's asset management practice against the maturity tool, scores from '2.5' to '3.0' with an average score of '2.95' were achieved as shown below. All the areas covered in the questionnaire are not of equal importance to an EDB, so target scores were set for each area. These target scores are indicated by the red curve.

The blue curve shows the result of this assessment.

Figure 47: Asset Management Maturity Assessment Scores



10.4 Gap Analysis and Planned Improvements

Asset Management Maturity

For a distribution company of EIL’s size a score of between ‘2’ and ‘3’ for many of the asset management functions is considered appropriate. However, as PowerNet provides EIL’s asset management services as well as providing this service across other networks, EIL believes that some improvements are realisable and appropriate. The 2023 audit showed that EIL had maturity improvement in all of the previously weaker areas:

Q50	Training, awareness, and competence	How does the organization ensure that persons under its direct control undertaking asset management related activities have an appropriate level of competence in terms of education, training, or experience?
Q63	Information management	How does the organization maintain its asset management information system(s) and ensure that the data held within it (them) is of the requisite quality and accuracy and is consistent?
Q79	Use and maintenance of asset risk information	How does the organization ensure that the results of risk assessments provide input into the identification of adequate resources and training and competency needs?

Other initiatives for improvement that have been completed or are in progress are:

- A new drawing management system that allowing access to drawings from the field.
- A system to keep everybody abreast of legal, regulatory, and statutory requirements.
- A Data Strategy and an Information System Strategy were developed and are being implemented. Key to these strategies is recognising and agreeing that the computerised asset management information system (MAXIMO) will be the single source of truth around assets. Further implemented improvements to the system are:
 - Developing more compatible units and unit rates to allow standardisation of common asset types including cost by materials and labour to enable efficient costing and scheduling of future work.
 - Integration of EIL’s financial management system to efficiently track costs supporting compatible units and understanding whole of lifecycle costs for these assets.
 - Rolling out field devices to operational staff that will allow the direct capturing of data from the field. This also includes automating the risk management framework used in works by field staff.
- Still to be fully implemented are:
 - Including a Risk Management module into the system.
 - Expanding work scheduling to more systematically and efficiently schedule and track asset maintenance activities to additional asset types.

ISO 55001 Asset Management System implementation

PowerNet’s Asset Management System has been certified to ISO 55001.

10.5 Benchmarking

Benchmarking against other local distribution networks assists with the identification of potential improvements in the current service levels that EIL offers. Comparisons with Nelson Electricity (and to a lesser extent Orion and Wellington Electricity), are useful as these networks are similar to EIL in terms of customer density and types of assets.

SAIFI

EDB reliability results since 2019 as published by the Commerce Commission show EIL is a leading network in minimising the number of supply interruptions to customers. Generally specific actions to improve SAIFI are not required. Latest benchmarking figures are shown in the following graphs:

Figure 48: SAIFI Class B Benchmarking





Figure 49: SAIFI Class C Benchmarking



SAIDI

Similar to SAIFI, SAIDI reliability results suggest that no specific actions to improve SAIDI are required, as EIL is a leading network in minimising the amount of time that customers have no supply.

Figure 50: SAIDI Class B Benchmarking






Figure 51: SAIDI Class C Benchmarking



Load Factor

EIL’s peak during winter months does not coincide with the LSI peak which tends to be to be late spring. Controlling the peak load was therefore not required in winter, resulting in a higher peak without an increase in energy consumption, thus having an adverse effect on load factor. EIL supplies mostly urban residential customers and the load factor achieved is typical of such a customer mix. None of this will have any adverse effect on the cost to customers.

Figure 52: Load Factor Comparison




EIL’s load factor is expected to remain at current levels in the short term. Improving the load factor would require influencing customer’s consumption patterns. This is challenging, as we do not have any direct control over the price to customers. Line charge incentives offered are typically repackaged by retailers in their tariffs.

Loss Ratio

Energy efficiency is getting increased attention, but in general it is uneconomical to improve efficiency of primary assets in order to minimise losses. The financial incentive for a network company to reduce losses is minimal. The exception is when the losses lead to other technical issues such as poor voltage or exceeding the current rating of equipment. Upgrading network equipment as growth occurs will maintain losses at present levels.

In order to determine network losses accurately, accurate consumption data is required. Smart meters are providing improved data and assist with the identification of high loss areas, allowing focussed interventions to address issues.

Figure 53: Loss Ratio Comparison




Comparison with other network companies shows EIL’s network as moderately efficient. However, not all networks have access to accurate data so comparisons may be misleading.

Capacity Utilisation

Capacity utilisation on the network can be improved through optimisation of transformer sizes and numbers. However, there is often a trade-off between utilisation and standardisation. A larger, standard size transformer will in most cases be less expensive than a smaller, non-standard transformer sized to improve utilisation. It is generally more cost effective to replace overloaded transformers with appropriately sized standard units than to build bespoke transformers to increase utilisation.

EIL has the highest capacity utilisation factor of local EDBs and does not require improvement interventions in this regard. Smart meters will provide improved equipment loading profiles which would facilitate planning accuracy and lead to better equipment utilisation.

Figure 54: Capacity Utilisation Comparison



Financial Efficiency

Financial efficiency ratios do not raise any concerns when benchmarked against industry peers. These comparisons are presented in the following figures. These figures show:

- Operational expenditure per ICP is in the low band.
- Operational expenditure per km of network length is relatively high. This mainly due to EIL's high customer density. Similar results are observed from comparable high density distribution networks.
- Operational expenditure per MVA of distribution transformer capacity is good, reflecting the high-capacity utilisation.
- Non-network Operational expenditure measures are comparatively high due to the characteristics of the network. The influence of the network characteristics is clear when these measures are compared with those of OtagoNet and The Power Company Limited which operate under the same financial arrangements.

Figure 55: Network \$OPEX/ICP Benchmarking




Figure 56: Network \$OPEX/km Benchmarking




Figure 57: Network \$OPEX/MVA Benchmarking




Figure 58: Non-Network \$OPEX/ICP Benchmarking




Figure 59: Non-Network \$OPEX/km Benchmarking





Figure 60: Non-Network \$OPEX/MVA Benchmarking





Annexures

SECTION CONTENTS

Fat Bastard Pies, Invercargill

Annexure 1 – Policies, Standards and Procedures	186
Annexure 2 – Customer Engagement Questionnaire	190
Annexure 3 – Disclosure Schedules	198
Annexure 4 – References	224
Annexure 5 – AMP Disclosure Table	225
Annexure 6 – Directors Approval	237

ANNEXURE 1 – POLICIES, STANDARDS AND PROCEDURES

Asset Management and Operating Policies

AM-POL-0001	Sale of Scrap Metal Policy
AM-POL-0002	Earth Safety and Maintenance Policy
AM-POL-0003	Mobile Equipment Policy
AM-POL-0004	Streetlight Connections Policy
AM-POL-0006	Asset Management Policy Statement
AM-POL-0007	Public Safety in Asset Design Policy V1
AM-POL-0008	Power Pole Selection and Disposal Policy
AM-POL-0009	Easement Policy
AM-POL-0011	Approvals Required from Chief Engineer Policy
AM-POL-0012	Asset Management Policy
AM-POL-0013	Safety in Design Framework - Policy
OP-POL-0001	Traffic Management Plans Policy
OP-POL-0002	Live Line Selection and Training Policy
OP-POL-0004	Standby for Faults Response Policy
OP-POL-0006	COVID-19 – Critical and Essential Works Policy
OP-POL-0007	Cable Location Policy

Asset Management and Operating Standards

AM-STD-0001	Distribution Earth Installation Standard
AM-STD-0002	Installation Connection Standard
AM-STD-0003	Maintenance of Zone Transformers Standard
AM-STD-0004	Painting of Power Transformers Standard
AM-STD-0005	Air Break Switch Inspection Standard
AM-STD-0006	Network Design Standard
AM-STD-0008	Maintenance of Mineral Insulating Oil Standard
AM-STD-0009	Overhead Lines Inspection Standard
AM-STD-0010	Site Physical Security - Restricted Areas Standard
AM-STD-0011	Major Overhauls of Zone Transformers Standard
AM-STD-0012	Safety in Design Standard
AM-STD-0013	New Network Asset and Material Approval Standard
AM-STD-0014	Network Constructed by Independent Contractors Standard
AM-STD-0015	EXTERNAL - AMST D1750-13 - International Standard - Standard Test Method for the Determination of Gassing Characteristics of Insulating Liquids Under Thermal Stress
AM-STD-0017	Fencing Standard
AM-STD-0018	EXTERNAL - BS 148:2009 - Reclaimed Mineral Insulating Oil For Transformers And Switchgear - Specification - British Standard
AM-STD-0019	Vegetation Management Standard
AM-STD-0020	Ring Main Unit – Standard Specification
AM-STD-0021	PowerNet Network Lock and Key Standard
AM-STD-0022	Network Fuse Protection Standard
AM-STD-0024	Substation Safety Signage Standard
AM-STD-0025	Protection Design Setting Philosophy Standard
AM-STD-0026	EXTERNAL - EEA Resilience Guide 2022
OP-STD-0001	Network Faults Standard
OP-STD-0003	Security of Supply - Participant Outage Plan Standard
OP-STD-0004	Load Control Standard
OP-STD-0005	Planned Outages and Operating Orders Standard
OP-STD-0006	Major Network Disruptions and Storm Gallery Standard
OP-STD-0007	Fault Response Standard
OP-STD-0008	Radio Telephone Communications Standard
OP-STD-0011	Operating Sequence Standard
OP-STD-0012	SmartCo - PowerNet Installation Requirements and Guidelines

Asset Management and Operating Procedures

AM-PRO-0001	Earth Test Procedure
AM-PRO-0008	Loss Factor Calculation Procedure
AM-PRO-0010	Cable Testing Procedure
AM-PRO-0013	Tendering Procedure
AM-PRO-0014	Commissioning Network Equipment Procedure
AM-PRO-0020	Transformer Maintenance Procedure
AM-PRO-0023	Project Close Out Issue Procedure
AM-PRO-0024	Design and Development Procedure
AM-PRO-0025	Project Control Procedure
AM-PRO-0026	Materials Management Procedure
AM-PRO-0028	Progressing the Project Procedure
AM-PRO-0029	Control of SCADA Computers Procedure
AM-PRO-0033	Setting up the Project Procedure
AM-PRO-0035	Safety In Design Procedure
OP-PRO-0057	Completion and Livening of Customer Connections on PowerNet Networks Procedure
OP-PRO-0002	Customer Service Performance Procedure
OP-PRO-0006	Identification of Cables Procedure
OP-PRO-0010	Ladder Management Procedure
OP-PRO-0013	Second Point of Attachment Procedure
OP-PRO-0017	System Control Station Log Book Procedure
OP-PRO-0023	Network Access Procedure
OP-PRO-0026	Entry to EIL Underground Substations Procedure
OP-PRO-0027	Work on De-energised Overhead Lines Procedure
OP-PRO-0036	Live LV Work - Install a Pole Mounted LV Three Phase Fuse Carrier for Parallel Connection Procedure
OP-PRO-0043	Confined Space Management Procedure
OP-PRO-0045	Operational Requirements for Live Line Work Procedure
OP-PRO-0047	Transpower GXP Building Access Procedure
OP-PRO-0048	Control of Tags Procedure
OP-PRO-0051	Live LV Work - Weekly Testing, Cleaning, Maintenance for Gloves, EWP & Associated Equipment
OP-PRO-0052	Access to Substations and Switchyards Procedure
OP-PRO-0058	H W Richardson Contracting - Hydro Vacuum Truck Procedure
OP-PRO-0059	ABB Series 2 Switchgear Remote Operating Procedure
OP-PRO-0060	ENTECH Halo Switchgear Remote Operating Procedure
OP-PRO-0061	Earthing Upgrade Installation and Final Connection Procedure
OP-PRO-0062	High Voltage Live Work - System Control Procedure
OP-PRO-0064	Long and Crawford Switchgear Remote Opening Procedure
OP-PRO-0065	Spiking of Cables Procedure
OP-PRO-0066	Securing Wooden or Concrete Poles for Travel (Failsafe Method) - Procedure
OP-PRO-0067	Working with Helicopters Procedure
OP-PRO-0068	Manual Reclosing of High Voltage Circuits Following a Fault Procedure

Asset Management and Operating Plans and Specifications

AM-PLN-5002	Asset Fleet Plan - Capacitors
AM-PLN-5003	Asset Fleet Plan - Distribution Transformers
AM-PLN-5004	Asset Fleet Plan - Field CB
AM-PLN-5005	Asset Fleet Plan - Generators and Generator Controllers
AM-PLN-5006	Asset Fleet Plan - LV Outdoor Cubicles
AM-PLN-5007	Asset Fleet Plan - Poles
AM-PLN-5008	Asset Fleet Plan - RMU
AM-PLN-5009	Asset Fleet Plan - StatCom
AM-PLN-5010	Asset Fleet Plan - Switchgear
AM-PLN-5011	Asset Fleet Plan - Trees
AM-PLN-5012	Asset Fleet Plan - Power Transformers
AM-PLN-5013	Asset Fleet Plan - Instrument Transformer
AM-PLN-5014	Asset Fleet Plan - Neutral Earth Resistor
AM-PLN-5015	Asset Fleet Plan - Regulator Transformer
AM-PLN-5016	Asset Fleet Plan - Oil Separator
AM-PLN-5017	Asset Fleet Plan - Distribution Earth
AM-PLN-5018	Asset Fleet Plan - CT-VT Units
AM-PLN-5019	Asset Fleet Plan - Fault Throw Switch
AM-PLN-5020	Asset Fleet Plan - Injection Station
AM-PLN-5021	Asset Fleet Plan - Oil separator
AM-PLN-5022	Asset Fleet Plan - Overhead Lines
AM-PLN-5023	Asset Fleet Plan - Battery Chargers
AM-PLN-5024	Asset Fleet Plan - Fault Indicator
AM-PLN-5025	Asset Fleet Plan - Power Supply
AM-PLN-5026	Asset Fleet Plan - Voltage Regulating Relay
AM-PLN-5028	Asset Fleet Plan - Surge Diverter
AM-PLN-5029	Asset Fleet Plan - Zone Sub
AM-PLN-5030	Asset Fleet Plan - RTU
AM-PLN-5031	Asset Fleet Plan - Cables
AM-PLN-5032	Asset Fleet Plan - Batteries
AM-PLN-5033	Asset Fleet Plan - Protection Relay
AM-SPE-0002	Wiring and Connection of Streetlights Specification
AM-SPE-0003	Standard Construction Specification

ANNEXURE 2 – CUSTOMER ENGAGEMENT QUESTIONNAIRE

Telephone Survey Questions

I'm calling from Research First on behalf of PowerNet.

We are not selling anything or asking you to change anything. We are conducting a survey to help PowerNet deliver the right levels of service to network customers and plan effectively for your future needs.

To thank you for your time and effort, everyone who completes this survey will go into the draw to win 1 of 5 \$100 cash prizes,

Can I speak to <NAME>, or the person mainly or jointly responsible for paying the electricity account or making decisions about power supply?

The survey will take about 15 minutes to complete. Are you able to help today?

If necessary: PowerNet is relevant to all electricity users in Southland, West Otago, Queenstown- Lakes, Central Otago and Stewart Island. I will explain further later in the survey.

If required: Please know that Research First is a professional market research company, so we abide by a Code of Practice. This means we treat everything you tell us as totally confidential. You have the right to decline or withdraw from the research at any time.

If required: Phone numbers have been supplied by PowerNet from the customer database. We will not use numbers for any other purpose. You can call PowerNet on (03) 211-1899 with any queries.

S1	I just have to check if you are eligible... Are you a PowerNet staff member, or are any of your immediate family a PowerNet staff member?	
	<input type="radio"/>	No
	<input type="radio"/>	Yes <survey will end>

Awareness and Perceptions of Performance

1.	Have you heard of PowerNet?	
	<input type="radio"/>	Yes – Q2
	<input type="radio"/>	No – Q4
2.	Where have you most recently seen or heard about PowerNet? <do not prompt> <route to 3 except if Facebook mentioned>	
	<input type="radio"/>	Sponsorship – St John
	<input type="radio"/>	Sponsorship – Tour of Southland
	<input type="radio"/>	Sponsorship – other
	<input type="radio"/>	Website
	<input type="radio"/>	Facebook page
	<input type="radio"/>	Logos on vehicles
	<input type="radio"/>	Newspaper ads
	<input type="radio"/>	LinkedIn
	<input type="radio"/>	Other specify
	<input type="radio"/>	Don't Know

3.	On a scale of 1 to 5 where 1 = 'very poor', 2 = 'poor', 3 = 'neutral', 4 = 'good', and 5 = 'very good', how would you rate PowerNet's performance on the following aspects over the last 12 months? <Don't read out 'Don't know'>						
	Caring for customers	1	2	3	4	5	6
	Supporting the community	1	2	3	4	5	6
	Being safety conscious	1	2	3	4	5	6
	Efficiency in service response	1	2	3	4	5	6
	Reliability of power supply	1	2	3	4	5	6

SECTION 2: Planned Interruptions to Service

4a	Given the frequency for a planned interruption is one every two years, is this an acceptable frequency for a planned interruption?	
	<input type="radio"/> Yes <input type="radio"/> No	
4b	Given the duration for a planned interruption on average is 4 hours, is this an acceptable duration for a planned interruption?	
	<input type="radio"/> Yes <input type="radio"/> No	
5	Which of the following options would you prefer?	
	<input type="radio"/> Retain the current plan: 1 interruption of 4 hours every 2 years	
	<input type="radio"/> Have more frequent interruptions but of shorter duration	
	<input type="radio"/> Have less frequent interruptions but of a longer duration	
	<input type="radio"/> Don't know <do not prompt>	

SECTION 3: Communications – Planned Interruptions

6	It is now your retailer's responsibility to notify you of any planned interruptions. Have you received advice of a planned electricity interruption during the last 6 months?	
	<input type="radio"/> Yes – Q7	
	<input type="radio"/> No – Q11	
	<input type="radio"/> Don't know – Q11 – DO NOT READ OUT	

7	Can you remember how much notice you were given?	
	<input type="radio"/>	1-2 day -Q8
	<input type="radio"/>	3-4 days -Q8
	<input type="radio"/>	5-6 days -Q8
	<input type="radio"/>	1 week -Q8
	<input type="radio"/>	2 weeks -Q8
	<input type="radio"/>	More than 2 weeks -Q8
	<input type="radio"/>	Don't know – Q11 – DO NOT READ OUT
8	Do you feel that you were given enough notice of this planned interruption?	
	<input type="radio"/>	Yes
	<input type="radio"/>	No
	<input type="radio"/>	Don't know – DO NOT READ OUT
9	Were you satisfied with the amount of information given to you about this planned interruption?	
	<input type="radio"/>	Yes
	<input type="radio"/>	No
	<input type="radio"/>	Don't know – DO NOT READ OUT
10	What additional information on an outage is needed? <i>Probe to clarify.</i>	
	<input type="radio"/>	Open comment
	<input type="radio"/>	Don't know
	<input type="radio"/>	No additional information is needed

SECTION 4: Unplanned Interruptions

11	Who would you telephone in the event your power supply has been unexpectedly interrupted? <i>Do not prompt.</i>	
	<input type="radio"/>	PowerNet
	<input type="radio"/>	Retailer/Power company
	<input type="radio"/>	Local government
	<input type="radio"/>	Other (specify)
	<input type="radio"/>	No-one

12	Where would you prefer to receive communication from PowerNet about outages? DO NOT READ OUT, randomise	
	<input type="radio"/>	PowerNet Facebook Page
	<input type="radio"/>	PowerNet 0800 faults number (0800 808 587)
	<input type="radio"/>	The internet (Google, firefox, etc)
	<input type="radio"/>	PowerNet's Outage Website Page? https://outages.powernet.co.nz/
	<input type="radio"/>	Text message
13	Can you recall when the last unexpected interruption to your power supply was?	
	<input type="radio"/>	Yes – In the last week – Q14
	<input type="radio"/>	In the last month – Q14
	<input type="radio"/>	2-3 months ago – Q14
	<input type="radio"/>	3-6 months ago – Q14
	<input type="radio"/>	More than 6 months ago – Q19
	<input type="radio"/>	Never had an unexpected interruption to power at this address – Q19
	<input type="radio"/>	Don't know – Q19 – DO NOT READ OUT
14	Do you recall how long your most recent power cut lasted? Read if necessary	
	<input type="radio"/>	1-2 hours
	<input type="radio"/>	2-3 hours
	<input type="radio"/>	3-4 hours
	<input type="radio"/>	More than 4 hours
	<input type="radio"/>	Don't know – DO NOT READ OUT
15	On a scale of 1 to 5 where 1 is no impact at all, 2 is minor impact, 3 is neutral, 4 is moderate impact and 5 is major impact, how much impact did your last power cut have on you?	
	<input type="radio"/>	No impact
	<input type="radio"/>	Minor impact
	<input type="radio"/>	Neutral
	<input type="radio"/>	Moderate impact
	<input type="radio"/>	Major impact
	<input type="radio"/>	Don't know – DO NOT READ OUT

16	Who did you call when the supply was interrupted?	
	<input type="radio"/>	PowerNet – Q17
	<input type="radio"/>	Retailer/Power company – Q19
	<input type="radio"/>	Local government – Q19
	<input type="radio"/>	No one – Q19
	<input type="radio"/>	Other (specify) – Q19
	<input type="radio"/>	Don't know/can't remember – Q19 – DO NOT READ OUT

17	On a scale of 1 to 5 where 1 = 'very dissatisfied', 2 = 'dissatisfied', 3 = 'neutral', 4 = 'satisfied', and 5 = 'very satisfied', how satisfied were you with...?						
		Very dissatisfied	Dissatisfied	Neutral	Satisfied	Very satisfied	Don't know
	The system you had to use to get information	1	2	3	4	5	6
	The information supplied was satisfactory	1	2	3	4	5	6

If coded 1 or 2 at Q17 – go to Q18

If coded 3,4,5 at Q17 – go to Q19

18	<If coded 1 or 2 at Q17> What could be done to improve this process? Probe to clarify.	
	<input type="radio"/>	Open comment
	<input type="radio"/>	Don't know

19	In the event of an unexpected interruption to your electricity supply, what do you consider would be a reasonable amount of time before the electricity supply is restored to your home?	
	<input type="radio"/>	Under 30 minutes
	<input type="radio"/>	30min - 1 hour
	<input type="radio"/>	1-2 hours
	<input type="radio"/>	2-3 hours
	<input type="radio"/>	3-4 hours
	<input type="radio"/>	More than 4 hours
	<input type="radio"/>	Don't know – DO NOT READ OUT
	<input type="radio"/>	Don't care – DO NOT READ OUT

20	In the event of an unexpected interruption to your electricity supply, what is the most important information that you wish to receive? Do not prompt, select all that apply.	
	<input type="radio"/>	Accurate time power will be restored
	<input type="radio"/>	Reason for fault
	<input type="radio"/>	That they know the problem and that it is being fixed
	<input type="radio"/>	Other (specify)
	<input type="radio"/>	No information required
21	Costs have gone up significantly due to global supply chain constraints. NZ inflation over the last year has been 6.9% which has increased costs of materials and labour to maintain our networks and service levels. Because of these factors, what percentage increase in line charges are you willing to pay to keep the same quality and reliability of supply?	
<input type="radio"/>	(Open comment - % textbox)	

SECTION 5: Evolving Technology

22	I am going to read out a list of technologies. For each of these I would like to know if you: Already have it, Would consider purchasing it, Would not consider purchasing it, Or, if you have never heard of it before. Read out.				
		Already have it	Considering purchasing it	Not Considering it	Never heard of it before
	Solar Panels or Photovoltaic Panels	1	2	3	4
	Wind Turbines	1	2	3	4
	Battery Energy Storage System	1	2	3	4
	EVs	1	2	3	4
	Hot Water Heat Pumps	1	2	3	4
	Space Heating Heat Pumps	1	2	3	4
	Smart Home Technologies (e.g. Smart Controlled Appliances)	1	2	3	4
23	I would like to know which of these technologies you are most interested in. Please tell me which is the 1st, 2nd and 3rd most interesting. Read out. [Rank 1, 2, and 3]				
		Solar Panels or Photovoltaic Panels			
		Wind Turbines			
		Battery Energy Storage System			
		EVs			
		Hot Water Heat Pumps			
		Space Heating Heat Pumps			
		Smart Home Technologies (e.g. Smart Controlled Appliances)			

Solar Panels

24.	If you were given an opportunity to receive an assessment and you found that installing Solar Panels would be the most economic option for yourself (as opposed to fully purchasing energy from the grid), On a scale from 1 to 5, how likely would you be to install Solar Panels? Where 1 = not at all likely, and 5 = very likely.
	<input type="checkbox"/> I am not interested at all
	<input type="checkbox"/> Not likely at all
	<input type="checkbox"/> Unlikely
	<input type="checkbox"/> Neutral
	<input type="checkbox"/> Likely
	<input type="checkbox"/> Very likely
	<input type="checkbox"/> Don't know DO NOT READ OUT

EVs

25.	Which of the following are most important when considering buying an EVs? Please tell me which is the 1st, 2nd and 3rd most important. [Randomise] [Rank 1, 2, and 3] Read out
	<input type="checkbox"/> Saving money on fuel
	<input type="checkbox"/> Reducing emissions
	<input type="checkbox"/> The distance you can drive on a single charge
	<input type="checkbox"/> The purchase price
	<input type="checkbox"/> The size and capability of the vehicle
	<input type="checkbox"/> The number of charging stations in your area
26	Do you have any comments you would like to make about why you would or would not buy solar panels or an EVs?
	<input type="radio"/> Open comment box
	<input type="radio"/> Don't know

Demographics

27	Which of these age groups do you fall into? Read out
	<input type="radio"/> 18-24
	<input type="radio"/> 25-44
	<input type="radio"/> 45-64
	<input type="radio"/> 65+
	<input type="radio"/> Prefer not to say – DO NOT READ OUT

28	At the property where you are currently living/ working, do you...? Read out	
	<input type="radio"/>	Own your dwelling outright
	<input type="radio"/>	Own your dwelling with a mortgage
	<input type="radio"/>	Rent from a private landlord
	<input type="radio"/>	Rent from friends/family
	<input type="radio"/>	Rent from the Council or government
	<input type="radio"/>	Other (specify) – DO NOT READ OUT

29	How many people are in your household / workplace?	
	<input type="radio"/>	How many adults are there, including yourself? Aged 18 years and over. Record number
	<input type="radio"/>	And how many children aged up to 18 are there? Record number
	<input type="radio"/>	Prefer not to say

SECTION 6: Final Comments

30	Finally, are there any other comments you would like to make about PowerNet services?	
	<input type="radio"/>	No comment
	<input type="radio"/>	Happy with service
	<input type="radio"/>	Other (specify)

Company Name **Electricity Invercargill Limited**
AMP Planning Period **1 April 2026 – 31 March 2036**

SCHEDULE 11a: REPORT ON FORECAST CAPITAL EXPENDITURE

This schedule requires a breakdown of forecast expenditure on assets for the current disclosure year and a 10 year planning period. The forecasts should be consistent with the supporting information set out in the AMP. The forecast is to be expressed in both constant price and nominal dollar terms. Also required is a forecast of the value of commissioned assets (i.e., the value of RAB additions)
EDBs must provide explanatory comment on the difference between constant price and nominal dollar forecasts of expenditure on assets in Schedule 14a (Mandatory Explanatory Notes). EDBs must express the information in this schedule (11a) as a specific value rather than ranges. Any supporting information about these values may be disclosed in Schedule 15 (Voluntary Explanatory Notes).
This information is not part of audited disclosure information.

sch ref

	Current Year CY	CY+1	CY+2	CY+3	CY+4	CY+5	CY+6	CY+7	CY+8	CY+9	CY+10
11a(i): Expenditure on Assets Forecast	\$000 (in nominal dollars)										
Consumer connection	850	307	314	765	890	761	1,089	791	807	823	879
System growth	-	-	-	-	-	1,209	453	462	157	-	-
Asset replacement and renewal	5,582	7,960	7,671	7,098	7,928	6,500	5,680	8,363	8,266	8,431	8,910
Asset relocations	7	8	8	8	8	8	9	9	9	9	9
Reliability, safety and environment:											
Quality of supply	175	114	117	63	64	65	66	68	69	70	23
Legislative and regulatory	-	-	-	-	-	-	-	-	-	-	-
Other reliability, safety and environment	686	570	1,271	595	607	3,943	5,248	644	657	670	623
Total reliability, safety and environment	861	685	1,388	658	671	4,008	5,315	712	726	741	646
Expenditure on network assets	7,300	8,960	9,380	8,528	9,496	12,486	12,545	10,337	9,964	10,004	10,445
Expenditure on non-network assets	-	-	-	-	-	-	-	-	-	-	-
Expenditure on assets	7,300	8,960	9,380	8,528	9,496	12,486	12,545	10,337	9,964	10,004	10,445
plus Cost of financing	-	-	-	-	-	-	-	-	-	-	-
less Value of capital contributions	90	215	220	535	623	532	762	554	565	576	615
plus Value of vested assets	-	-	-	-	-	-	-	-	-	-	-
Capital expenditure forecast	7,210	8,745	9,161	7,993	8,873	11,953	11,782	9,783	9,399	9,428	9,830
Assets commissioned	7,700	8,864	9,286	8,299	9,229	12,169	12,127	8,131	9,691	9,757	10,181
	Current Year CY	CY+1	CY+2	CY+3	CY+4	CY+5	CY+6	CY+7	CY+8	CY+9	CY+10
	\$000 (in constant prices)										
Consumer connection	851	307	307	733	836	701	983	701	701	701	733
System growth	-	-	-	-	-	1,113	409	409	136	-	-
Asset replacement and renewal	5,582	7,960	7,506	6,802	7,448	5,987	5,129	7,405	7,175	7,175	7,434
Asset relocations	7	8	8	8	8	8	8	8	8	8	8
Reliability, safety and environment:											
Quality of supply	175	114	114	60	60	60	60	60	60	60	19
Legislative and regulatory	-	-	-	-	-	-	-	-	-	-	-
Other reliability, safety and environment	686	570	1,244	570	570	3,632	4,740	570	570	570	520
Total reliability, safety and environment	861	685	1,358	630	630	3,692	4,800	630	630	630	539
Expenditure on network assets	7,301	8,960	9,178	8,173	8,922	11,501	11,329	9,152	8,649	8,513	8,714
Expenditure on non-network assets	-	-	-	-	-	-	-	-	-	-	-
Expenditure on assets	7,301	8,960	9,178	8,173	8,922	11,501	11,329	9,152	8,649	8,513	8,714
Subcomponents of expenditure on assets (where known)											
Energy efficiency and demand side management, reduction of energy losses	-	-	-	-	-	-	-	-	-	-	-
Overhead to underground conversion	-	-	-	-	-	-	-	-	-	-	-
Research and development	-	-	-	-	-	-	-	-	-	-	-

Company Name **Electricity Invercargill Limited**
 AMP Planning Period **1 April 2026 – 31 March 2036**

SCHEDULE 11a: REPORT ON FORECAST CAPITAL EXPENDITURE

This schedule requires a breakdown of forecast expenditure on assets for the current disclosure year and a 10 year planning period. The forecasts should be consistent with the supporting information set out in the AMP. The forecast is to be expressed in both constant price and nominal dollar terms. Also required is a forecast of the value of commissioned assets (i.e., the value of RAB additions)
 EDBs must provide explanatory comment on the difference between constant price and nominal dollar forecasts of expenditure on assets in Schedule 14a (Mandatory Explanatory Notes). EDBs must express the information in this schedule (11a) as a specific value rather than ranges. Any supporting information about these values may be disclosed in Schedule 15 (Voluntary Explanatory Notes).
 This information is not part of audited disclosure information.

sch ref

	Current Year CY	CY+1	CY+2	CY+3	CY+4	CY+5	CY+6	CY+7	CY+8	CY+9	CY+10
Difference between nominal and constant price forecasts	\$000										
Consumer connection	(1)	-	7	32	54	60	106	91	107	123	146
System growth	-	-	-	-	-	95	44	53	21	-	-
Asset replacement and renewal	-	-	165	296	479	513	551	959	1,091	1,256	1,476
Asset relocations	-	-	0	0	0	1	1	1	1	1	2
Reliability, safety and environment:											
Quality of supply	-	-	3	3	4	5	6	8	9	10	4
Legislative and regulatory	-	-	-	-	-	-	-	-	-	-	-
Other reliability, safety and environment	-	-	27	25	37	311	509	74	87	100	103
Total reliability, safety and environment	-	-	30	27	41	316	515	82	96	110	107
Expenditure on network assets	(1)	-	202	355	574	985	1,216	1,185	1,315	1,491	1,731
Expenditure on non-network assets	-	-	-	-	-	-	-	-	-	-	-
Expenditure on assets	(1)	-	202	355	574	985	1,216	1,185	1,315	1,491	1,731

Commentary on options and considerations made in the assessment of forecast expenditure

EDBs may provide explanatory comment on the options they have considered (including scenarios used) in assessing forecast expenditure on assets for the current disclosure year and a 10 year planning period in Schedule 15

	Current Year CY	CY+1	CY+2	CY+3	CY+4	CY+5
11a(ii): Consumer Connection	\$000 (in constant prices)					
<i>Consumer types defined by EDB*</i>						
Customer Connections (≤ 20 kVA)	77	78	78	78	78	78
Customer Connections (21 to 99 kVA)	68	70	70	70	70	70
Customer Connections (≥ 100 kVA)	154	155	155	155	155	155
Distributed Generation Connection	3	4	4	4	4	4
New Subdivisions	549	-	-	426	529	394
<i>*Include additional rows if needed</i>						
Consumer connection expenditure	851	307	307	733	836	701
less Capital contributions funding consumer connection	596	215	215	513	585	490
Consumer connection less capital contributions	255	92	92	220	251	210
11a(iii): System Growth						
Subtransmission	-	-	-	-	-	-
Zone substations	-	-	-	-	-	787
Distribution and LV lines	-	-	-	-	-	-
Distribution and LV cables	-	-	-	-	-	245
Distribution substations and transformers	-	-	-	-	-	-
Distribution switchgear	-	-	-	-	-	82
Other network assets	-	-	-	-	-	-
System growth expenditure	-	-	-	-	-	1,113
less Capital contributions funding system growth	-	-	-	-	-	-
System growth less capital contributions	-	-	-	-	-	1,113

Company Name **Electricity Invercargill Limited**
AMP Planning Period **1 April 2026 – 31 March 2036**

SCHEDULE 11a: REPORT ON FORECAST CAPITAL EXPENDITURE

This schedule requires a breakdown of forecast expenditure on assets for the current disclosure year and a 10 year planning period. The forecasts should be consistent with the supporting information set out in the AMP. The forecast is to be expressed in both constant price and nominal dollar terms. Also required is a forecast of the value of commissioned assets (i.e., the value of RAB additions)
EDBs must provide explanatory comment on the difference between constant price and nominal dollar forecasts of expenditure on assets in Schedule 14a (Mandatory Explanatory Notes). EDBs must express the information in this schedule (11a) as a specific value rather than ranges. Any supporting information about these values may be disclosed in Schedule 15 (Voluntary Explanatory Notes).
This information is not part of audited disclosure information.

sch ref

	Current Year CY	CY+1	CY+2	CY+3	CY+4	CY+5
99 11a(iv): Asset Replacement and Renewal	\$000 (in constant prices)					
100 Subtransmission	-	-	-	-	-	-
101 Zone substations	11	2,099	1,835	1,051	2,330	869
102 Distribution and LV lines	497	512	382	382	382	382
103 Distribution and LV cables	808	843	991	1,120	1,120	1,120
104 Distribution substations and transformers	1,141	1,187	1,187	1,210	1,210	1,210
105 Distribution switchgear	2,923	3,111	2,902	2,830	2,197	2,197
106 Other network assets	202	209	209	209	209	209
107 Asset replacement and renewal expenditure	5,582	7,960	7,506	6,802	7,448	5,987
108 less Capital contributions funding asset replacement and renewal	-	-	-	-	-	-
109 Asset replacement and renewal less capital contributions	5,582	7,960	7,506	6,802	7,448	5,987

	Current Year CY	CY+1	CY+2	CY+3	CY+4	CY+5
113 11a(v): Asset Relocations	\$000 (in constant prices)					
114 <i>Project or programme*</i>						
115 Asset Relocation Projects	7	8	8	8	8	8
116 [Description of material project or programme]						
117 [Description of material project or programme]						
118 [Description of material project or programme]						
119 [Description of material project or programme]						
120 <i>*include additional rows if needed</i>						
121 All other project or programmes - asset relocations	-	-	-	-	-	-
122 Asset relocations expenditure	7	8	8	8	8	8
123 less Capital contributions funding asset relocations	-	-	-	-	-	-
124 Asset relocations less capital contributions	7	8	8	8	8	8

	Current Year CY	CY+1	CY+2	CY+3	CY+4	CY+5
128 11a(vi): Quality of Supply	\$000 (in constant prices)					
129 <i>Project or programme*</i>						
130 Supply Quality Upgrades - City/Bluff	18	19	19	19	19	19
131 Network Automation Projects	39	41	41	41	41	41
132 Fault Indicator project	118	54	54	-	-	-
133 [Description of material project or programme]						
134 [Description of material project or programme]						
135 <i>*include additional rows if needed</i>						
136 All other projects or programmes - quality of supply	-	-	-	-	-	-
137 Quality of supply expenditure	175	114	114	60	60	60
138 less Capital contributions funding quality of supply	-	-	-	-	-	-
139 Quality of supply less capital contributions	175	114	114	60	60	60

Company Name **Electricity Invercargill Limited**
 AMP Planning Period **1 April 2026 – 31 March 2036**

SCHEDULE 11a: REPORT ON FORECAST CAPITAL EXPENDITURE

This schedule requires a breakdown of forecast expenditure on assets for the current disclosure year and a 10 year planning period. The forecasts should be consistent with the supporting information set out in the AMP. The forecast is to be expressed in both constant price and nominal dollar terms. Also required is a forecast of the value of commissioned assets (i.e., the value of RAB additions).
 EDBs must provide explanatory comment on the difference between constant price and nominal dollar forecasts of expenditure on assets in Schedule 14a (Mandatory Explanatory Notes). EDBs must express the information in this schedule (11a) as a specific value rather than ranges. Any supporting information about these values may be disclosed in Schedule 15 (Voluntary Explanatory Notes).
 This information is not part of audited disclosure information.

sch ref		Current Year CY	CY+1	CY+2	CY+3	CY+4	CY+5
141							
142							
143	11a(vii): Legislative and Regulatory						
144	Project or programme*	\$000 (in constant prices)					
145	[Description of material project or programme]						
146	[Description of material project or programme]						
147	[Description of material project or programme]						
148	[Description of material project or programme]						
149	[Description of material project or programme]						
150	*include additional rows if needed						
151	All other projects or programmes - legislative and regulatory						
152	Legislative and regulatory expenditure						
153	less Capital contributions funding legislative and regulatory						
154	Legislative and regulatory less capital contributions						
155							
156		Current Year CY	CY+1	CY+2	CY+3	CY+4	CY+5
157	11a(viii): Other Reliability, Safety and Environment						
158	Project or programme*	\$000 (in constant prices)					
159	Earth Upgrades - City/Bluff	206	77	77	77	77	77
160	Pillar Box Lid Upgrade	149	159	159	159	159	159
161	Oil-Filled Cable Work	-	-	673	-	-	3,062
162	LV Tie Point Disconnectors	283	284	284	284	284	284
163	Fibre Installation	48	50	50	50	50	50
164	*include additional rows if needed						
165	All other projects or programmes - other reliability, safety and environment						
166	Other reliability, safety and environment expenditure	686	570	1,244	570	570	3,632
167	less Capital contributions funding other reliability, safety and environment						
168	Other reliability, safety and environment less capital contributions	686	570	1,244	570	570	3,632
169							
170		Current Year CY	CY+1	CY+2	CY+3	CY+4	CY+5
171							
172	11a(bx): Non-Network Assets						
173	Routine expenditure	\$000 (in constant prices)					
174	Project or programme*						
175	[Description of material project or programme]						
176	[Description of material project or programme]						
177	[Description of material project or programme]						
178	[Description of material project or programme]						
179	[Description of material project or programme]						
180	*include additional rows if needed						
181	All other projects or programmes - routine expenditure						
182	Routine expenditure						
183	Atypical expenditure						
184	Project or programme*						
185	[Description of material project or programme]						
186	[Description of material project or programme]						
187	[Description of material project or programme]						
188	[Description of material project or programme]						
189	[Description of material project or programme]						
190	*include additional rows if needed						
191	All other projects or programmes - atypical expenditure						
192	Atypical expenditure						
193							
194	Expenditure on non-network assets						

Company Name **Electricity Invercargill Limited**
AMP Planning Period **1 April 2026 – 31 March 2036**

SCHEDULE 11b: REPORT ON FORECAST OPERATIONAL EXPENDITURE

This schedule requires a breakdown of forecast operational expenditure for the disclosure year and a 10 year planning period. The forecasts should be consistent with the supporting information set out in the AMP. The forecast is to be expressed in both constant price and nominal dollar terms.

sch ref		Current Year CY	CY+1	CY+2	CY+3	CY+4	CY+5	CY+6	CY+7	CY+8	CY+9	CY+10
7												
8												
9	Operational Expenditure Forecast	\$000 (in nominal dollars)										
10	Service interruptions and emergencies	604	638	652	666	679	693	707	721	735	750	765
11	Vegetation management	2	3	3	3	3	3	3	3	3	3	3
12	Routine and corrective maintenance and inspection	1,616	1,567	1,601	1,635	1,668	1,701	1,735	1,770	1,805	1,841	1,878
13	Asset replacement and renewal	183	190	195	199	203	207	211	215	219	224	228
14	Network Opex	2,406	2,398	2,451	2,503	2,553	2,604	2,656	2,709	2,763	2,818	2,875
15	System operations and network support	1,994	1,755	1,794	1,831	1,868	1,905	1,943	1,982	2,022	2,062	2,104
16	Business support	2,517	2,382	2,470	2,485	2,535	2,586	2,637	2,690	2,744	2,799	2,855
17	Non-network solutions provided by a related party or third party											
18	Non-network opex	4,511	4,137	4,264	4,317	4,403	4,491	4,581	4,672	4,766	4,861	4,958
19	Operational expenditure	6,917	6,535	6,715	6,819	6,955	7,095	7,236	7,381	7,529	7,679	7,833
20		Current Year CY	CY+1	CY+2	CY+3	CY+4	CY+5	CY+6	CY+7	CY+8	CY+9	CY+10
21												
22		\$000 (in constant prices)										
23	Service interruptions and emergencies	604	638	638	638	638	638	638	638	638	638	638
24	Vegetation management	2	3	3	3	3	3	3	3	3	3	3
25	Routine and corrective maintenance and inspection	1,616	1,567	1,567	1,567	1,567	1,567	1,567	1,567	1,567	1,567	1,567
26	Asset replacement and renewal	183	190	190	190	190	190	190	190	190	190	190
27	Network Opex	2,406	2,398	2,398	2,398	2,398	2,398	2,398	2,398	2,398	2,398	2,398
28	System operations and network support	1,994	1,755	1,755	1,755	1,755	1,755	1,755	1,755	1,755	1,755	1,755
29	Business support	2,517	2,382	2,417	2,382	2,382	2,382	2,382	2,382	2,382	2,382	2,382
30	Non-network solutions provided by a related party or third party											
31	Non-network opex	4,511	4,137	4,172	4,137	4,137	4,137	4,137	4,137	4,137	4,137	4,137
32	Operational expenditure	6,917	6,535	6,570	6,535	6,535	6,535	6,535	6,535	6,535	6,535	6,535
33	Subcomponents of operational expenditure (where known)											
34												
35												
36	Energy efficiency and demand side management, reduction of energy losses	150	150	150	150	150	150	150	150	150	150	150
37	Direct billing*											
38	Research and Development											
39	Insurance	231	229	229	229	229	229	229	229	229	229	229
40	* Direct billing expenditure by suppliers that direct bill the majority of their consumers											
41												
42												
43		Current Year CY	CY+1	CY+2	CY+3	CY+4	CY+5	CY+6	CY+7	CY+8	CY+9	CY+10
44												
45	Difference between nominal and real forecasts	\$000										
46	Service interruptions and emergencies	-	-	14	28	41	55	69	83	97	112	127
47	Vegetation management	-	-	0	0	0	0	0	0	0	0	1
48	Routine and corrective maintenance and inspection	-	-	34	68	101	134	168	203	238	274	311
49	Asset replacement and renewal	-	-	4	8	12	16	20	25	29	33	38
50	Network Opex	-	-	53	104	154	205	257	311	365	420	476
51	System operations and network support	-	-	39	76	113	150	188	227	267	307	349
52	Business support	-	-	53	104	153	204	256	308	362	417	473
53	Non-network solutions provided by a related party or third party	-	-	-	-	-	-	-	-	-	-	-
54	Non-network opex	-	-	92	180	266	354	444	536	629	724	822
55	Operational expenditure	-	-	145	284	420	560	701	846	994	1,144	1,298
56												
57	Commentary on options and considerations made in the assessment of forecast expenditure											
58	<i>EDBs may provide explanatory comment on the options they have considered (including scenarios used) in assessing forecast operational expenditure for the current disclosure year and a 10 year planning period in Schedule 15.</i>											

Company Name **Electricity Invercargill Limited**

AMP Planning Period **1 April 2026 – 31 March 2036**

SCHEDULE 12a: REPORT ON ASSET CONDITION

This schedule requires a breakdown of asset condition by asset class as at the start of the forecast year. The data accuracy assessment relates to the percentage values disclosed in the asset condition columns. Also required is a forecast of the percentage of units to be replaced in the next 5 years. All information should be consistent with the information provided in the AMP and the expenditure on assets forecast in Schedule 11a. All units relating to cable and line assets, that are expressed in km, refer to circuit lengths.

sch ref

Asset condition at start of planning period (percentage of units by grade)														
sch ref	Voltage	Asset category	Asset class	Units	H1	H2	H3	H4	H5	Grade unknown	Data accuracy (1-4)	% of asset forecast to be replaced in next 5 years		
7														
9														
10	All	Overhead Line	Concrete poles / steel structure	No.	-	-	-	41.24%	57.97%	0.79%	3			
11	All	Overhead Line	Wood poles	No.	-	-	73.27%	22.68%	2.58%	1.47%	3			
12	All	Overhead Line	Other pole types	No.	N/A	N/A	N/A	N/A	N/A	N/A	N/A			
13	HV	Subtransmission Line	Subtransmission OH up to 66kV conductor	km	-	-	15.98%	82.76%	0.37%	0.88%	3			
14	HV	Subtransmission Line	Subtransmission OH 110kV+ conductor	km	N/A	N/A	N/A	N/A	N/A	N/A	N/A			
15	HV	Subtransmission Cable	Subtransmission UG up to 66kV (XLPE)	km	-	40.91%	13.64%	21.21%	22.73%	1.51%	3			
16	HV	Subtransmission Cable	Subtransmission UG up to 66kV (Oil pressurised)	km	-	80.00%	20.00%	-	-	-	3			
17	HV	Subtransmission Cable	Subtransmission UG up to 66kV (Gas pressurised)	km	N/A	N/A	N/A	N/A	N/A	N/A	N/A			
18	HV	Subtransmission Cable	Subtransmission UG up to 66kV (PILC)	km	N/A	N/A	N/A	N/A	N/A	N/A	N/A			
19	HV	Subtransmission Cable	Subtransmission UG 110kV+ (XLPE)	km	N/A	N/A	N/A	N/A	N/A	N/A	N/A			
20	HV	Subtransmission Cable	Subtransmission UG 110kV+ (Oil pressurised)	km	N/A	N/A	N/A	N/A	N/A	N/A	N/A			
21	HV	Subtransmission Cable	Subtransmission UG 110kV+ (Gas Pressurised)	km	N/A	N/A	N/A	N/A	N/A	N/A	N/A			
22	HV	Subtransmission Cable	Subtransmission UG 110kV+ (PILC)	km	N/A	N/A	N/A	N/A	N/A	N/A	N/A			
23	HV	Subtransmission Cable	Subtransmission submarine cable	km	N/A	N/A	N/A	N/A	N/A	N/A	N/A			
24	HV	Zone substation Buildings	Zone substations up to 66kV	No.	-	20.00%	20.00%	60.00%	-	-	4			
25	HV	Zone substation Buildings	Zone substations 110kV+	No.	N/A	N/A	N/A	N/A	N/A	N/A	N/A			
26	HV	Zone substation switchgear	22/33kV CB (Indoor)	No.	-	8.33%	-	83.33%	-	8.33%	3			
27	HV	Zone substation switchgear	22/33kV CB (Outdoor)	No.	N/A	N/A	N/A	N/A	N/A	N/A	N/A			
28	HV	Zone substation switchgear	33kV Switch (Ground Mounted)	No.	N/A	N/A	N/A	N/A	N/A	N/A	N/A			
29	HV	Zone substation switchgear	33kV Switch (Pole Mounted)	No.	-	-	-	-	-	-	N/A			
30	HV	Zone substation switchgear	33kV RMU	No.	N/A	N/A	N/A	N/A	N/A	N/A	N/A			
31	HV	Zone substation switchgear	50/66/110kV CB (Indoor)	No.	N/A	N/A	N/A	N/A	N/A	N/A	N/A			
32	HV	Zone substation switchgear	50/66/110kV CB (Outdoor)	No.	N/A	N/A	N/A	N/A	N/A	N/A	N/A			
33	HV	Zone substation switchgear	3.3/6.6/11/22kV CB (ground mounted)	No.	-	2.00%	-	96.00%	-	2.00%	4			
34	HV	Zone substation switchgear	3.3/6.6/11/22kV CB (pole mounted)	No.	N/A	N/A	N/A	N/A	N/A	N/A	N/A			
35														

Company Name	Electricity Invercargill Limited
AMP Planning Period	1 April 2026 – 31 March 2036

SCHEDULE 12a: REPORT ON ASSET CONDITION

This schedule requires a breakdown of asset condition by asset class as at the start of the forecast year. The data accuracy assessment relates to the percentage values disclosed in the asset condition columns. Also required is a forecast of the percentage of units to be replaced in the next 5 years. All information should be consistent with the information provided in the AMP and the expenditure on assets forecast in Schedule 11a. All units relating to cable and line assets, that are expressed in km, refer to circuit lengths.

sch ref

		Asset condition at start of planning period (percentage of units by grade)										
	Voltage	Asset category	Asset class	Units	H1	H2	H3	H4	H5	Grade unknown	Data accuracy (1-4)	% of asset forecast to be replaced in next 5 years
36												
37												
38												
39	HV	Zone Substation Transformer	Zone Substation Transformers	No.	-	28.57%	14.29%	57.14%	-	-	4	
40	HV	Distribution Line	Distribution OH Open Wire Conductor	km	-	0.36%	47.66%	35.71%	16.11%	0.16%	3	
41	HV	Distribution Line	Distribution OH Aerial Cable Conductor	km	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
42	HV	Distribution Line	SWER conductor	km	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
43	HV	Distribution Cable	Distribution UG XLPE or PVC	km	-	0.35%	0.97%	31.50%	61.41%	5.77%	3	
44	HV	Distribution Cable	Distribution UG PILC	km	0.05%	-	10.00%	77.96%	11.90%	0.08%	3	
45	HV	Distribution Cable	Distribution Submarine Cable	km	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
46	HV	Distribution switchgear	3.3/6.6/11/22kV CB (pole mounted) - reclosers and sectionalisers	No.	-	-	-	100.00%	-	-	4	
47	HV	Distribution switchgear	3.3/6.6/11/22kV CB (Indoor)	No.	-	-	-	-	-	-	N/A	
48	HV	Distribution switchgear	3.3/6.6/11/22kV Switches and fuses (pole mounted)	No.	3.00%	6.67%	10.00%	26.66%	7.00%	46.67%	3	
49	HV	Distribution switchgear	3.3/6.6/11/22kV Switch (ground mounted) - except RMU	No.	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
50	HV	Distribution switchgear	3.3/6.6/11/22kV RMU	No.	0.33%	44.08%	3.95%	42.43%	4.93%	4.28%	4	
51	HV	Distribution Transformer	Pole Mounted Transformer	No.	-	-	67.50%	25.00%	-	7.50%	4	
52	HV	Distribution Transformer	Ground Mounted Transformer	No.	-	0.91%	8.86%	84.32%	3.86%	2.05%	4	
53	HV	Distribution Transformer	Voltage regulators	No.	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
54	HV	Distribution Substations	Ground Mounted Substation Housing	No.	-	-	-	-	-	100.00%	1	
55	LV	LV Line	LV OH Conductor	km	-	0.60%	33.22%	55.06%	10.15%	0.97%	3	
56	LV	LV Cable	LV UG Cable	km	-	7.08%	24.50%	50.70%	17.30%	0.41%	3	
57	LV	LV Streetlighting	LV OH/UG Streetlight circuit	km	-	4.99%	7.32%	77.45%	8.65%	1.59%	3	
58	LV	Connections	OH/UG consumer service connections	No.	-	7.82%	33.82%	42.90%	13.64%	1.82%	3	
59	All	Protection	Protection relays (electromechanical, solid state and numeric)	No.	-	-	23.68%	73.68%	2.11%	0.53%	3	
60	All	SCADA and communications	SCADA and communications equipment operating as a single system	Lot	-	100.00%	-	-	-	-	1	
61	All	Capacitor Banks	Capacitors including controls	No.	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
62	All	Load Control	Centralised plant	Lot	-	100.00%	-	-	-	-	3	
63	All	Load Control	Relays	No.	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
64	All	Civils	Cable Tunnels	km	N/A	N/A	N/A	N/A	N/A	N/A	N/A	

Company Name: **Electricity Invercargill Limited**
 AMP Planning Period: **1 April 2026 – 31 March 2036**

SCHEDULE 12b: REPORT ON FORECAST CAPACITY

This schedule requires a breakdown of current and forecast capacity and constraints for each zone substation. The data provided should be consistent with the information provided in the AMP. Information provided in this table should relate to the operation of the network in its normal steady state configuration.

Subst	12b(i): System Growth - Zone Substations																		Forecast				Year of any forecast constraint				Constraint solution		Temporary constraint solution		Explanation				
	Existing Zone Substations	Current peak load (MVA)	Installed firm Capacity (MVA)	Security of Supply Classification (Type)	Transfer Capacity (MVA)	Utilisation of Installed Firm Capacity %	Installed Firm Capacity +5 years (MVA)	Utilisation of Installed Firm Capacity +5 yrs %	Installed Firm Capacity +5 years (cause)	Current peak load period	Installed operating capacity (MVA)	Current security of supply classification (Type)	Current constraint type	Current available capacity (MVA)	Peak load period 5 yrs	Available capacity +5 yrs (MVA)	Security of supply classification +5 yrs	Peak load period +10 yrs	Min. available capacity +10 yrs (MVA)	Max. available capacity +10 yrs (MVA)	Security of supply classification +10 yrs (Type)	Forecast constraint type	Year of any forecast constraint	Constraint primary cause	Constraint solution type	Constraint solution progress	Temporary constraint remaining lifespan								
9	Esby Street	26							Winter	27	N-1	No constraint	9.8	Winter	9	N-1	Winter	7.35	9.1	N-1	No constraint	None	9.8	Not applicable	Not applicable	Not applicable	Not applicable								
10	Levin Street	15							Winter	46	N-1 switched	No constraint	8.4	Winter	5.05	N-1 switched	Winter	3.82	5.22	N-1 switched	No constraint	None	Not applicable	Not applicable	Not applicable	Not applicable	Not applicable	Not applicable							When investigation for upgrading of primary cable supply from alternate GXP via TPL owned substation/circuits.
11	Raccoon Road	12							Winter	23	N	No constraint	10.9	Winter	10.6	N	Winter	9.3	10.15	N	No constraint	None	Not applicable	Not applicable	Not applicable	Not applicable	Not applicable							No firm capacity	
12	Southern	12							Winter	46	N-1 switched	No constraint	10.5	Winter	9.8	N-1 switched	Winter	7.33	8.27	N-1 switched	No constraint	None	Not applicable	Not applicable	Not applicable	Not applicable	Not applicable							Limited transfer capacity for extended periods. Further transfer of load will result in poorer network reliability. Utilization projected to increase with planned feeder 50-gauge shifts from Raccoon Rd to Southern substation.	
13																																			
14																																			
15																																			
16																																			
17																																			
18																																			
19																																			
20																																			
21																																			
22																																			
23																																			
24																																			
25																																			
26																																			
27																																			
28																																			
29																																			

¹ Extend table as necessary to disclose all capacity and constraint information by each zone substation

Company Name **Electricity Invercargill Limited**
AMP Planning Period **1 April 2026 – 31 March 2036**

SCHEDULE 12c: REPORT ON FORECAST NETWORK DEMAND

This schedule requires a forecast of new connections (by consumer type), peak demand and energy volumes for the disclosure year and a 5 year planning period. The forecasts should be consistent with the supporting information set out in the AMP as well as the assumptions used in developing the expenditure forecasts in Schedule 11a and Schedule 11b and the capacity and utilisation forecasts in Schedule 12b.

sch ref

12c(i): Consumer Connections

Number of ICPs connected during year by consumer type

Number of connections
Current Year CY CY+1 CY+2 CY+3 CY+4 CY+5

Consumer types defined by EDB*

Customer Connections (≤ 20kVA)
Customer Connections (21 to 99kVA)
Customer Connections (≥ 100kVA)

46	46	46	46	46	46	46
15	15	15	15	15	15	15
3	3	3	3	3	3	3
64	64	64	64	64	64	64

Connections total

*include additional rows if needed

Distributed generation

Number of connections made in year

Capacity of distributed generation installed in year (MVA)

Current Year CY CY+1 CY+2 CY+3 CY+4 CY+5

6	10	10	10	10	10	10
0	0	0	0	0	0	0

12c(ii): System Demand

Maximum coincident system demand (MW)

GXP demand

plus Distributed generation output at HV and above

Maximum coincident system demand

less Net transfers to (from) other EDBs at HV and above

Demand on system for supply to consumers' connection points

Current Year CY CY+1 CY+2 CY+3 CY+4 CY+5

65	62	62	62	62	62	62
-	-	-	-	-	-	-
65	62	62	62	62	62	62
(1)	(1)	(1)	(1)	(1)	(1)	(1)
66	63	63	63	63	63	63

Electricity volumes carried (GWh)

Electricity supplied from GXPs

less Electricity exports to GXPs

plus Electricity supplied from distributed generation

less Net electricity supplied to (from) other EDBs

Electricity entering system for supply to ICPs

less Total energy delivered to ICPs

Losses

Load factor

Loss ratio

255	256	256	256	256	256	256
-	-	-	-	-	-	-
0.534	0.534	0.534	0.534	0.534	0.534	0.534
(14)	(14)	(14)	(14)	(14)	(14)	(14)
269	270	270	270	270	270	270
256	256	256	256	256	256	256
13	14	14	14	14	14	14

46%	49%	49%	49%	49%	49%	49%
4.8%	5.1%	5.1%	5.1%	5.1%	5.1%	5.1%

Company Name	Electricity Invercargill Limited
AMP Planning Period	1 April 2026 – 31 March 2036
Network / Sub-network Name	

SCHEDULE 12d: REPORT FORECAST INTERRUPTIONS AND DURATION

This schedule requires a forecast of SAIFI and SAIDI for disclosure and a 5 year planning period. The forecasts should be consistent with the supporting information set out in the AMP as well as the assumed impact of planned and unplanned SAIFI and SAIDI on the expenditures forecast provided in Schedule 11a and Schedule 11b.

sch ref

		Current Year CY	CY+1	CY+2	CY+3	CY+4	CY+5
8							
9							
10	SAIDI						
11	Class B (planned interruptions on the network)	23.9	28.0	28.0	28.0	28.0	28.0
12	Class C (unplanned interruptions on the network)	34.7	38.2	37.8	37.4	37.1	36.7
13	SAIFI						
14	Class B (planned interruptions on the network)	0.08	0.11	0.11	0.11	0.11	0.11
15	Class C (unplanned interruptions on the network)	0.61	0.68	0.67	0.67	0.66	0.66

Company Name	Electricity Invercargill Limited
AMP Planning Period	1 April 2026 – 31 March 2036
Asset Management Standard Applied	

SCHEDULE 13: REPORT ON ASSET MANAGEMENT MATURITY

This schedule requires information on the EDB's self-assessment of the maturity of its asset management practices .

Question No.	Function	Question	Score	Evidence—Summary	User Guidance	Why	Who	Record/document Information
3	Asset management policy	To what extent has an asset management policy been documented, authorised and communicated?	3			Widely used AM practice standards require an organisation to document, authorise and communicate its asset management policy (eg, as required in PAS 55 para 4.2 i). A key pre-requisite of any robust policy is that the organisation's top management must be seen to endorse and fully support it. Also vital to the effective implementation of the policy, is to tell the appropriate people of its content and their obligations under it. Where an organisation outsources some of its asset-related activities, then these people and their organisations must equally be made aware of the policy's content. Also, there may be other stakeholders, such as regulatory authorities and shareholders who should be made aware of it.	Top management. The management team that has overall responsibility for asset management.	The organisation's asset management policy, its organisational strategic plan, documents indicating how the asset management policy was based upon the needs of the organisation and evidence of communication.
10	Asset management strategy	What has the organisation done to ensure that its asset management strategy is consistent with other appropriate organisational policies and strategies, and the needs of stakeholders?	3			In setting an organisation's asset management strategy, it is important that it is consistent with any other policies and strategies that the organisation has and has taken into account the requirements of relevant stakeholders. This question examines to what extent the asset management strategy is consistent with other organisational policies and strategies (eg, as required by PAS 55 para 4.3.1 b) and has taken account of stakeholder requirements as required by PAS 55 para 4.3.1 c). Generally, this will take into account the same policies, strategies and stakeholder requirements as covered in drafting the asset management policy but at a greater level of detail.	Top management. The organisation's strategic planning team. The management team that has overall responsibility for asset management.	The organisation's asset management strategy document and other related organisational policies and strategies. Other than the organisation's strategic plan, these could include those relating to health and safety, environmental, etc. Results of stakeholder consultation.
11	Asset management strategy	In what way does the organisation's asset management strategy take account of the lifecycle of the assets, asset types and asset systems over which the organisation has stewardship?	3			Good asset stewardship is the hallmark of an organisation compliant with widely used AM standards. A key component of this is the need to take account of the lifecycle of the assets, asset types and asset systems. (For example, this requirement is recognised in 4.3.1 d) of PAS 55). This question explores what an organisation has done to take lifecycle into account in its asset management strategy.	Top management. People in the organisation with expert knowledge of the assets, asset types, asset systems and their associated life-cycles. The management team that has overall responsibility for asset management. Those responsible for developing and adopting methods and processes used in asset management	The organisation's documented asset management strategy and supporting working documents.
26	Asset management plan(s)	How does the organisation establish and document its asset management plan(s) across the life cycle activities of its assets and asset systems?	3			The asset management strategy need to be translated into practical plan(s) so that all parties know how the objectives will be achieved. The development of plan(s) will need to identify the specific tasks and activities required to optimize costs, risks and performance of the assets and/or asset system(s), when they are to be carried out and the resources required.	The management team with overall responsibility for the asset management system. Operations, maintenance and engineering managers.	The organisation's asset management plan(s).

Company Name	Electricity Invercargill Limited
AMP Planning Period	
Asset Management Standard Applied	

SCHEDULE 13: REPORT ON ASSET MANAGEMENT MATURITY (cont)

Question No.	Function	Question	Maturity Level 0	Maturity Level 1	Maturity Level 2	Maturity Level 3	Maturity Level 4
3	Asset management policy	To what extent has an asset management policy been documented, authorised and communicated?	The organisation does not have a documented asset management policy.	The organisation has an asset management policy, but it has not been authorised by top management, or it is not influencing the management of the assets.	The organisation has an asset management policy, which has been authorised by top management, but it has had limited circulation. It may be in use to influence development of strategy and planning but its effect is limited.	The asset management policy is authorised by top management, is widely and effectively communicated to all relevant employees and stakeholders, and used to make these persons aware of their asset related obligations.	The organisation's process(es) surpass the standard required to comply with requirements set out in a recognised standard. The assessor is advised to note in the Evidence section why this is the case and the evidence seen.
10	Asset management strategy	What has the organisation done to ensure that its asset management strategy is consistent with other appropriate organisational policies and strategies, and the needs of stakeholders?	The organisation has not considered the need to ensure that its asset management strategy is appropriately aligned with the organisation's other organisational policies and strategies or with stakeholder requirements. OR The organisation does not have an asset management strategy.	The need to align the asset management strategy with other organisational policies and strategies as well as stakeholder requirements is understood and work has started to identify the linkages or to incorporate them in the drafting of asset management strategy.	Some of the linkages between the long-term asset management strategy and other organisational policies, strategies and stakeholder requirements are defined but the work is fairly well advanced but still incomplete.	All linkages are in place and evidence is available to demonstrate that, where appropriate, the organisation's asset management strategy is consistent with its other organisational policies and strategies. The organisation has also identified and considered the requirements of relevant stakeholders.	The organisation's process(es) surpass the standard required to comply with requirements set out in a recognised standard. The assessor is advised to note in the Evidence section why this is the case and the evidence seen.
11	Asset management strategy	In what way does the organisation's asset management strategy take account of the lifecycle of the assets, asset types and asset systems over which the organisation has stewardship?	The organisation has not considered the need to ensure that its asset management strategy is produced with due regard to the lifecycle of the assets, asset types or asset systems that it manages. OR The organisation does not have an asset management strategy.	The need is understood, and the organisation is drafting its asset management strategy to address the lifecycle of its assets, asset types and asset systems.	The long-term asset management strategy takes account of the lifecycle of some, but not all, of its assets, asset types and asset systems.	The asset management strategy takes account of the lifecycle of all of its assets, asset types and asset systems.	The organisation's process(es) surpass the standard required to comply with requirements set out in a recognised standard. The assessor is advised to note in the Evidence section why this is the case and the evidence seen.
26	Asset management plan(s)	How does the organisation establish and document its asset management plan(s) across the life cycle activities of its assets and asset systems?	The organisation does not have an identifiable asset management plan(s) covering asset systems and critical assets.	The organisation has asset management plan(s) but they are not aligned with the asset management strategy and objectives and do not take into consideration the full asset life cycle (including asset creation, acquisition, enhancement, utilisation, maintenance decommissioning and disposal).	The organisation is in the process of putting in place comprehensive, documented asset management plan(s) that cover all life cycle activities, clearly aligned to asset management objectives and the asset management strategy.	Asset management plan(s) are established, documented, implemented and maintained for asset systems and critical assets to achieve the asset management strategy (and asset management objectives across all life cycle phases).	The organisation's process(es) surpass the standard required to comply with requirements set out in a recognised standard. The assessor is advised to note in the Evidence section why this is the case and the evidence seen.

Question No.	Function	Question	Score	Evidence—Summary	User Guidance	Why	Who	Record/document information
27	Asset management plan(s)	How has the organisation communicated its plan(s) to all relevant parties to a level of detail appropriate to the receiver's role in their delivery?	3			Plans will be ineffective unless they are communicated to all those, including contracted suppliers and those who undertake enabling function(s). The plan(s) need to be communicated in a way that is relevant to those who need to use them.	The management team with overall responsibility for the asset management system. Delivery functions and suppliers.	Distribution lists for plan(s). Documents derived from plan(s) which detail the receivers role in plan delivery. Evidence of communication.
29	Asset management plan(s)	How are designated responsibilities for delivery of asset plan actions documented?	3			The implementation of asset management plan(s) relies on (1) actions being clearly identified, (2) an owner allocated and (3) that owner having sufficient delegated responsibility and authority to carry out the work required. It also requires alignment of actions across the organisation. This question explores how well the plan(s) set out responsibility for delivery of asset plan actions.	The management team with overall responsibility for the asset management system. Operations, maintenance and engineering managers. If appropriate, the performance management team.	The organisation's asset management plan(s). Documentation defining roles and responsibilities of individuals and organisational departments.
31	Asset management plan(s)	What has the organisation done to ensure that appropriate arrangements are made available for the efficient and cost effective implementation of the plan(s)? (Note this is about resources and enabling support)	3			It is essential that the plan(s) are realistic and can be implemented, which requires appropriate resources to be available and enabling mechanisms in place. This question explores how well this is achieved. The plan(s) not only need to consider the resources directly required and timescales, but also the enabling activities, including for example, training requirements, supply chain capability and procurement timescales.	The management team with overall responsibility for the asset management system. Operations, maintenance and engineering managers. If appropriate, the performance management team. Where appropriate the procurement team and service providers working on the organisation's asset-related activities.	The organisation's asset management plan(s). Documented processes and procedures for the delivery of the asset management plan.
33	Contingency planning	What plan(s) and procedure(s) does the organisation have for identifying and responding to incidents and emergency situations and ensuring continuity of critical asset management activities?	3			Widely used AM practice standards require that an organisation has plan(s) to identify and respond to emergency situations. Emergency plan(s) should outline the actions to be taken to respond to specified emergency situations and ensure continuity of critical asset management activities including the communication to, and involvement of, external agencies. This question assesses if, and how well, these plan(s) triggered, implemented and resolved in the event of an incident. The plan(s) should be appropriate to the level of risk as determined by the organisation's risk assessment methodology. It is also a requirement that relevant personnel are competent and trained.	The manager with responsibility for developing emergency plan(s). The organisation's risk assessment team. People with designated duties within the plan(s) and procedure(s) for dealing with incidents and emergency situations.	The organisation's plan(s) and procedure(s) for dealing with emergencies. The organisation's risk assessments and risk registers.

<div style="text-align: right;"> Company Name <input type="text" value="Electricity Invercargill Limited"/> AMP Planning Period <input type="text"/> Asset Management Standard Applied <input type="text"/> </div> SCHEDULE 13: REPORT ON ASSET MANAGEMENT MATURITY (cont)							
<div style="text-align: right;"> Company Name <input type="text" value="Electricity Invercargill Limited"/> AMP Planning Period <input type="text"/> Asset Management Standard Applied <input type="text"/> </div> SCHEDULE 13: REPORT ON ASSET MANAGEMENT MATURITY (cont)							
Question No.	Function	Question	Maturity Level 0	Maturity Level 1	Maturity Level 2	Maturity Level 3	Maturity Level 4
27	Asset management plan(s)	How has the organisation communicated its plan(s) to all relevant parties to a level of detail appropriate to the receiver's role in their delivery?	The organisation does not have plan(s) or their distribution is limited to the authors.	The plan(s) are communicated to some of those responsible for delivery of the plan(s). OR Communicated to those responsible for delivery is either irregular or ad-hoc.	The plan(s) are communicated to most of those responsible for delivery but there are weaknesses in identifying relevant parties resulting in incomplete or inappropriate communication. The organisation recognises improvement is needed as is working towards resolution.	The plan(s) are communicated to all relevant employees, stakeholders and contracted service providers to a level of detail appropriate to their participation or business interests in the delivery of the plan(s) and there is confirmation that they are being used effectively.	The organisation's process(es) surpass the standard required to comply with requirements set out in a recognised standard. The assessor is advised to note in the Evidence section why this is the case and the evidence seen.
29	Asset management plan(s)	How are designated responsibilities for delivery of asset plan actions documented?	The organisation has not documented responsibilities for delivery of asset plan actions.	Asset management plan(s) inconsistently document responsibilities for delivery of plan actions and activities and/or responsibilities and authorities for implementation inadequate and/or delegation level inadequate to ensure effective delivery and/or contain misalignments with organisational accountability.	Asset management plan(s) consistently document responsibilities for the delivery of actions but responsibility/authority levels are inappropriate/ inadequate, and/or there are misalignments within the organisation.	Asset management plan(s) consistently document responsibilities for the delivery actions and there is adequate detail to enable delivery of actions. Designated responsibility and authority for achievement of asset plan actions is appropriate.	The organisation's process(es) surpass the standard required to comply with requirements set out in a recognised standard. The assessor is advised to note in the Evidence section why this is the case and the evidence seen.
31	Asset management plan(s)	What has the organisation done to ensure that appropriate arrangements are made available for the efficient and cost effective implementation of the plan(s)? (Note this is about resources and enabling support)	The organisation has not considered the arrangements needed for the effective implementation of plan(s).	The organisation recognises the need to ensure appropriate arrangements are in place for implementation of asset management plan(s) and is in the process of determining an appropriate approach for achieving this.	The organisation has arrangements in place for the implementation of asset management plan(s) but the arrangements are not yet adequately efficient and/or effective. The organisation is working to resolve existing weaknesses.	The organisation's arrangements fully cover all the requirements for the efficient and cost effective implementation of asset management plan(s) and realistically address the resources and timescales required, and any changes needed to functional policies, standards, processes and the asset management information system.	The organisation's process(es) surpass the standard required to comply with requirements set out in a recognised standard. The assessor is advised to note in the Evidence section why this is the case and the evidence seen.
33	Contingency planning	What plan(s) and procedure(s) does the organisation have for identifying and responding to incidents and emergency situations and ensuring continuity of critical asset management activities?	The organisation has not considered the need to establish plan(s) and procedure(s) to identify and respond to incidents and emergency situations.	The organisation has some ad-hoc arrangements to deal with incidents and emergency situations, but these have been developed on a reactive basis in response to specific events that have occurred in the past.	Most credible incidents and emergency situations are identified. Either appropriate plan(s) and procedure(s) are incomplete for critical activities or they are inadequate. Training/ external alignment may be incomplete.	Appropriate emergency plan(s) and procedure(s) are in place to respond to credible incidents and manage continuity of critical asset management activities consistent with policies and asset management objectives. Training and external agency alignment is in place.	The organisation's process(es) surpass the standard required to comply with requirements set out in a recognised standard. The assessor is advised to note in the Evidence section why this is the case and the evidence seen.

Company Name	Electricity Invercargill Limited
AMP Planning Period	1 April 2026 – 31 March 2036
Asset Management Standard Applied	

SCHEDULE 13: REPORT ON ASSET MANAGEMENT MATURITY

This schedule requires information on the EDB'S self-assessment of the maturity of its asset management practices .

Company Name	Electricity Invercargill Limited
AMP Planning Period	
Asset Management Standard Applied	

SCHEDULE 13: REPORT ON ASSET MANAGEMENT MATURITY (cont)

Question No.	Function	Question	Score	Evidence—Summary	User Guidance	Why	Who	Record/documented information
37	Structure, authority and responsibilities	What has the organisation done to appoint member(s) of its management team to be responsible for ensuring that the organisation's assets deliver the requirements of the asset management strategy, objectives and plan(s)?	3			In order to ensure that the organisation's assets and asset systems deliver the requirements of the asset management policy, strategy and objectives responsibilities need to be allocated to appropriate people who have the necessary authority to fulfil their responsibilities. (This question, relates to the organisation's assets eg, para b), s 4.4.1 of PAS 55, making it therefore distinct from the requirement contained in para a), s 4.4.1 of PAS 55).	Top management. People with management responsibility for the delivery of asset management policy, strategy, objectives and plan(s). People working on asset-related activities.	Evidence that managers with responsibility for the delivery of asset management policy, strategy, objectives and plan(s) have been appointed and have assumed their responsibilities. Evidence may include the organisation's documents relating to its asset management system, organisational charts, job descriptions of post-holders, annual targets/objectives and personal development plan(s) of post-holders as appropriate.
40	Structure, authority and responsibilities	What evidence can the organisation's top management provide to demonstrate that sufficient resources are available for asset management?	3			Optimal asset management requires top management to ensure sufficient resources are available. In this context the term 'resources' includes manpower, materials, funding and service provider support.	Top management. The management team that has overall responsibility for asset management. Risk management team. The organisation's managers involved in day-to-day supervision of asset-related activities, such as frontline managers, engineers, foremen and chargehands as appropriate.	Evidence demonstrating that asset management plan(s) and/or the process(es) for asset management plan implementation consider the provision of adequate resources in both the short and long term. Resources include funding, materials, equipment, services provided by third parties and personnel (internal and service providers) with appropriate skills competencies and knowledge.
42	Structure, authority and responsibilities	To what degree does the organisation's top management communicate the importance of meeting its asset management requirements?	3			Widely used AM practice standards require an organisation to communicate the importance of meeting its asset management requirements such that personnel fully understand, take ownership of, and are fully engaged in the delivery of the asset management requirements (eg, PAS 55 s 4.4.1 g).	Top management. The management team that has overall responsibility for asset management. People involved in the delivery of the asset management requirements.	Evidence of such activities as road shows, written bulletins, workshops, team talks and management walk-about would assist an organisation to demonstrate it is meeting this requirement of PAS 55.
45	Outsourcing of asset management activities	Where the organisation has outsourced some of its asset management activities, how has it ensured that appropriate controls are in place to ensure the compliant delivery of its organisational strategic plan, and its asset management policy and strategy?	3			Where an organisation chooses to outsource some of its asset management activities, the organisation must ensure that these outsourced process(es) are under appropriate control to ensure that all the requirements of widely used AM standards (eg, PAS 55) are in place, and the asset management policy, strategy objectives and plan(s) are delivered. This includes ensuring capabilities and resources across a time span aligned to life cycle management. The organisation must put arrangements in place to control the outsourced activities, whether it be to external providers or to other in-house departments. This question explores what the organisation does in this regard.	Top management. The management team that has overall responsibility for asset management. The manager(s) responsible for the monitoring and management of the outsourced activities. People involved with the procurement of outsourced activities. The people within the organisations that are performing the outsourced activities. The people impacted by the outsourced activity.	The organisation's arrangements that detail the compliance required of the outsourced activities. For example, this this could form part of a contract or service level agreement between the organisation and the suppliers of its outsourced activities. Evidence that the organisation has demonstrated to itself that it has assurance of compliance of outsourced activities.

SCHEDULE 13: REPORT ON ASSET MANAGEMENT MATURITY (cont)							
						Company Name	Electricity Invercargill Limited
						AMP Planning Period	
						Asset Management Standard Applied	
SCHEDULE 13: REPORT ON ASSET MANAGEMENT MATURITY (cont)							
						Company Name	Electricity Invercargill Limited
						AMP Planning Period	
						Asset Management Standard Applied	
Question No.	Function	Question	Maturity Level 0	Maturity Level 1	Maturity Level 2	Maturity Level 3	Maturity Level 4
37	Structure, authority and responsibilities	What has the organisation done to appoint member(s) of its management team to be responsible for ensuring that the organisation's assets deliver the requirements of the asset management strategy, objectives and plan(s)?	Top management has not considered the need to appoint a person or persons to ensure that the organisation's assets deliver the requirements of the asset management strategy, objectives and plan(s).	Top management understands the need to appoint a person or persons to ensure that the organisation's assets deliver the requirements of the asset management strategy, objectives and plan(s).	Top management has appointed an appropriate person to ensure the assets deliver the requirements of the asset management strategy, objectives and plan(s) but their areas of responsibility are not fully defined and/or they have insufficient delegated authority to fully execute their responsibilities.	The appointed person or persons have full responsibility for ensuring that the organisation's assets deliver the requirements of the asset management strategy, objectives and plan(s). They have been given the necessary authority to achieve this.	The organisation's process(es) surpass the standard required to comply with requirements set out in a recognised standard. The assessor is advised to note in the Evidence section why this is the case and the evidence seen.
40	Structure, authority and responsibilities	What evidence can the organisation's top management provide to demonstrate that sufficient resources are available for asset management?	The organisation's top management has not considered the resources required to deliver asset management.	The organisation's top management understands the need for sufficient resources but there are no effective mechanisms in place to ensure this is the case.	A process exists for determining what resources are required for its asset management activities and in most cases these are available but in some instances resources remain insufficient.	An effective process exists for determining the resources needed for asset management and sufficient resources are available. It can be demonstrated that resources are matched to asset management requirements.	The organisation's process(es) surpass the standard required to comply with requirements set out in a recognised standard. The assessor is advised to note in the Evidence section why this is the case and the evidence seen.
42	Structure, authority and responsibilities	To what degree does the organisation's top management communicate the importance of meeting its asset management requirements?	The organisation's top management has not considered the need to communicate the importance of meeting its asset management requirements.	The organisation's top management understands the need to communicate the importance of meeting its asset management requirements but does not do so.	Top management communicates the importance of meeting its asset management requirements but only to parts of the organisation.	Top management communicates the importance of meeting its asset management requirements to all relevant parts of the organisation.	The organisation's process(es) surpass the standard required to comply with requirements set out in a recognised standard. The assessor is advised to note in the Evidence section why this is the case and the evidence seen.
45	Outsourcing of asset management activities	Where the organisation has outsourced some of its asset management activities, how has it ensured that appropriate controls are in place to ensure the compliant delivery of its organisational strategic plan, and its asset management policy and strategy?	The organisation has not considered the need to put controls in place.	The organisation controls its outsourced activities on an ad-hoc basis, with little regard for ensuring the compliant delivery of the organisational strategic plan and/or its asset management policy and strategy.	Controls systematically considered but currently only provide for the compliant delivery of some, but not all, aspects of the organisational strategic plan and/or its asset management policy and strategy. Gaps exist.	Evidence exists to demonstrate that outsourced activities are appropriately controlled to provide for the compliant delivery of the organisational strategic plan, asset management policy and strategy, and that these controls are integrated into the asset management system.	The organisation's process(es) surpass the standard required to comply with requirements set out in a recognised standard. The assessor is advised to note in the Evidence section why this is the case and the evidence seen.

ANNEXURE 3 Disclosure Schedules



Company Name	Electricity Invercargill Limited
AMP Planning Period	1 April 2026 – 31 March 2036
Asset Management Standard Applied	

SCHEDULE 13: REPORT ON ASSET MANAGEMENT MATURITY
This schedule requires information on the EDB's self-assessment of the maturity of its asset management practices.

Company Name	Electricity Invercargill Limited
AMP Planning Period	
Asset Management Standard Applied	

SCHEDULE 13: REPORT ON ASSET MANAGEMENT MATURITY (cont)

Question No.	Function	Question	Score	Evidence—Summary	User Guidance	Why	Who	Record/document information
48	Training, awareness and competence	How does the organisation develop plan(s) for the human resources required to undertake asset management activities - including the development and delivery of asset management strategy, process(es), objectives and plan(s)?	3			There is a need for an organisation to demonstrate that it has considered what resources are required to develop and implement its asset management system. There is also a need for the organisation to demonstrate that it has assessed what development plan(s) are required to provide its human resources with the skills and competencies to develop and implement its asset management systems. The timescales over which the plan(s) are relevant should be commensurate with the planning horizons within the asset management strategy considers e.g. if the asset management strategy considers 5, 10 and 15 year time scales then the human resources development plan(s) should align with these. Resources include both 'in house' and external resources who undertake asset management activities.	Senior management responsible for agreement of plan(s). Managers responsible for developing asset management strategy and plan(s). Managers with responsibility for development and recruitment of staff (including HR functions). Staff responsible for training. Procurement officers. Contracted service providers.	Evidence of analysis of future work load plan(s) in terms of human resources. Document(s) containing analysis of the organisation's own direct resources and contractors resource capability over suitable timescales. Evidence, such as minutes of meetings, that suitable management forums are monitoring human resource development plan(s). Training plan(s), personal development plan(s), contract and service level agreements.
49	Training, awareness and competence	How does the organisation identify competency requirements and then plan, provide and record the training necessary to achieve the competencies?	3			Widely used AM standards require that organisations to undertake a systematic identification of the asset management awareness and competencies required at each level and function within the organisation. Once identified the training required to provide the necessary competencies should be planned for delivery in a timely and systematic way. Any training provided must be recorded and maintained in a suitable format. Where an organisation has contracted service providers in place then it should have a means to demonstrate that this requirement is being met for their employees. (eg, PAS 55 refers to frameworks suitable for identifying competency requirements).	Senior management responsible for agreement of plan(s). Managers responsible for developing asset management strategy and plan(s). Managers with responsibility for development and recruitment of staff (including HR functions). Staff responsible for training. Procurement officers. Contracted service providers.	Evidence of an established and applied competency requirements assessment process and plan(s) in place to deliver the required training. Evidence that the training programme is part of a wider, co-ordinated asset management activities training and competency programme. Evidence that training activities are recorded and that records are readily available (for both direct and contracted service provider staff) e.g. via organisation wide information system or local records database.
50	Training, awareness and competence	How does the organization ensure that persons under its direct control undertaking asset management related activities have an appropriate level of competence in terms of education, training or experience?	3			A critical success factor for the effective development and implementation of an asset management system is the competence of persons undertaking these activities. Organisations should have effective means in place for ensuring the competence of employees to carry out their designated asset management function(s). Where an organisation has contracted service providers undertaking elements of its asset management system then the organisation shall assure itself that the outsourced service provider also has suitable arrangements in place to manage the competencies of its employees. The organisation should ensure that the individual and corporate competencies it requires are in place and actively monitor, develop and maintain an appropriate balance of these competencies.	Managers, supervisors, persons responsible for developing training programmes. Staff responsible for procurement and service agreements. HR staff and those responsible for recruitment.	Evidence of a competency assessment framework that aligns with established frameworks such as the asset management Competencies Requirements Framework (Version 2.0); National Occupational Standards for Management and Leadership; UK Standard for Professional Engineering Competence, Engineering Council, 2005.

Company Name		Electricity Invercargill Limited
AMP Planning Period		
Asset Management Standard Applied		
SCHEDULE 13: REPORT ON ASSET MANAGEMENT MATURITY (cont)		

Company Name		Electricity Invercargill Limited
AMP Planning Period		
Asset Management Standard Applied		
SCHEDULE 13: REPORT ON ASSET MANAGEMENT MATURITY (cont)		

Question No.	Function	Question	Maturity Level 0	Maturity Level 1	Maturity Level 2	Maturity Level 3	Maturity Level 4
48	Training, awareness and competence	How does the organisation develop plan(s) for the human resources required to undertake asset management activities - including the development and delivery of asset management strategy, process(es), objectives and plan(s)?	The organisation has not recognised the need for assessing human resources requirements to develop and implement its asset management system.	The organisation has recognised the need to assess its human resources requirements and to develop a plan(s). There is limited recognition of the need to align these with the development and implementation of its asset management system.	The organisation has developed a strategic approach to aligning competencies and human resources to the asset management system including the asset management plan but the work is incomplete or has not been consistently implemented.	The organisation can demonstrate that plan(s) are in place and effective in matching competencies and capabilities to the asset management system including the plan for both internal and contracted activities. Plans are reviewed integral to asset management system process(es).	The organisation's process(es) surpass the standard required to comply with requirements set out in a recognised standard. The assessor is advised to note in the Evidence section why this is the case and the evidence seen.
49	Training, awareness and competence	How does the organisation identify competency requirements and then plan, provide and record the training necessary to achieve the competencies?	The organisation does not have any means in place to identify competency requirements.	The organisation has recognised the need to identify competency requirements and then plan, provide and record the training necessary to achieve the competencies.	The organisation is in the process of identifying competency requirements aligned to the asset management plan(s) and then plan, provide and record appropriate training. It is incomplete or inconsistently applied.	Competency requirements are in place and aligned with asset management plan(s). Plans are in place and effective in providing the training necessary to achieve the competencies. A structured means of recording the competencies achieved is in place.	The organisation's process(es) surpass the standard required to comply with requirements set out in a recognised standard. The assessor is advised to note in the Evidence section why this is the case and the evidence seen.
50	Training, awareness and competence	How does the organization ensure that persons under its direct control undertaking asset management related activities have an appropriate level of competence in terms of education, training or experience?	The organization has not recognised the need to assess the competence of person(s) undertaking asset management related activities.	Competency of staff undertaking asset management related activities is not managed or assessed in a structured way, other than formal requirements for legal compliance and safety management.	The organization is in the process of putting in place a means for assessing the competence of person(s) involved in asset management activities including contractors. There are gaps and inconsistencies.	Competency requirements are identified and assessed for all persons carrying out asset management related activities - internal and contracted. Requirements are reviewed and staff reassessed at appropriate intervals aligned to asset management requirements.	The organisation's process(es) surpass the standard required to comply with requirements set out in a recognised standard. The assessor is advised to note in the Evidence section why this is the case and the evidence seen.

Company Name	Electricity Invercargill Limited
AMP Planning Period	1 April 2026 – 31 March 2036
Asset Management Standard Applied	

SCHEDULE 13: REPORT ON ASSET MANAGEMENT MATURITY
This schedule requires information on the EDB's self-assessment of the maturity of its asset management practices .

Company Name	Electricity Invercargill Limited
AMP Planning Period	
Asset Management Standard Applied	

SCHEDULE 13: REPORT ON ASSET MANAGEMENT MATURITY (cont)

Question No.	Function	Question	Score	Evidence—Summary	User Guidance	Why	Who	Record/document Information
53	Communication, participation and consultation	How does the organisation ensure that pertinent asset management information is effectively communicated to and from employees and other stakeholders, including contracted service providers?	3			Widely used AM practice standards require that pertinent asset management information is effectively communicated to and from employees and other stakeholders including contracted service providers. Pertinent information refers to information required in order to effectively and efficiently comply with and deliver asset management strategy, plan(s) and objectives. This will include for example the communication of the asset management policy, asset performance information, and planning information as appropriate to contractors.	Top management and senior management representative(s), employee's representative(s), employee's trade union representative(s); contracted service provider management and employee representative(s); representative(s) from the organisation's Health, Safety and Environmental team. Key stakeholder representative(s).	Asset management policy statement prominently displayed on notice boards, intranet and internet; use of organisation's website for displaying asset performance data; evidence of formal briefings to employees, stakeholders and contracted service providers; evidence of inclusion of asset management issues in team meetings and contracted service provider contract meetings; newsletters, etc.
59	Asset Management System documentation	What documentation has the organisation established to describe the main elements of its asset management system and interactions between them?	3			Widely used AM practice standards require an organisation maintain up to date documentation that ensures that its asset management systems (ie the systems the organisation has in place to meet the standards) can be understood, communicated and operated. (eg, s 4.5 of PAS 55 requires the maintenance of up to date documentation of the asset management system requirements specified throughout s 4 of PAS 55).	The management team that has overall responsibility for asset management. Managers engaged in asset management activities.	The documented information describing the main elements of the asset management system (process(es) and their interaction.
62	Information management	What has the organisation done to determine what its asset management information system(s) should contain in order to support its asset management system?	4			Effective asset management requires appropriate information to be available. Widely used AM standards therefore require the organisation to identify the asset management information it requires in order to support its asset management system. Some of the information required may be held by suppliers. The maintenance and development of asset management information systems is a poorly understood specialist activity that is akin to IT management but different from IT management. This group of questions provides some indications as to whether the capability is available and applied. Note: To be effective, an asset information management system requires the mobilisation of technology, people and process(es) that create, secure, make available and destroy the information required to support the asset management system.	The organisation's strategic planning team. The management team that has overall responsibility for asset management. Information management team. Operations, maintenance and engineering managers	Details of the process the organisation has employed to determine what its asset information system should contain in order to support its asset management system. Evidence that this has been effectively implemented.
63	Information management	How does the organisation maintain its asset management information system(s) and ensure that the data held within it (them) is of the requisite quality and accuracy and is consistent?	4			The response to the questions is progressive. A higher scale cannot be awarded without achieving the requirements of the lower scale. This question explores how the organisation ensures that information management meets widely used AM practice requirements (eg, s 4.4.6 (a), (c) and (d) of PAS 55).	The management team that has overall responsibility for asset management. Users of the organisational information systems.	The asset management information system, together with the policies, procedure(s), improvement initiatives and audits regarding information controls.

SCHEDULE 13: REPORT ON ASSET MANAGEMENT MATURITY (cont)							
							Company Name AMP Planning Period Asset Management Standard Applied
							Electricity Invercargill Limited _____ _____ _____
SCHEDULE 13: REPORT ON ASSET MANAGEMENT MATURITY (cont)							
							Company Name AMP Planning Period Asset Management Standard Applied
							Electricity Invercargill Limited _____ _____ _____
Question No.	Function	Question	Maturity Level 0	Maturity Level 1	Maturity Level 2	Maturity Level 3	Maturity Level 4
53	Communication, participation and consultation	How does the organisation ensure that pertinent asset management information is effectively communicated to and from employees and other stakeholders, including contracted service providers?	The organisation has not recognised the need to formally communicate any asset management information.	There is evidence that the pertinent asset management information to be shared along with those to share it with is being determined.	The organisation has determined pertinent information and relevant parties. Some effective two way communication is in place but as yet not all relevant parties are clear on their roles and responsibilities with respect to asset management information.	Two way communication is in place between all relevant parties, ensuring that information is effectively communicated to match the requirements of asset management strategy, plan(s) and process(es). Pertinent asset information requirements are regularly reviewed.	The organisation's process(es) surpass the standard required to comply with requirements set out in a recognised standard. The assessor is advised to note in the Evidence section why this is the case and the evidence seen.
59	Asset Management System documentation	What documentation has the organisation established to describe the main elements of its asset management system and interactions between them?	The organisation has not established documentation that describes the main elements of the asset management system.	The organisation is aware of the need to put documentation in place and is in the process of determining how to document the main elements of its asset management system.	The organisation in the process of documenting its asset management system and has documentation in place that describes some, but not all, of the main elements of its asset management system and their interaction.	The organisation has established documentation that comprehensively describes all the main elements of its asset management system and the interactions between them. The documentation is kept up to date.	The organisation's process(es) surpass the standard required to comply with requirements set out in a recognised standard. The assessor is advised to note in the Evidence section why this is the case and the evidence seen.
62	Information management	What has the organisation done to determine what its asset management information system(s) should contain in order to support its asset management system?	The organisation has not considered what asset management information is required.	The organisation is aware of the need to determine in a structured manner what its asset information system should contain in order to support its asset management system and is in the process of deciding how to do this.	The organisation has developed a structured process to determine what its asset information system should contain in order to support its asset management system and has commenced implementation of the process.	The organisation has determined what its asset information system should contain in order to support its asset management system. The requirements relate to the whole life cycle and cover information originating from both internal and external sources.	The organisation's process(es) surpass the standard required to comply with requirements set out in a recognised standard. The assessor is advised to note in the Evidence section why this is the case and the evidence seen.
63	Information management	How does the organisation maintain its asset management information system(s) and ensure that the data held within it (them) is of the requisite quality and accuracy and is consistent?	There are no formal controls in place or controls are extremely limited in scope and/or effectiveness.	The organisation is aware of the need for effective controls and is in the process of developing an appropriate control process(es).	The organisation has developed a controls that will ensure the data held is of the requisite quality and accuracy and is consistent and is in the process of implementing them.	The organisation has effective controls in place that ensure the data held is of the requisite quality and accuracy and is consistent. The controls are regularly reviewed and improved where necessary.	The organisation's process(es) surpass the standard required to comply with requirements set out in a recognised standard. The assessor is advised to note in the Evidence section why this is the case and the evidence seen.

Company Name Electricity Invercargill Limited
AMP Planning Period 1 April 2026 – 31 March 2036
Asset Management Standard Applied

SCHEDULE 13: REPORT ON ASSET MANAGEMENT MATURITY

This schedule requires information on the EDB'S self-assessment of the maturity of its asset management practices .

Company Name Electricity Invercargill Limited
AMP Planning Period
Asset Management Standard Applied

SCHEDULE 13: REPORT ON ASSET MANAGEMENT MATURITY (cont)

Question No.	Function	Question	Score	Evidence—Summary	User Guidance	Why	Who	Record/document information
64	Information management	How has the organisation's ensured its asset management information system is relevant to its needs?	3			Widely used AM standards need not be prescriptive about the form of the asset management information system, but simply require that the asset management information system is appropriate to the organisations needs, can be effectively used and can supply information which is consistent and of the requisite quality and accuracy.	The organisation's strategic planning team. The management team that has overall responsibility for asset management. Information management team. Users of the organisational information systems.	The documented process the organisation employs to ensure its asset management information system aligns with its asset management requirements. Minutes of information systems review meetings involving users.
69	Risk management process(es)	How has the organisation documented process(es) and/or procedure(s) for the identification and assessment of asset and asset management related risks throughout the asset life cycle?	4			Risk management is an important foundation for proactive asset management. Its overall purpose is to understand the cause, effect and likelihood of adverse events occurring, to optimally manage such risks to an acceptable level, and to provide an audit trail for the management of risks. Widely used standards require the organisation to have process(es) and/or procedure(s) in place that set out how the organisation identifies and assesses asset and asset management related risks. The risks have to be considered across the four phases of the asset lifecycle (eg, para 4.3.3 of PAS 55).	The top management team in conjunction with the organisation's senior risk management representatives. There may also be input from the organisation's Safety, Health and Environment team. Staff who carry out risk identification and assessment.	The organisation's risk management framework and/or evidence of specific process(es) and/ or procedure(s) that deal with risk control mechanisms. Evidence that the process(es) and/or procedure(s) are implemented across the business and maintained. Evidence of agendas and minutes from risk management meetings. Evidence of feedback in to process(es) and/or procedure(s) as a result of incident investigation(s). Risk registers and assessments.
79	Use and maintenance of asset risk information	How does the organisation ensure that the results of risk assessments provide input into the identification of adequate resources and training and competency needs?	4			Widely used AM standards require that the output from risk assessments are considered and that adequate resource (including staff) and training is identified to match the requirements. It is a further requirement that the effects of the control measures are considered, as there may be implications in resources and training required to achieve other objectives.	Staff responsible for risk assessment and those responsible for developing and approving resource and training plan(s). There may also be input from the organisation's Safety, Health and Environment team.	The organisations risk management framework. The organisation's resourcing plan(s) and training and competency plan(s). The organisation should be able to demonstrate appropriate linkages between the content of resource plan(s) and training and competency plan(s) to the risk assessments and risk control measures that have been developed.
82	Legal and other requirements	What procedure does the organisation have to identify and provide access to its legal, regulatory, statutory and other asset management requirements, and how is requirements incorporated into the asset management system?	3			In order for an organisation to comply with its legal, regulatory, statutory and other asset management requirements, the organisation first needs to ensure that it knows what they are (eg, PAS 55 specifies this in s 4.4.8). It is necessary to have systematic and auditable mechanisms in place to identify new and changing requirements. Widely used AM standards also require that requirements are incorporated into the asset management system (e.g. procedure(s) and process(es))	Top management. The organisations regulatory team. The organisation's legal team or advisors. The management team with overall responsibility for the asset management system. The organisation's health and safety team or advisors. The organisation's policy making team.	The organisational processes and procedures for ensuring information of this type is identified, made accessible to those requiring the information and is incorporated into asset management strategy and objectives

SCHEDULE 13: REPORT ON ASSET MANAGEMENT MATURITY (cont)							
							Company Name AMP Planning Period Asset Management Standard Applied
							Electricity Invercargill Limited _____ _____ _____
SCHEDULE 13: REPORT ON ASSET MANAGEMENT MATURITY (cont)							
							Company Name AMP Planning Period Asset Management Standard Applied
							Electricity Invercargill Limited _____ _____ _____
Question No.	Function	Question	Maturity Level 0	Maturity Level 1	Maturity Level 2	Maturity Level 3	Maturity Level 4
64	Information management	How has the organisation's ensured its asset management information system is relevant to its needs?	The organisation has not considered the need to determine the relevance of its management information system. At present there are major gaps between what the information system provides and the organisations needs.	The organisation understands the need to ensure its asset management information system is relevant to its needs and is determining an appropriate means by which it will achieve this. At present there are significant gaps between what the information system provides and the organisations needs.	The organisation has developed and is implementing a process to ensure its asset management information system is relevant to its needs. Gaps between what the information system provides and the organisations needs have been identified and action is being taken to close them.	The organisation's asset management information system aligns with its asset management requirements. Users can confirm that it is relevant to their needs.	The organisation's process(es) surpass the standard required to comply with requirements set out in a recognised standard. The assessor is advised to note in the Evidence section why this is the case and the evidence seen.
69	Risk management process(es)	How has the organisation documented process(es) and/or procedure(s) for the identification and assessment of asset and asset management related risks throughout the asset life cycle?	The organisation has not considered the need to document process(es) and/or procedure(s) for the identification and assessment of asset and asset management related risks throughout the asset life cycle.	The organisation is aware of the need to document the management of asset related risk across the asset lifecycle. The organisation has plan(s) to formally document all relevant process(es) and procedure(s) or has already commenced this activity.	The organisation is in the process of documenting the identification and assessment of asset related risk across the asset lifecycle but it is incomplete or there are inconsistencies between approaches and a lack of integration.	Identification and assessment of asset related risk across the asset lifecycle is fully documented. The organisation can demonstrate that appropriate documented mechanisms are integrated across life cycle phases and are being consistently applied.	The organisation's process(es) surpass the standard required to comply with requirements set out in a recognised standard. The assessor is advised to note in the Evidence section why this is the case and the evidence seen.
79	Use and maintenance of asset risk information	How does the organisation ensure that the results of risk assessments provide input into the identification of adequate resources and training and competency needs?	The organisation has not considered the need to conduct risk assessments.	The organisation is aware of the need to consider the results of risk assessments and effects of risk control measures to provide input into reviews of resources, training and competency needs. Current input is typically ad-hoc and reactive.	The organisation is in the process ensuring that outputs of risk assessment are included in developing requirements for resources and training. The implementation is incomplete and there are gaps and inconsistencies.	Outputs from risk assessments are consistently and systematically used as inputs to develop resources, training and competency requirements. Examples and evidence is available.	The organisation's process(es) surpass the standard required to comply with requirements set out in a recognised standard. The assessor is advised to note in the Evidence section why this is the case and the evidence seen.
82	Legal and other requirements	What procedure does the organisation have to identify and provide access to its legal, regulatory, statutory and other asset management requirements, and how is requirements incorporated into the asset management system?	The organisation has not considered the need to identify its legal, regulatory, statutory and other asset management requirements.	The organisation identifies some its legal, regulatory, statutory and other asset management requirements, but this is done in an ad-hoc manner in the absence of a procedure.	The organisation has procedure(s) to identify its legal, regulatory, statutory and other asset management requirements, but the information is not kept up to date, inadequate or inconsistently managed.	Evidence exists to demonstrate that the organisation's legal, regulatory, statutory and other asset management requirements are identified and kept up to date. Systematic mechanisms for identifying relevant legal and statutory requirements.	The organisation's process(es) surpass the standard required to comply with requirements set out in a recognised standard. The assessor is advised to note in the Evidence section why this is the case and the evidence seen.

<p style="text-align: right;">Company Name <u>Electricity Invercargill Limited</u> AMP Planning Period <u>1 April 2026 – 31 March 2036</u> Asset Management Standard Applied _____</p> <p>SCHEDULE 13: REPORT ON ASSET MANAGEMENT MATURITY This schedule requires information on the EDB'S self-assessment of the maturity of its asset management practices .</p>								
<p style="text-align: right;">Company Name <u>Electricity Invercargill Limited</u> AMP Planning Period _____ Asset Management Standard Applied _____</p> <p>SCHEDULE 13: REPORT ON ASSET MANAGEMENT MATURITY (cont)</p>								
Question No.	Function	Question	Score	Evidence—Summary	User Guidance	Why	Who	Record/document Information
88	Life Cycle Activities	How does the organisation establish implement and maintain process(es) for the implementation of its asset management plan(s) and control of activities across the creation, acquisition or enhancement of assets. This includes design, modification, procurement, construction and commissioning activities?	4			Life cycle activities are about the implementation of asset management plan(s) i.e. they are the "doing" phase. They need to be done effectively and well in order for asset management to have any practical meaning. As a consequence, widely used standards (eg, PAS 55 s 4.5.1) require organisations to have in place appropriate process(es) and procedure(s) for the implementation of asset management plan(s) and control of lifecycle activities. This question explores those aspects relevant to asset creation.	Asset managers, design staff, construction staff and project managers from other impacted areas of the business, e.g. Procurement	Documented process(es) and procedure(s) which are relevant to demonstrating the effective management and control of life cycle activities during asset creation, acquisition, enhancement including design, modification, procurement, construction and commissioning.
91	Life Cycle Activities	How does the organisation ensure that process(es) and/or procedure(s) for the implementation of asset management plan(s) and control of activities during maintenance (and inspection) of assets are sufficient to ensure activities are carried out under specified conditions, are consistent with asset management strategy and control cost, risk and performance?	4			Having documented process(es) which ensure the asset management plan(s) are implemented in accordance with any specified conditions, in a manner consistent with the asset management policy, strategy and objectives and in such a way that cost, risk and asset system performance are appropriately controlled is critical. They are an essential part of turning intention into action (eg, as required by PAS 55 s 4.5.1).	Asset managers, operations managers, maintenance managers and project managers from other impacted areas of the business	Documented procedure for review. Documented procedure for audit of process delivery. Records of previous audits, improvement actions and documented confirmation that actions have been carried out.
95	Performance and condition monitoring	How does the organisation measure the performance and condition of its assets?	4			Widely used AM standards require that organisations establish implement and maintain procedure(s) to monitor and measure the performance and/or condition of assets and asset systems. They further set out requirements in some detail for reactive and proactive monitoring, and leading/lagging performance indicators together with the monitoring or results to provide input to corrective actions and continual improvement. There is an expectation that performance and condition monitoring will provide input to improving asset management strategy, objectives and plan(s).	A broad cross-section of the people involved in the organisation's asset-related activities from data input to decision-makers, i.e. an end-to-end assessment. This should include contactors and other relevant third parties as appropriate.	Functional policy and/or strategy documents for performance or condition monitoring and measurement. The organisation's performance monitoring frameworks, balanced scorecards etc. Evidence of the reviews of any appropriate performance indicators and the action lists resulting from these reviews. Reports and trend analysis using performance and condition information. Evidence of the use of performance and condition information shaping improvements and supporting asset management strategy, objectives and plan(s).
99	Investigation of asset-related failures, incidents and nonconformities	How does the organisation ensure responsibility and the authority for the handling, investigation and mitigation of asset-related failures, incidents and emergency situations and non conformances is clear, unambiguous, understood and communicated?	3			Widely used AM standards require that the organisation establishes implements and maintains process(es) for the handling and investigation of failures incidents and non-conformities for assets and sets down a number of expectations. Specifically this question examines the requirement to define clearly responsibilities and authorities for these activities, and communicate these unambiguously to relevant people including external stakeholders if appropriate.	The organisation's safety and environment management team. The team with overall responsibility for the management of the assets. People who have appointed roles within the asset-related investigation procedure, from those who carry out the investigations to senior management who review the recommendations. Operational controllers responsible for managing the asset base under fault conditions and maintaining services to consumers. Contractors and other third parties as appropriate.	Process(es) and procedure(s) for the handling, investigation and mitigation of asset-related failures, incidents and emergency situations and non conformances. Documentation of assigned responsibilities and authority to employees. Job Descriptions, Audit reports. Common communication systems i.e. all Job Descriptions on Internet etc.

<div style="text-align: right;"> Company Name: <u>Electricity Invercargill Limited</u> AMP Planning Period: _____ Asset Management Standard Applied: _____ </div> SCHEDULE 13: REPORT ON ASSET MANAGEMENT MATURITY (cont)							
<div style="text-align: right;"> Company Name: <u>Electricity Invercargill Limited</u> AMP Planning Period: _____ Asset Management Standard Applied: _____ </div> SCHEDULE 13: REPORT ON ASSET MANAGEMENT MATURITY (cont)							
Question No.	Function	Question	Maturity Level 0	Maturity Level 1	Maturity Level 2	Maturity Level 3	Maturity Level 4
88	Life Cycle Activities	How does the organisation establish implement and maintain process(es) for the implementation of its asset management plan(s) and control of activities across the creation, acquisition or enhancement of assets. This includes design, modification, procurement, construction and commissioning activities?	The organisation does not have process(es) in place to manage and control the implementation of asset management plan(s) during activities related to asset creation including design, modification, procurement, construction and commissioning.	The organisation is aware of the need to have process(es) and procedure(s) in place to manage and control the implementation of asset management plan(s) during activities related to asset creation including design, modification, procurement, construction and commissioning but currently do not have these in place (note: procedure(s) may exist but they are inconsistent/incomplete).	The organisation is in the process of putting in place process(es) and procedure(s) to manage and control the implementation of asset management plan(s) during activities related to asset creation including design, modification, procurement, construction and commissioning. Gaps and inconsistencies are being addressed.	Effective process(es) and procedure(s) are in place to manage and control the implementation of asset management plan(s) during activities related to asset creation including design, modification, procurement, construction and commissioning.	The organisation's process(es) surpass the standard required to comply with requirements set out in a recognised standard. The assessor is advised to note in the Evidence section why this is the case and the evidence seen.
91	Life Cycle Activities	How does the organisation ensure that process(es) and/or procedure(s) for the implementation of asset management plan(s) and control of activities during maintenance (and inspection) of assets are sufficient to ensure activities are carried out under specified conditions, are consistent with asset management strategy and control cost, risk and performance?	The organisation does not have process(es)/procedure(s) in place to control or manage the implementation of asset management plan(s) during this life cycle phase.	The organisation is aware of the need to have process(es) and procedure(s) in place to manage and control the implementation of asset management plan(s) during this life cycle phase but currently do not have these in place and/or there is no mechanism for confirming they are effective and where needed modifying them.	The organisation is in the process of putting in place process(es) and procedure(s) to manage and control the implementation of asset management plan(s) during this life cycle phase. They include a process for confirming the process(es)/procedure(s) are effective and if necessary carrying out modifications.	The organisation has in place process(es) and procedure(s) to manage and control the implementation of asset management plan(s) during this life cycle phase. They include a process, which is itself regularly reviewed to ensure it is effective, for confirming the process(es)/ procedure(s) are effective and if necessary carrying out modifications.	The organisation's process(es) surpass the standard required to comply with requirements set out in a recognised standard. The assessor is advised to note in the Evidence section why this is the case and the evidence seen.
95	Performance and condition monitoring	How does the organisation measure the performance and condition of its assets?	The organisation has not considered how to monitor the performance and condition of its assets.	The organisation recognises the need for monitoring asset performance but has not developed a coherent approach. Measures are incomplete, predominantly reactive and lagging. There is no linkage to asset management objectives.	The organisation is developing coherent asset performance monitoring linked to asset management objectives. Reactive and proactive measures are in place. Use is being made of leading indicators and analysis. Gaps and inconsistencies remain.	Consistent asset performance monitoring linked to asset management objectives is in place and universally used including reactive and proactive measures. Data quality management and review process are appropriate. Evidence of leading indicators and analysis.	The organisation's process(es) surpass the standard required to comply with requirements set out in a recognised standard. The assessor is advised to note in the Evidence section why this is the case and the evidence seen.
99	Investigation of asset-related failures, incidents and nonconformities	How does the organisation ensure responsibility and the authority for the handling, investigation and mitigation of asset-related failures, incidents and emergency situations and non conformance is clear, unambiguous, understood and communicated?	The organisation has not considered the need to define the appropriate responsibilities and the authorities.	The organisation understands the requirements and is in the process of determining how to define them.	The organisation are in the process of defining the responsibilities and authorities with evidence. Alternatively there are some gaps or inconsistencies in the identified responsibilities/authorities.	The organisation have defined the appropriate responsibilities and authorities and evidence is available to show that these are applied across the business and kept up to date.	The organisation's process(es) surpass the standard required to comply with requirements set out in a recognised standard. The assessor is advised to note in the Evidence section why this is the case and the evidence seen.

Company Name	Electricity Invercargill Limited
AMP Planning Period	1 April 2026 – 31 March 2036
Asset Management Standard Applied	

SCHEDULE 13: REPORT ON ASSET MANAGEMENT MATURITY

This schedule requires information on the EDB's self-assessment of the maturity of its asset management practices.

Company Name	Electricity Invercargill Limited
AMP Planning Period	
Asset Management Standard Applied	

SCHEDULE 13: REPORT ON ASSET MANAGEMENT MATURITY (cont)

Question No.	Function	Question	Score	Evidence—Summary	User Guidance	Why	Who	Record/document information
105	Audit	What has the organisation done to establish procedure(s) for the audit of its asset management system (process(es))?	3			This question seeks to explore what the organisation has done to comply with the standard practice AM audit requirements (eg, the associated requirements of PAS 55 s 4.6.4 and its linkages to s 4.7).	The management team responsible for its asset management procedure(s). The team with overall responsibility for the management of the assets. Audit teams, together with key staff responsible for asset management. For example, Asset Management Director, Engineering Director. People with responsibility for carrying out risk assessments	The organisation's asset-related audit procedure(s). The organisation's methodology(s) by which it determined the scope and frequency of the audits and the criteria by which it identified the appropriate audit personnel. Audit schedules, reports etc. Evidence of the procedure(s) by which the audit results are presented, together with any subsequent communications. The risk assessment schedule or risk registers.
109	Corrective & Preventative action	How does the organisation instigate appropriate corrective and/or preventive actions to eliminate or prevent the causes of identified poor performance and non conformance?	4			Having investigated asset related failures, incidents and non-conformances, and taken action to mitigate their consequences, an organisation is required to implement preventative and corrective actions to address root causes. Incident and failure investigations are only useful if appropriate actions are taken as a result to assess changes to a businesses risk profile and ensure that appropriate arrangements are in place should a recurrence of the incident happen. Widely used AM standards also require that necessary changes arising from preventive or corrective action are made to the asset management system.	The management team responsible for its asset management procedure(s). The team with overall responsibility for the management of the assets. Audit and incident investigation teams. Staff responsible for planning and managing corrective and preventive actions.	Analysis records, meeting notes and minutes, modification records. Asset management plan(s), investigation reports, audit reports, improvement programmes and projects. Recorded changes to asset management procedure(s) and process(es). Condition and performance reviews. Maintenance reviews
113	Continual Improvement	How does the organisation achieve continual improvement in the optimal combination of costs, asset related risks and the performance and condition of assets and asset systems across the whole life cycle?	4			Widely used AM standards have requirements to establish, implement and maintain process(es)/procedure(s) for identifying, assessing, prioritising and implementing actions to achieve continual improvement. Specifically there is a requirement to demonstrate continual improvement in optimisation of cost risk and performance/condition of assets across the life cycle. This question explores an organisation's capabilities in this area—looking for systematic improvement mechanisms rather than reviews and audit (which are separately examined).	The top management of the organisation. The manager/team responsible for managing the organisation's asset management system, including its continual improvement. Managers responsible for policy development and implementation.	Records showing systematic exploration of improvement. Evidence of new techniques being explored and implemented. Changes in procedure(s) and process(es) reflecting improved use of optimisation tools/techniques and available information. Evidence of working parties and research.

Schedule 14a - Mandatory Explanatory Notes on Forecast Information

Company Name: Electricity Invercargill Limited

For Year Ended: 31 March 2026

(In this Schedule, clause references are to the Electricity Distribution Information Disclosure Determination 2012 – as amended and consolidated 9 December 2021.)

1. This Schedule requires EDBs to provide explanatory notes to reports prepared in accordance with clause 2.6.6.

This Schedule is mandatory—EDBs must provide the explanatory comment specified below, in accordance with clause 2.7.2. This information is not part of the audited disclosure information, and so is not subject to the assurance requirements specified in section 2.8.

Commentary on difference between nominal and constant price capital expenditure forecasts (Schedule 11a)

2. In the box below, comment on the difference between nominal and constant price capital expenditure for the current disclosure year and 10 year planning period, as disclosed in Schedule 11a.

Box 1: Commentary on difference between nominal and constant price capital expenditure forecasts

Inflationary assumptions were used to calculate the nominal prices in the forecast. Nominal Prices are based on NZ Treasury’s economic forecasts, as published in the Half Year Economic and Fiscal Update released December 2025.

	2026/27	2027/28	2028/29	2029/30	2030/31
Inflator CAPEX	2.4%	2.200%	2.100%	2.000%	2.000%

Forecasts are in line with the business plan projections and explanations outlined in the Asset Management Plan

Commentary on difference between nominal and constant price operational expenditure forecasts (Schedule 11b)

3. In the box below, comment on the difference between nominal and constant price operational expenditure for the current disclosure year and 10 year planning period, as disclosed in Schedule 11b.

Box 2: Commentary on difference between nominal and constant price operational expenditure forecasts

Nominal Prices are based on NZ Treasury’s economic forecasts, as published in the Half Year Economic and Fiscal Update released December 2025.

	2026/27	2027/28	2028/29	2029/30	2030/31
Inflator OPEX	2.4%	2.200%	2.100%	2.000%	2.000%

Forecasts are in line with the business plan projections and explanations outlined in the Asset Management Plan

ANNEXURE 4 – REFERENCES

Ref #	Description
1	Electricity Distribution Information Disclosure (amendments related to IM Review 2023) Amendment Determination 2024 [2024] NZCC 31, ISSN 1178-2560, Project no. 14.09/47300, Publication date: 27 November 2024, Commerce Commission, Wellington, New Zealand.
2	EIL's Strategic Plan.
3	ISO 31000:2009 Standard: Risk Management - Principles and Guidelines.
4	Health and Safety at Work Act 2015.
5	Electricity (Safety) Regulations 2010
6	Electricity (Hazards from Trees) Regulations 2003.
7	Maintaining safe clearances from live conductors (NZECP34 or AS2067).
8	EEA Guide to Power System Earthing Practice 2009
9	https://comcom.govt.nz/regulated-industries/electricity-lines/electricity-distributor-performance-and-data/performance-accessibility-tool-for-electricity-distributors
10	https://comcom.govt.nz/regulated-industries/electricity-lines/electricity-distributor-performance-and-data/trends-in-local-lines-company-performance

ANNEXURE 5 – AMP DISCLOSURE TABLE

Electricity Distribution Information Disclosure (amendments related to IM Review 2023) Amendment Determination 2024			
Attachment A; Asset Management Plans - Mandatory disclosure requirements			
AMP design			Where in the AMP? (Chapter/ paragraph)
1	The core elements of asset management—		
1.1		A focus on measuring network performance, and managing the assets to achieve service targets;	2.2; 5; 10.2
1.2		Monitoring and continuously improving asset management practices;	10.3; 10.4
1.3		Close alignment with corporate vision and strategy;	2.1; 2.5
1.4		That asset management is driven by clearly defined strategies, business objectives and service level targets;	2; 5; 6
1.5		That responsibilities and accountabilities for asset management are clearly assigned	2.2; 2.6
1.6		An emphasis on knowledge of what assets are owned and why, the location of the assets and the condition of the assets;	3
1.7		An emphasis on optimising asset utilisation and performance;	6
1.8		That a total life cycle approach should be taken to asset management;	6
1.9		That the use of 'non-network' solutions and demand management techniques as alternatives to asset acquisition is considered.	2.1; 7.1; 7.2; 7.3; 7.6
2	The disclosure requirements are designed to produce AMPs that—		
2.1		Are based on, but are not limited to, the core elements of asset management identified in clause 1;	Overall
2.2		Are clearly documented and made available to all stakeholders;	Website
2.3		Contain sufficient information to allow interested persons to make an informed judgement about the extent to which the EDB's asset management processes meet best practice criteria and outcomes are consistent with outcomes produced in competitive markets;	2.5
2.4		Specifically support the achievement of disclosed service level targets;	5; 10.2
2.5		Emphasise knowledge of the performance and risks of assets and identify opportunities to improve performance and provide a sound basis for ongoing risk assessment;	4
2.6		Consider the mechanics of delivery including resourcing;	2.5; 9.1; 9.2
2.7		Consider the organisational structure and capability necessary to deliver the AMP;	2.6
2.8		Consider the organisational and contractor competencies and any training requirements;	6.2; Schedule 13
2.9		Consider the systems, integration and information management necessary to deliver the plans;	9
2.10		To the extent practical, use unambiguous and consistent definitions of asset management processes and terminology consistent with the terms used in this attachment to enhance comparability of asset management practices over time and between EDBs; and	Overall
2.11		Promote continual improvements to asset management practices.	10.4

Contents of the AMP				
3			The AMP must include the following:	
	3.1		A summary that provides a brief overview of the contents and highlights information that the EDB considers significant;	Exec Summary
	3.2		Details of the background and objectives of the EDB's asset management and planning processes;	2.1; 6
	3.3		A purpose statement which -	
		3.3.1	makes clear the purpose and status of the AMP in the EDB's asset management practices. The purpose statement must also include a statement of the objectives of the asset management and planning processes;	1; 2.5; 6
		3.3.2	states the corporate mission or vision as it relates to asset management;	2.1
		3.3.3	identifies the documented plans produced as outputs of the annual business planning process adopted by the EDB;	2.5
		3.3.4	states how the different documented plans relate to one another, with particular reference to any plans specifically dealing with asset management; and	2.5
		3.3.5	includes a description of the interaction between the objectives of the AMP and other corporate goals, business planning processes, and plans;	2.5
			<i>The purpose statement should be consistent with the EDB's vision and mission statements, and show a clear recognition of stakeholder interest.</i>	
	3.4		Details of the AMP planning period, which must cover at least a projected period of 10 years commencing with the disclosure year following the date on which the AMP is disclosed;	1.1
			<i>Good asset management practice recognises the greater accuracy of short-to-medium term planning, and will allow for this in the AMP. The asset management planning information for the second 5 years of the AMP planning period need not be presented in the same detail as the first 5 years.</i>	
	3.5		The date that it was approved by the directors;	Annexure
	3.6		A description of stakeholder interests (owners, consumers etc) which identifies important stakeholders and indicates-	2.2
		3.6.1	how the interests of stakeholders are identified	2.2
		3.6.2	what these interests are;	2.2
		3.6.3	how these interests are accommodated in asset management practices; and	2.2
		3.6.4	how conflicting interests are managed;	2.2
	3.7		A description of the accountabilities and responsibilities for asset management on at least 3 levels, including	2.2; 2.6
		3.7.1	governance—a description of the extent of director approval required for key asset management decisions and the extent to which asset management outcomes are regularly reported to directors;	2.6
		3.7.2	executive—an indication of how the in-house asset management and planning organisation is structured; and	2.6

	3.7.3	field operations—an overview of how field operations are managed, including a description of the extent to which field work is undertaken in-house and the areas where outsourced contractors are used;	2.6
3.8		All significant assumptions	1.3
	3.8.1	quantified where possible;	1.3
	3.8.2	clearly identified in a manner that makes their significance understandable to interested persons, including	1.3
	3.8.3	a description of changes proposed where the information is not based on the EDB's existing business;	N/A
	3.8.4	the sources of uncertainty and the potential effect of the uncertainty on the prospective information; and	1.3
	3.8.5	the price inflator assumptions used to prepare the financial information disclosed in nominal New Zealand dollars in the Report on Forecast Capital Expenditure set out in Schedule 11a and the Report on Forecast Operational Expenditure set out in Schedule 11b;	Annexure 3
3.9		A description of the factors that may lead to a material difference between the prospective information disclosed and the corresponding actual information recorded in future disclosures;	1.4
3.10		An overview of asset management strategy and delivery;	2.1; 2.5
		<p><i>To support the Report on Asset Management Maturity disclosure and assist interested persons to assess the maturity of asset management strategy and delivery, the AMP should identify-</i></p> <ul style="list-style-type: none"> <i>• how the asset management strategy is consistent with the EDB's other strategy and policies;</i> <i>• how the asset strategy takes into account the life cycle of the assets;</i> <i>• the link between the asset management strategy and the AMP; and</i> <i>• processes that ensure costs, risks and system performance will be effectively controlled when the AMP is implemented.</i> 	
3.11		An overview of systems and information management data;	9.3
		<p>To support the Report on Asset Management Maturity disclosure and assist interested persons to assess the maturity of systems and information management, the AMP should describe-</p> <ul style="list-style-type: none"> the processes used to identify asset management data requirements that cover the whole of life cycle of the assets; the systems used to manage asset data and where the data is used, including an overview of the systems to record asset conditions and operation capacity and to monitor the performance of assets; the systems and controls to ensure the quality and accuracy of asset management information; and the extent to which these systems, processes and controls are integrated. 	
3.12		A statement covering any limitations in the availability or completeness of asset management data and disclose any initiatives intended to improve the quality of this data;	9.3
		<i>Discussion of the limitations of asset management data is intended to enhance the transparency of the AMP and identify gaps in the asset management system.</i>	
3.13		A description of the processes used within the EDB for:	

	3.13.1	managing routine asset inspections and network maintenance;	8.1
	3.13.2	planning and implementing network development projects; and	7.1
	3.13.3	measuring network performance;	10.2
3.14		An overview of asset management documentation, controls and review processes.	2.5; 6
		<i>To support the Report on Asset Management Maturity disclosure and assist interested persons to assess the maturity of asset management documentation, controls and review processes, the AMP should-</i> <i>(i) identify the documentation that describes the key components of the asset management system and the links between the key components;</i> <i>(ii) describe the processes developed around documentation, control and review of key components of the asset management system;</i> <i>(iii) where the EDB outsources components of the asset management system, the processes and controls that the EDB uses to ensure efficient and cost effective delivery of its asset management strategy;</i> <i>(iv) where the EDB outsources components of the asset management system, the systems it uses to retain core asset knowledge in-house; and</i> <i>(v) audit or review procedures undertaken in respect of the asset management system.</i>	
3.15		An overview of communication and participation processes;	1.2; 2.1; 6.1
		<i>To support the Report on Asset Management Maturity disclosure and assist interested persons to assess the maturity of asset management documentation, controls and review processes, the AMP should-</i> <i>(i) communicate asset management strategies, objectives, policies and plans to stakeholders involved in the delivery of the asset management requirements, including contractors and consultants; and</i> <i>(ii) demonstrate staff engagement in the efficient and cost effective delivery of the asset management requirements.</i>	
3.16		The AMP must present all financial values in constant price New Zealand dollars except where specified otherwise; and	1.3
3.17		The AMP must be structured and presented in a way that the EDB considers will support the purposes of AMP disclosure set out in clause 2.6.2 of the determination.	Overall
Assets covered			
4		The AMP must provide details of the assets covered and non-network solutions, including	
4.1		a high-level description of the service areas covered by the EDB and the degree to which these are interlinked, including	2.7; 3.1
	4.1.1	the region(s) covered;	2.7
	4.1.2	identification of large consumers that have a significant impact on network operations or asset management priorities;	2.7
	4.1.3	description of the load characteristics for different parts of the network;	3.1
	4.1.4	peak demand and total energy delivered in the previous year, broken down by sub-network, if any.	3.1

4.2		a description of the network configuration, including-	
	4.2.1	identifying bulk electricity supply points and any distributed generation with a capacity greater than 1 MW. State the existing firm supply capacity and current peak load of each bulk electricity supply point;	3.1
	4.2.2	a description of the subtransmission system fed from the bulk electricity supply points, including the capacity of zone substations and the voltage(s) of the subtransmission network(s). The AMP must identify the supply security provided at individual zone substations, by describing the extent to which each has n-x subtransmission security or by providing alternative security class ratings;	3.1; 7.2
	4.2.3	a description of the distribution system, including the extent to which it is underground;	3.1
	4.2.4	a brief description of the network's distribution substation arrangements;	3.1
	4.2.5	a description of the low voltage network including the extent to which it is underground;	3.1
	4.2.6	an overview of secondary assets such as protection relays, ripple injection systems, SCADA and telecommunications systems; and	3.1
	4.2.7	a quantification of the contribution each non-network solution makes towards solving a network risk or constraint, and a description of the extent to which those non-network solutions are provided by a related party or third party.	7.1
		<i>To help clarify the network descriptions, network maps and a single line diagram of the subtransmission network should be made available to interested persons. These may be provided in the AMP or, alternatively, made available upon request with a statement to this effect made in the AMP.</i>	3.1
4.3		If sub-networks exist, the network configuration information referred to in clause 4.2 must be disclosed for each sub-network.	N/A
Network assets by category			
4.4		The AMP must describe the network assets by providing the following information for each asset category	3.1
	4.4.1	voltage levels;	3.1
	4.4.2	description and quantity of assets;	3.1
	4.4.3	age profiles; and	3.1
	4.4.4	a discussion of the condition of the assets, further broken down into more detailed categories as considered appropriate. Systemic issues leading to the premature replacement of assets or parts of assets should be discussed.	3.1
4.5		The asset categories discussed in clause 4.4 should include at least the following	
	4.5.1	the categories listed in the Report on Forecast Capital Expenditure in Schedule 11a(iii);	3.1
	4.5.2	assets owned by the EDB but installed at bulk electricity supply points owned by others;	N/A
	4.5.3	EDB owned mobile substations and generators whose function is to increase supply reliability or reduce peak demand; and	3.1
	4.5.4	other generation plant owned by the EDB.	3.1

Service Levels				
5			The AMP must clearly identify or define a set of performance indicators for which annual performance targets have been defined. The annual performance targets must be consistent with business strategies and asset management objectives and be provided for each year of the AMP planning period. The targets should reflect what is practically achievable given the current network configuration, condition and planned expenditure levels. The targets should be disclosed for each year of the AMP planning period.	5.1; 5.2
6			Performance indicators for which targets have been defined in clause 5 must include SAIDI values and SAIFI values for the next 5 disclosure years.	5.1
7			Performance indicators for which targets have been defined in clause 5 should also include	
		7.1	Consumer oriented indicators that preferably differentiate between different consumer types; and	5.1
		7.2	Indicators of asset performance, asset efficiency and effectiveness, and service efficiency, such as technical and financial performance indicators related to the efficiency of asset utilisation and operation.	10.2; 10.4
8			The AMP must describe the basis on which the target level for each performance indicator was determined. Justification for target levels of service includes consumer expectations or demands, legislative, regulatory, and other stakeholders' requirements or considerations. The AMP should demonstrate how stakeholder needs were ascertained and translated into service level targets.	5.1
9			Targets should be compared to historic values where available to provide context and scale to the reader.	5.1
10			Where forecast expenditure is expected to materially affect performance against a target defined in clause 5, the target should be consistent with the expected change in the level of performance.	5.1; 5.2
			<i>Performance against target must be monitored for disclosure in the Evaluation of Performance section of each subsequent AMP.</i>	
Network Development Planning				
11			AMPs must provide a detailed description of network development plans, including—	
	11.1		A description of the planning criteria and assumptions for network development;	7.1
	11.2		Planning criteria for network developments should be described logically and succinctly. Where probabilistic or scenario-based planning techniques are used, this should be indicated and the methodology briefly described;	7.1
	11.3		A description of strategies or processes (if any) used by the EDB that promote cost efficiency including through the use of standardised assets and designs;	6.1; 7.2
	11.4		The use of standardised designs may lead to improved cost efficiencies. This section should discuss	
		11.4.1	the categories of assets and designs that are standardised; and	7.2
		11.4.2	the approach used to identify standard designs;	7.2
	11.5		A description of strategies or processes (if any) used by the EDB that promote the energy efficient operation of the network;	

		<i>The energy efficient operation of the network could be promoted, for example, through network design strategies, demand side management strategies and asset purchasing strategies.</i>	
11.6		A description of the criteria used to determine the capacity of equipment for different types of assets or different parts of the network;	7.1; 7.2
		<i>The criteria described should relate to the EDB's philosophy in managing planning risks.</i>	
11.7		A description of the process and criteria used to prioritise network development projects and how these processes and criteria align with the overall corporate goals and vision;	2.1; 2.2; 7.2
11.8		Details of demand forecasts, the basis on which they are derived, and the specific network locations where constraints are expected due to forecast increases in demand;	7.1
	11.8.1	explain the load forecasting methodology and indicate all the factors used in preparing the load estimates;	7.1
	11.8.2	provide separate forecasts to at least the zone substation level covering at least a minimum five year forecast period. Discuss how uncertain but substantial individual projects/developments that affect load are taken into account in the forecasts, making clear the extent to which these uncertain increases in demand are reflected in the forecasts;	7.1
	11.8.3	identify any network or equipment constraints that may arise due to the anticipated growth in demand during the AMP planning period; and	7.1
	11.8.4	discuss the impact on the load forecasts of any anticipated levels of non-network solutions in a network;	7.1
11.9		Analysis of the significant network level development options identified and details of the decisions made to satisfy and meet target levels of service, including	
	11.9.1	the reasons for choosing a selected option for projects where decisions have been made;	7.1
	11.9.2	the alternative options considered for projects that are planned to start in the next five years and the potential for non-network solutions described; and	7.1
	11.9.3	consideration of planned innovations that improve efficiencies within the network, such as improved utilisation, extended asset lives, and deferred investment;	7.2
11.10		A description and identification of the network development programme including non-network solutions and actions to be taken, including associated expenditure projections. The network development plan must include	7.1
	11.10.1	a detailed description of the material projects and a summary description of the non-material projects currently underway or planned to start within the next 12 months;	7.1
	11.10.2	a summary description of the programmes and projects planned for the following four years (where known); and	7.1
	11.10.3	an overview of the material projects being considered for the remainder of the AMP planning period;	7.1; 7.2; 7.3; 7.5

			<i>For projects included in the AMP where decisions have been made, the reasons for choosing the selected option should be stated which should include how target levels of service will be impacted. For other projects planned to start in the next five years, alternative options should be discussed, including a detailed description of the investigations undertaken in respect of the potential for non-network solutions to be more cost effective than network augmentations and vice-versa. This should specify if any third parties were approached in relation to non-network solutions, and if so, whether those third parties are related parties. For the purposes of disclosing the information described in clause 11.10.3, an EDB is not required to include commercially sensitive or confidential information.</i>	
11.11			A description of the EDB's policies on distributed generation, including the policies for connecting distributed generation. The impact of such generation on network development plans must also be stated;	7.2
11.12			A description of the EDB's policies on non-network solutions, including	
	11.12.1		economically feasible and practical alternatives to conventional network augmentation. These are typically approaches that would reduce network demand and/or improve asset utilisation;	7.2
	11.12.2		the potential for non-network solutions to address network problems or constraints; and	7.2
	11.12.3		how information on current and forecast constraints (both load and injection) is shared with potential providers of non-network solutions. This must include any information on low voltage network constraints, including the constraint information the EDB derives from the data specified under clause 17.2.2 of Attachment A.	
Lifecycle Asset Management Planning (Maintenance and Renewal)				
12			The AMP must provide a detailed description of the lifecycle asset management processes, including—	6.1
	12.1		The key drivers for maintenance planning and assumptions;	8
	12.2		Identification of routine and corrective maintenance and inspection policies and programmes and actions to be taken for each asset category, including associated expenditure projections. This must include	8
		12.2.1	the approach to inspecting and maintaining each category of assets, including a description of the types of inspections, tests and condition monitoring carried out and the intervals at which this is done;	8.2
		12.2.2	any systemic problems identified with any particular asset types and the proposed actions to address these problems; and	7.3; 7.7
		12.2.3	budgets for maintenance activities broken down by asset category for the AMP planning period;	8.4
	12.3		Identification of asset replacement and renewal policies and programmes and actions to be taken for each asset category, including associated expenditure projections. This must include	7.3
		12.3.1	the processes used to decide when and whether an asset is replaced or refurbished, including a description of the factors on which decisions are based, and consideration of future demands on the network and the optimum use of existing network assets;	7.3
		12.3.2	a description of innovations that have deferred asset replacements;	7.3

	12.3.3	a description of the projects currently underway or planned for the next 12 months;	7.3
	12.3.4	a summary of the projects planned for the following four years (where known); and	7.3
	12.3.5	an overview of other work being considered for the remainder of the AMP planning period; and	7.3
12.4		The asset categories discussed in clauses 12.2 and 12.3 should include at least the categories in clause 4.5.	
Non-Network Development, Maintenance and Renewal			
13		AMPs must provide a summary description of material non-network development, maintenance and renewal plans, including—	
	13.1	a description of non-network assets;	N/A
	13.2	development, maintenance and renewal policies that cover them;	N/A
	13.3	a description of material capital expenditure projects (where known) planned for the next five years; and	N/A
	13.4	a description of material maintenance and renewal projects (where known) planned for the next five years.	N/A
Risk Management			
14		AMPs must provide details of risk policies, assessment, and mitigation, including—	4
	14.1	Methods, details and conclusions of risk analysis;	4.2
	14.2	Strategies used to identify areas of the network that are vulnerable to high impact low probability events and a description of the resilience of the network and asset management systems to such events;	4.3; 4.4
	14.3	A description of the policies to mitigate or manage the risks of events identified in clause 14.2; and	4.4
	14.4	Details of emergency response and contingency plans.	4.4
		<i>Asset risk management forms a component of an EDB's overall risk management plan or policy, focusing on the risks to assets and maintaining service levels. AMPs should demonstrate how the EDB identifies and assesses asset related risks and describe the main risks within the network. The focus should be on credible low-probability, high-impact risks. Risk evaluation may highlight the need for specific development projects or maintenance programmes. Where this is the case, the resulting projects or actions should be discussed, linking back to the development plan or maintenance programme.</i>	
Evaluation of performance			
15		AMPs must provide details of performance measurement, evaluation, and improvement, including—	
	15.1	A review of progress against plan, both physical and financial;	10.1; 10.2

		<ul style="list-style-type: none"> referring to the most recent disclosures made under Section 2.6 of this determination, discussing any significant differences and highlighting reasons for substantial variances; commenting on the progress of development projects against that planned in the previous AMP and provide reasons for substantial variances along with any significant construction or other problems experienced; and commenting on progress against maintenance initiatives and programmes and discuss the effectiveness of these programmes noted. 	
15.2		An evaluation and comparison of actual service level performance against targeted performance;	10.2
		<ul style="list-style-type: none"> in particular, comparing the actual and target service level performance for all the targets discussed under the Service Levels section of the AMP in the previous AMP and explain any significant variances. 	
15.3		An evaluation and comparison of the results of the asset management maturity assessment disclosed in the Report on Asset Management Maturity set out in Schedule 13 against relevant objectives of the EDB's asset management and planning processes.	10.4; Schedule 13
15.4		An analysis of gaps identified in clauses 15.2 and 15.3. Where significant gaps exist (not caused by one-off factors), the AMP must describe any planned initiatives to address the situation.	10.4
Capability to deliver			
16		AMPs must describe the processes used by the EDB to ensure that-	
16.1		The AMP is realistic and the objectives set out in the plan can be achieved; and	1.3; 9.1
16.2		The organisation structure and the processes for authorisation and business capabilities will support the implementation of the AMP plans.	1.2; 2.6
Requirements to provide qualitative information in narrative form			
17		AMPs must include qualitative information in narrative form, as prescribed in clauses 17.1-17.7 below:	
Notice of planned and unplanned interruptions			
17.1		a description of how the EDB provides notice to and communicates with consumers regarding planned interruptions and unplanned interruptions, including any changes to the EDB's processes and communications in respect of planned interruptions and unplanned interruptions;	5.1; 8.3; 10.2
Voltage quality and constraints			
17.2		a description of the EDB's practices for:	


	17.2.1	<p>monitoring voltage, including:</p> <p>(a) the EDB's practices for monitoring voltage quality on its low voltage network;</p> <p>(b) work the EDB is doing on its low voltage network to address any known non-compliance with the applicable voltage requirements of the Electricity (Safety) Regulations 2010;</p> <p>(c) how the EDB responds to and reports on voltage quality issues when the EDB identifies them, or when they are raised by a stakeholder;</p> <p>(d) how the EDB communicates with affected consumers regarding the voltage quality work it is carrying out on its low voltage network; and</p> <p>(e) any plans for improvements to any of the practices outlined at clauses (a)-(d) above;</p>	5.1; 6.2; 7.3; 8.2; 8.3
	17.2.2	<p>monitoring load and injection constraints, including:</p> <p>(a) any challenges, and progress, towards collecting or procuring data required to inform the EDB of current and forecast constraints on its low voltage network, including historical consumption data; and</p> <p>(b) any analysis and modelling (including any assumptions and limitations) the EDB undertakes, or intends to undertake, with the data described in clause 17.2.2(a).</p>	7.1
Customer service practices			
		There may be a degree of overlap between the information required under this clause and the information required in respect of customer charters under clause 2.5.3. For the avoidance of doubt, if there is overlap, EDBs should disclose the information in both places.	
	17.3	a description of the EDB's customer service practices, including:	
	17.3.1	the EDB's customer engagement protocols and customer service measures – including customer satisfaction with the EDB's supply of electricity distribution services;	5.1
	17.3.2	the EDB's approach to planning and managing customer complaint resolution;	5.1; 10.2
Practices for connecting new consumers and altering existing connections			
	17.4	a description of the EDB's practices for connecting consumers, including:	
	17.4.1	the EDB's approach to planning and management of- (a) connecting new consumers (offtake and injection connections), and overcoming commonly encountered issues; and (b) alterations to existing connections (offtake and injection connections);	Exec Summary; 2.8; 7.1
	17.4.2	how the EDB is seeking to minimise the cost to consumers of new or altered connections;	7.1
	17.4.3	the EDB's approach to planning and managing communication with consumers about new or altered connections;	5.1
	17.4.4	commonly encountered delays and potential timeframes for different connections; and	5.1; 7.1
	17.4.5	the EDB's approach to sharing information on current and forecast constraints (both load and injection) with potential new consumers. This must include any information on low voltage network constraints, including the constraint information the EDB derives from the data specified under clause 17.2.2(a) of Attachment A.	7.1

New connections likely to have a significant impact on network operations or asset management priorities			
		The following requirements focus on the EDB's capability and risk management regarding demand, generation, or storage capacity that the EDB considers are likely to have a significant impact on its network operations or asset management priorities. The EDB may consider voltage, network location, or other factors in making this assessment.	
	17.5	A description of the following:	
	17.5.1	how the EDB assesses the impact that new demand, generation, or storage capacity will have on the EDB's network, including: (a) how the EDB measures the scale and impact of new demand, generation, or storage capacity; (b) how the EDB takes the timing and uncertainty of new demand, generation, or storage capacity into account; (c) how the EDB takes other factors into account, eg, the network location of new demand, generation, or storage capacity; and	1.3; 7.1
	17.5.2	how the EDB assesses and manages the risk to the network posed by uncertainty regarding new demand, generation, or storage capacity;	4; 7.1
Innovation practices			
	17.6	a description of the following:	
	17.6.1	any innovation practices the EDB has planned or undertaken since the last AMP or AMP update was publicly disclosed, including case studies and trials;	NA
	17.6.2	the EDB's desired outcomes of any innovation practices, and how they may improve outcomes for consumers;	NA
	17.6.3	how the EDB measures success and makes decisions regarding any innovation practices, including how the EDB decides whether to commence, commercially adopt, or discontinue these practices;	NA
	17.6.4	how the EDB's decision-making and innovation practices depend on the work of other companies, including other EDBs and providers of non-network solutions; and	NA
	17.6.5	the types of information the EDB uses to inform or enable any innovation practices, and the EDB's approach to seeking that information.	NA
	17.7	For the purpose of disclosing the information required under clauses 17.6.1-17.6.5 above, an EDB is not required to include commercially sensitive or confidential information.	NA


Annexure 6 – Directors' Approval

We, Stephen Paul Lewis (Chair) and Simon Venn Young, being directors of Electricity Invercargill Limited certify that, having made all reasonable enquiry, to the best of our knowledge:

- a. The following attached information of Electricity Invercargill Limited prepared for the purposes of clauses 2.6.1, 2.6.3 and 2.7.2 of the Electricity Distribution Information Disclosure Determination 2012 in all material respects complies with that determination.
- b. The prospective financial or non-financial information included in the attached information has been measured on a basis consistent with regulatory requirements or recognised industry standards.
- c. The forecasts in Schedules 11a, 11b, 12a, 12b, 12c, 12d and 14a are based on objective and reasonable assumptions which both align with Electricity Invercargill Limited corporate purpose and strategy and are documented in retained records.



Stephen Paul Lewis (Chair)



Simon Venn Young

19th March 2026
Date

← Centre Management
Offices
Car Park P
Farmers ↑

COTTON ON

MERCHANT

WALKER